



① REMOVE EXISTING CONDENSATE PUMP (CP-3 & CP-4) AS INDICATED.

1. PROVIDE NEW CONDENSATE PUMPS (CP-3 & CP-4) AS INDICATED. MOUNT NEW BASES TO EXISTING HOUSEKEEPING PAD.
2. PROVIDE NEW 1500HPS PIPE FROM EXISTING ROUTE TO DISTRIBUTION IN 615 BOOTH AS INDICATED. REFER TO 2/M302 FOR CONTINUATION.
3. OFFSET PIPE UP APPROXIMATELY 600mm TO AVOID INTERFERENCE WITH EXISTING DUCTWORK.
4. PROVIDE NEW 50# PRESSURE REGULATING BYPASS BACK TO CONDENSATE TANK THROUGH EXISTING PUMPED CONDENSATE LINE AS INDICATED.
5. PROVIDE NEW STEAM TRAPS AT DRIP LEGS AS INDICATED TO ACCOMMODATE ROUTING WITH AVAILABLE SPACE ON SITE. EXTEND HPS PIPING BACK TO MAIN FEEDING FLASH TANK AS INDICATED.
6. PROVIDE NEW 50# COND. PIPE FROM 615 BOOTH AND CONNECT TO EXISTING 100# COND. SERVING NEW BOILER PLANT AS INDICATED.



REFER TO 2/M302 FOR CONTINUATION

