



1
E301 1:100
BASEMENT PART PLAN
POWER - DEMOLITION WORK

2
E301 1:100
BASEMENT PART PLAN
POWER - NEW WORK

- DRAWING NOTES**
- 1 TYPICAL:
CONDENSATE PUMP REPLACED BY MECHANICAL CONTRACTOR.
DISCONNECT EXISTING PUMP, REMOVE WIRE AND COMBINATION
STARTERS AND MAKE SAFE.
- 2 TYPICAL:
NEW CONDENSATE PUMP SUPPLIED AND INSTALLED BY MECHANICAL
CONTRACTOR. PROVIDE NEW 15A/3PH/600V CIRCUIT AND NEW
COMBINATION BREAKER STYLE STARTER UNITS IN EXISTING MCC.
REUSE EXISTING CONDUIT TO PUMP AND PROVIDE FINAL
TERMINATION.



KEY PLAN
PLAN-REPÈRE

revision		date
05		
04	ISSUED FOR TENDER	2014/11/21
03	ISSUED FOR REVIEW	2014/10/06
02	ISSUED FOR 99% REVIEW	2014/07/14
01	ISSUED FOR 66% REVIEW	2014/05/30

A	A detail no. no. du détail	A
C	B location drawing no. no. de localisation	BC
	C drawing no. no. du dessin	

project project

555/601/615 BOOTH
STAND ALONE
HEATING PLANT

drawing dessin

615 BOOTH
BASEMENT FLOOR
POWER DEMOLITION AND
NEW WORK

designed	T.HOPKIN	conçu
date	2014/01/22	
drawn	T.HOPKIN	dessiné
date	2014/01/22	
revised	T.HOPKIN	révisé
date	2014/01/22	
approved	J.MOFFAT	approuvé
date	2014/01/22	
tender	C.CAMPBELL	soumission
PWC Project Manager	Administrateur de projets TPC	
project no.		no. du projet
	R.060128.002	

drawing no. no. du dessin

E301