



KEY PLAN
PLAN-REPÈRE

revision	date
05	
04	ISSUED FOR TENDER 2014/11/21
03	ISSUED FOR REVIEW 2014/10/06
02	ISSUED FOR 99% REVIEW 2014/07/14
01	ISSUED FOR 66% REVIEW 2014/05/30


A	A detail no. / no. du détail	A
C	B location drawing no. / no. de localisation	BC
	C drawing no. / no. du dessin	

project 555/601/615 BOOTH
STAND ALONE
HEATING PLANT





drawing 601 BOOTH
BASEMENT FLOOR
POWER DEMOLITION AND
NEW WORK

designed	T.HOPKIN	conçu
date	2014/01/22	
drawn	T.HOPKIN	dessiné
date	2014/01/22	
revised	T.HOPKIN	révisé
date	2014/01/22	
approved	J.MOFFAT	approuvé
date	2014/01/22	
tender	C.CAMPBELL	soumission
PWC Project Manager	Administrateur de projets TPC	
project no.	R.060128.002	no. du projet


drawing no. E201 / no. du dessin



1 E201 1:200
BASEMENT PART PLAN
POWER - NEW WORK



2 E201 1:100
BASEMENT PART PLAN - MECHANICAL ROOM
POWER - DEMOLITION WORK



3 E201 1:100
BASEMENT PART PLAN - MECHANICAL ROOM
POWER - NEW WORK

- DRAWING NOTES**
- NEW HEAT TRACE PANEL SUPPLIED AND INSTALLED BY MECHANICAL CONTRACTOR. PROVIDE NEW 25A/120V CIRCUIT, C/W GFI BREAKER, FROM PANEL 'LP-BEG' ON BASEMENT LEVEL. HEAT TRACE WIRING BY MECHANICAL CONTRACTOR.
 - TYPICAL: CONDENSATE PUMPS REPLACED BY MECHANICAL CONTRACTOR. DISCONNECT EXISTING PUMP AND COMBINATION STARTERS AND MAKE SAFE.
 - TYPICAL: NEW CONDENSATE PUMPS SUPPLIED AND INSTALLED BY MECHANICAL CONTRACTOR. PROVIDE NEW COMBINATION HAND/OFF/AUTO STARTER AND RECONNECT TO PREVIOUS CIRCUIT. PROVIDE TERMINATION TO NEW PUMPS.
 - NEW BOILER PLANT SUPPLIED AND INSTALLED BY MECHANICAL TRADES AT EXTERIOR GROUND LEVEL. PROVIDE NEW 60A/3PH/600V BREAKER IN EMERGENCY DISTRIBUTION PANEL DP-BEA AND EXTEND CIRCUIT TO NEW BOILER UNIT. REFER TO DRAWING E202.
 - NEW BOILER PLANT SUPPLIED AND INSTALLED BY MECHANICAL TRADES AT EXTERIOR GROUND LEVEL. PROVIDE NEW 120A/3PH/600V BREAKER AND BUS BAR EXTENSION KIT IN DISTRIBUTION PANEL DP-BD AND EXTEND CIRCUIT TO NEW BOILER UNIT. REFER TO DRAWING E202.