

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Penstock & Cylinder Refurbishment	
Solicitation No. - N° de l'invitation EZ108-151488/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2014-12-24
GETS Reference No. - N° de référence de SEAG PW-\$PWY-026-7394	
File No. - N° de dossier PWY-4-37231 (026)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-12-29	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Liu (PWY), Patty	Buyer Id - Id de l'acheteur pwy026
Telephone No. - N° de téléphone (604) 775-6227 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Esquimalt Graving Dock - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ108-151488/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

003

File No. - N° du dossier

PWY-4-37231

Buyer ID - Id de l'acheteur

pw026

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande

Amendment 003 attached.

All other terms and conditions remain unchanged.

The following changes/clarifications in the tender documents are effective immediately.

ANSWERS TO QUESTIONS RAISED BY CONTRACTORS

- Q1. **Plan Sheet 10** Hydraulic piping layout . Is the piping to be under the slab inside just when it enters the building, or all the way? where exactly?
- A1. The piping is to be under the slab just when it enters the building.
- Q2. **Plan sheet 7** There is a metal circular cover at the auxiliary access cover to be removed, Concrete at the lid to be removed, once work is complete it does not detail how the lid would go back on, if it even does.
- A2. Finished project as shown on drawings, lid does not need to be replaced by contractor.
- Q3. **Plan Sheet 8** Auxiliary Penstock gate , plan shows it going on the narrow side of the rectangle even though it fits going down perpendicular to where it goes Gate is 835mm wide, opening above is 790mm . I assume it has been worked out that it can be turned and installed as such , please confirm.
- A3. See note on drawing 8. Gate installation details represent a reference design to indicate required functionality and are to be read in conjunction with the specifications. Detailed system design and component specifications is the responsibility of the contractor."
- Q4. Specifications 03 30 00.01 Concrete 2.3.7.1 & .2 , .3 Patching compound . Please give us products names. Also how do we know what the existing mpa is? Please confirm what it is if we are to have the Mpa of the patching to be tuned up to the existing.
- A4. Product names will not be provided. MPa of existing concrete will vary; assume 35 MPa for tender purposes.
- Q5. **Sheet 10 Section C** concrete utility trench , Is this a cast in place or precast item? Galvanized checkered plate cover, what thickness is it? what load rating does it have ?
- A5. For concrete utility trench, either cast in place or precast is acceptable. For Galvanized checkered plate cover see specification section 055000 2.8
- Q6. Security Requirement: It is my understanding that escorts are not allowed to be used anymore for this type of security requirements. From what the documents show, it appears that we could have one cleared individual escorting the rest of the crew. Is that correct?

- A6. The escorting is only done via Commissionaires or by PWGSC employees – this cost will be born by the awarded contractor.

END OF AMENDMENT