

**Requisition No. EZ 899-151744/A**

**The following changes in the tender documents are effective immediately. This addendum will form part of the Contract documents.**

**Specifications:**

1. Section 01 14 00 Work Restrictions, Article 1.07 Special Requirements:

**Add:**

- .7 Security Contacts (Windows):
  - .1 Security Contacts requiring temporary removal and reinstallation to be serviced by Departmental Representative approved contractor. Contractor shall coordinate work with approved contractor.

**Drawings:**

1. REPLACE Drawing A000 'Issued for IFC' dated December 03, 2014 with Drawing A000 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
2. REPLACE Drawing A200 'Issued for IFC' dated December 03, 2014 with Drawing A200 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
3. REPLACE Drawing A301 'Issued for IFC' dated December 03, 2014 with Drawing A301 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
4. REPLACE Drawing A400 'Issued for IFC' dated December 03, 2014 with Drawing A400 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
5. REPLACE Drawing A401 'Issued for IFC' dated December 03, 2014 with Drawing A401 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
6. REPLACE Drawing A600 'Issued for IFC' dated December 03, 2014 with Drawing A600 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
7. REPLACE Drawing A700 'Issued for IFC' dated December 03, 2014 with Drawing A700 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
8. REPLACE Drawing A701 'Issued for IFC' dated December 03, 2014 with Drawing A701 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
9. REPLACE Drawing A702 'Issued for IFC' dated December 03, 2014 with Drawing A702 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
10. REPLACE Drawing A703 'Issued for IFC' dated December 03, 2014 with Drawing A703 'Issued for Addendum #02 – January 6, 2015' with revised areas and keynotes clouded.
11. ADD Drawing A704 'Issued for Addendum #02 – January 6, 2015'.

**Enquiries from Bidders:**

1. **Enquiry:** A301 colour legend points to 4/A702 doesn't appear to be the correct detail.

**Response:** Refer to attached revised Drawing A301 'Issued for Addendum #02 – January 6, 2015'. Colour Legend revised.

2. **Enquiry:** A703, Detail 6 points to detail 5/A703 however this doesn't appear to be correct detail for work described.

**Response:** Refer to attached revised Drawing A703 'Issued for Addendum #02 – January 6, 2015'. Detail reference deleted.

3. **Enquiry:** A703, Detail 6 points to detail 3/A703 which doesn't seem to coincide, please confirm.

**Response:** Refer to attached revised Drawing A703 'Issued for Addendum #02 – January 6, 2015'. Detail reference revised to read 6/A702.

4. **Enquiry:** Please specify inspection and repair requirements for kitchen area and shower area, as these will have different linear M prices for both remediation and inspection, also what inspection is required for our lump sum cost behind these areas.

**Response:** Refer to attached revised Drawing A301 'Issued for Addendum #02 – January 6, 2015'. Kitchen and shower areas are excluded.

5. **Enquiry:** The tender documents require that the security cameras and equipment be re-located by an approved contractor. Who pays for this and it is the general contractor we will require a list of approved contractors prior to tender closing.

**Response:** Security camera, antennae, and security contacts - remove and replace, where necessary, by and paid for by others. Contractor is responsible for coordination with other contractors employed by the Departmental Representative.

6. **Enquiry:** The contractor is to relocate the Cascade building sign during construction. Where will the sign be located to?

**Response:** Refer to attached revised Drawings A400 and A401, 'Issued for Addendum #02 – January 6, 2015'. Keynote 02-7 revised to read: **REMOVE & TEMPORARILY RELOCATE EXISTING SIGN, TO A LOCATION DIRECTED BY DEPARTMENTAL REPRESENTATIVE DURING INSTALLATION OF NEW EXTERIOR CLADDING ASSEMBLY. REINSTALL EXISTING SIGN AT SAME LOCATION AS PREVIOUSLY INSTALLED**'.

7. **Enquiry:** Some of the spacing of the aluminum reveals is such that it creates a lot of siding waste. Would we be able to make minor spacing changes to the reveals in order to decrease the amount of waste?

**Response:** Aluminum reveal configurations are to be in accordance with Drawings.

**END OF ADDENDUM**