

PART 1 - GENERAL

1.1 RELATED WORK .1 Electrical General Requirements: Section 26 05 00

PART 2 - PRODUCTS

- 2.1 EQUIPMENT .1 Clamps for grounding of conductor, size as required to grounding buses.
- .2 System and circuit, equipment, grounding conductors, bare stranded copper, un- tinned, soft annealed, size as indicated.
- .3 Insulated grounding conductors: green, type RW90 in all conduits. Minimum size: #14 AWG or as indicated in Table No. 16 of C.E.C., whichever is larger.
- .4 Ground bus: copper, size as indicated complete with insulated supports, fastenings and connectors.
- .5 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
- .1 Grounding and bonding bushings.
 - .2 Protective type clamps.
 - .3 Bolted type conductor connectors.
 - .4 Thermit welded type conductor connectors.
 - .5 Bonding jumpers, straps.
 - .6 Pressure wire connectors.
- .6 Copper crimp type compression connectors, (long barrel, two hole).
- 2.2 MANUFACTURERS .1 Acceptable manufacturers: FCI - Burndy Corporation, Erico Inc., Thomas & Betts, Ilsco.

PART 3 - EXECUTION

3.1 INSTALLATION
GENERAL

- .1 Install complete permanent, continuous, system and circuit, equipment, grounding systems including, conductors, connectors, accessories, as indicated, to conform to requirements of Departmental Representative, and local authority having jurisdiction over installation.
- .2 Install connectors in accordance with manufacturer's instructions.
- .3 Protect exposed grounding conductors from mechanical injury.
- .4 Use mechanical connectors for grounding connections to equipment provided with grounding lugs.
- .5 Soldered joints are not permitted.
- .6 Make grounding connections in radial configurations only, with connections terminating at single grounding point. Avoid loop connections.
- .7 Provide insulated copper bonding conductor in all conduit runs.

3.2 SYSTEM AND
CIRCUIT GROUNDING

- .1 Install system and circuit grounding connections to neutral of secondary systems.

3.3 EQUIPMENT
GROUNDING

- .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list: transformers and power factor correction equipment.
- .2 Install grounding connection(s) to generator frame and neutral in accordance with manufacturer's instructions and applicable CEC requirements.

3.4 GROUNDING BUS

- .1 Install new copper grounding bus as indicated, mounted on insulated supports on the wall.
- .2 Ground items of electrical equipment to ground bus.

- 3.5 FIELD QUALITY CONTROL
-
- .1 Perform tests in accordance with Section 26 05 00.
 - .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
 - .3 Perform tests before energizing electrical system.