

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving
PWGSC
33 City Centre Drive
Suite 480C
Mississauga
Ontario
L5B 2N5
Bid Fax: (905) 615-2095

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Ontario Region
33 City Centre Drive
Suite 480
Mississauga
Ontario
L5B 2N5

Title - Sujet Walk-In Freezer	
Solicitation No. - N° de l'invitation W3508-140225/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client W3508-140225	Date 2015-01-12
GETS Reference No. - N° de référence de SEAG PW-\$TOR-029-6706	
File No. - N° de dossier TOR-4-37085 (029)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-01-20	
Time Zone Fuseau horaire Eastern Standard Time EST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Cunning, David	
Buyer Id - Id de l'acheteur tor029	
Telephone No. - N° de téléphone (905) 615-2466 ()	FAX No. - N° de FAX (905) 615-2060
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

W3508-140225/A

Client Ref. No. - N° de réf. du client

W3508-140225

Amd. No. - N° de la modif.

002

File No. - N° du dossier

TOR-4-37085

Buyer ID - Id de l'acheteur

tor029

CCC No./N° CCC - FMS No/ N° VME

Amendment 001 has been issued to make a change to the Solicitation.

At Page 1, Solicitation Closes

Delte: 2015-01-12

Insert: 2015-01-20

AMENDMENT 001 IS ISSUED TO ANSWER QUESTIONS FROM POTENTIAL BIDDERS

Questions and Answers

Q1: Is this an indoor Freezer?

A1: This freezer will be installed inside the kitchen, not outdoors, located at the 4th Canadian Division Training Centre Kitchen, Bldg. M-206, Meaford, ON.

Q2: Can you confirm the location of the condensing unit and how far away is it from the walk-in?

A2: The Condensing unit is located on a flat roof above the present freezer, approximately 20 ft away. The line set's run via a roof penetration which can be re used when the old freezer is removed.

Q3: Under scope of work by others it states drains by contractor, where is the drain?

A3: The current system has a gravity system via pipe mounted on exterior of cabinet and runs to floor drain. Condensate pump to drain is other option.

Q4: Under scope of work electrical by contractor, who is the contractor?

A4: Sourcing the electrical contractor is done by the bidder.

Q5: Is Coring and patching required for roof penetration?

A5: Coring and patching is not required as existing roof cone/penetration to be used.

Q6: How is the compressor unit set up?

A6: The compressor unit must be set up off the roof membrane to not wear a hole through the roof. See attached pictures.

Q7: Are there any layouts of drawings?

A7: See attachment with the freeze drawing. The maximum exterior dimensions are 195.5" width X 240" length X 103" height.

Q8: Should the steel door and frame have an air curtain?

A8: There must be a Vinyl strip air curtain (inside freezer) over door.

Q9: Who removes the old freezer?

A9: The existing freezer will be removed by the client prior to the installation of the new freezer.





