

E1 – ELECTRICAL LEGEND, LIST OF DRAWINGS AND SUBSCRIPTS.

E2 – DEMOLITION LIGHTING AND FIRE ALARM SYSTEMS FLOOR PLAN – LEVEL 3.

E3 – DEMOLITION POWER AND MISC. SYSTEMS FLOOR PLAN – LEVEL 3.

E4 – REVISED LIGHTING AND FIRE ALARM SYSTEMS FLOOR PLAN – LEVEL 3.

E5 – REVISED POWER AND MISC. SYSTEMS FLOOR PLAN – LEVEL 3.

E6 – SECURITY SYSTEM FLOOR PLAN – LEVEL 3

E7 – PANEL SCHEDULES, LIGHTING FIXTURE SCHEDULE AND HEATING FIXTURE SCHEDULE.

LIST OF SUBSCRIPTS.

E – INDICATES EXISTING TO REMAIN.


ER – INDICATES EXISTING TO BE REMOVED.

L.V. – LOW VOLTAGE THERMOSTAT.

RL – INDICATES EXISTING TO BE RELOCATED.

- E - INDICATES EXISTING TO REMAIN.
- INDICATES EXISTING TO BE REMOVED.
- ER -
- L.V. - LOW VOLTAGE THERMOSTAT.
-
- RL - INDICATES EXISTING TO BE RELOCATED.

- | A19 | |
|-----|--|
| — | FLUORESCENT LUMINAIRE TYPE AS SPECIFIED. CONNECT TO PANEL A, CIRCUIT 19. |
| — | LINE INDICATES UNWITHEDED LIGHT FIXTURE. |
| ③ | — LED, COMPACT FLUORESCENT, OR HID LUMINAIRE TYPE "B", CEILING MOUNTED. |
| \$ | — TOGGLE SWITCH, 347 VAC, 15 AMP. |
| \$p | — TOGGLE DIMMER SWITCH, 347 VAC, 15 AMP. |
| ⑤ | — CEILING MOUNTED LINE VOLTAGE OCCUPANCY SENSOR. |
| ▽ | — SINGLE DATA OUTLET |
| ▽ | — 2-DATA OUTLET, 1-VOICE AND 1-SPEAK. PROVIDE 3 CARB CABLES TO TELCOM ROOM 3008(CABLING INSTALLED IN FRIE AIR TO BE TTB PLENUM RATED). |
| ▼ | — VOICE OUTLET, PROVIDE CARB CABLEING TO TELCOM ROOM 3008, STUB 21mm CONDUIT TO CEILING SPACE. CABLING INSTALLED IN FRIE AIR TO BE TTB PLENUM RATED. |
| ⑤ | — HIGH INTENSITY STROBE FIRE ALARM SIGNAL, CEILING MOUNTED. |
| ⑤ | — STROBE/HORN STYLE FIRE ALARM SIGNAL. |
| □ | — DOORBELL CHIME, STANDARD OR ACCEPTANCE; HONEYWELL RM100N100/N OR EQUAL. |
| ① | — DUPLEX CONVENIENCE RECEPTACLE, 120V, 15 AMP, CSA TYPE 5-15R. |
| ⚡ | — GROUND FAULT RECEPTACLE, 120V, 15A, CSA TYPE 5-15R, MOUNTED AT 175mm ABOVE SPLASHBACK OR 150mm A.F.F. |
| ⚡ | — 20A, 120V, RECEPTACLE, CSA TYPE 5-20R. |
| ① | — LOW VOLTAGE THERMOSTAT. |
| ① | — DOOR CONTACT, CARD ACCESS SYSTEM. |
| ⑤ | — ELECTRIC STRIKE, SUPPLIED AND INSTALLED BY ARCHITECTURAL TRADE. |
| ⑤ | — PROXIMITY CARD READER. |
| ⑤ | — MOTION DETECTOR. |
| ⑤ | — MAGNETIC WINDOW CONTACT. |
| — | — SURFACE MOUNTED PANELBOARD. |
| — | — RECESSED MOUNTED PANELBOARD. |
| ⑤ | — FIRE ALARM BELL. |
| ⊗ | — EXIT SIGN, WALL MOUNTED |
| ⊗ | — EXIT SIGN, CEILING MOUNTED |
| ⑤ | — FIRE ALARM MANUAL PULL STATION. |
| ⑤ | — HEAT DETECTOR |
| ⑤ | — EXISTING ELECTRIC HEAT RELAY (24 VOLT) MOUNTED IN CEILING SPACE. |
| ⑤ | — PUSHBUTTON |
| ⑤ | — DOOR HARDWARE POWER SUPPLY, SUPPLIED AND INSTALLED BY DOOR HARDWARE CONTRACTOR. |
| □ | — OUTLET OR JUNCTION BOX. |
| ⊗ | — SAFETY DISCONNECT SWITCH. |
| ⊗ | — CONNECTION TO MECHANICAL EQUIPMENT. |
| ⑤ | — HAND DRYER |



1. Adhesive X-Pull, 3 x 100mm TALL BOX IN CEILING SPACE ABOVE DOOR, PROVIDE 2" OF LOOSED WIRE AT EACH PULL BOX.
2. CONDUIT SHALL BE RUN BY ELECTRICAL, WIRING BY DOOR HARDWARE CONTRACTOR.
3. DOOR HARDWARE CONTRACTOR (DHC) BY DOOR HARDWARE CONTRACTOR.
4. POWER SHUTTY FOR ONE (ONE) FOR UP TO 5 DOORS WITHIN 50' RADIUS), BY DOOR HARDWARE CONTRACTOR.
5. ALL WIRING FOR DOOR HARDWARE, IF REQUIRED, BY DOOR HARDWARE CONTRACTOR.
6. ALL FIVE (5) AMMERS CONNECTIONS BY ELECTRICAL.
7. ALL 120V WIRING AND CONNECTIONS BY ELECTRICAL.
8. ALL 120V WIRING AND CONNECTIONS BY ELECTRICAL.
9. ALL LOW VOLTAGE WIRING AND DEVICES BY DOOR HARDWARE CONTRACTOR.

1 TYPICAL DOOR HARDWARE ROUGH-IN

0	ISSUED FOR TENDER	DEC 10 2014
revisions		date

PAROLE OFFICE FIT-UP CSC

drawing
dessin

ELECTRICAL LEGEND AND LIST OF DRAWINGS AND SUBSCRIPTS

designed	conçu
doile	
drown	deussé
doile	
approved	approuvé

Tender	Submission
PMWSC	2014-12-15
PMWSC Project Manager	Administrateur de projets TPWSC
Project number	no. du projet
R.063761.003	