



Addendum / Addenda

No./N^o
1

Project Description / Description de projet M10 Chiller Replacement		
Solicitation No./ No de sollicitation 14-22096	Project No./N ^o de projet 4045	W.O. No./N ^o d'ordre de travail A1-005221-06-01
Departmental Representative / représentant ministériel Maurice Richard		Date January 13, 2015
<p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

Questions :

- 1- What is the completion date :
 - a. Complete all work within 15 weeks after receipt of notification of acceptance of tender.
- 2- Who will take care of the asbestos removal:
 - a. Asbestos will be removed by NRC.
- 3- Who will bypass the fire alarm system:
 - a. The fire alarm system will be bypassed by NRC, a notice of 48 hres is required.
- 4- Is there a Designated Substance Report available.
 - a. DSR report will be provided by NRC.
- 5- How long can the system be shutdown.
 - a. System can be shutdown 3 weeks prior of new installation.
- 6- Do you know the anticipated delivery time would be for the equipments.
 - a. It is the contractor responsibility to manage delivery time with Manufacturer.
- 7- Do we carry the added cost to complete the exterior tower supports, etc... under winter conditions.
 - a. Complete all work within 15 weeks after receipt of notification of acceptance of tender.
- 8- Are we allowed to use the crane at loading dock.
 - a. No , under no circumstance , usage of any NRC equipments will be allowed.

Alternate Equipment:

- 1- Water –cooled Chiller (York YCWL) Johnson Control
 - a. The performance of the alternative is acceptable , but all cost required by or as a result of this alternative will be borne by the contractor and the chiller shall have all the specified options and accessories.

Design:

- 1- New cooling tower 10CTR02 must be installed 1 meter from existing building, not 3.048 meter as per drawing 4045-M02, supports and structure remain as per tender documents.