



Addendum / Addenda

No./N^o
2

Project Description / Description de projet M10 Chiller replacement		
Solicitation No./ No de sollicitation 14-22096	Project No./N ^o de projet 4045	W.O. No./N ^o d'ordre de travail A1-005221-06-01
Departmental Representative / représentant ministériel Maurice Richard		Date January 14,2014
<p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

Questions :

- 1- Can we use welded steel for the chilled and condenser water versus grooved piping.
 - a. No , welded steel is not acceptable. Provide grooved piping as per specification