



Addendum / Addenda

No./N^o
3

Project Description / Description de projet M10-Chiller Replacement		
Solicitation No./ No de sollicitation 14-22096	Project No./N ^o de projet 4045	W.O. No./N ^o d'ordre de travail A1-005221-06-01
Departmental Representative / représentant ministériel Maurice Richard		Date January 19,2015
<p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

Alternate Equipment proposal :

1- Cooling Tower (CWT RTA-53A)

The performance of the alternative is acceptable , but all cost required by or as a result of this alternative will be borne by the contractor and the cooling tower shall have all the specified options and accessories. Contractor must modify the dimension of support structural accordingly.

2- Extend tender closing date to January 28, 2015.