

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Le Goulet Reconstruction	
Solicitation No. - N° de l'invitation EC015-151642/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client R.044301.001	Date 2015-01-20
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3527	
File No. - N° de dossier PWB-4-37127 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-01-27	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment Number 7 is raised to include the following **Addendum No. 7.**

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 7

QUESTIONS AND ANSWERS

Q1: Please specify what tip elevations should be assumed for bidder purposes for the Channel Side H-Piles? No information has been provided in the tender package to allow the Contractor to determine the anticipated final tip elevations of these piles.

A1: For bidding purposes , tip elevations are shown on Section J-6-6 (M6), Section K-6-9, Section L-6-9 (M9).

Q2: Please specify how the “Rock Excavation” shown on Drawing M9 – Section “ Typical Rock Cut Section – Channel Side “ will be paid ? Also please specify the quantity and extent of this rock excavation, since no channel side rock elevations have been provided in the tender package?

A2: Rock excavation and removal as required for the proper installation of the precast wall panels on the channel side will not be measured separately for payment but will be included in the lump sum for Item No.1 - Construction/Demolition/Mobilization/Demobilization, Section 02 41 13, of the contract specifications. The Contractor is to make his own determination of the quantity and extent of this rock excavation, based on the geotechnical and bathometric information supplied with the tender package. Excavated rock material removed from the harbour bottom for this purpose is to be transported and stockpiled on site in a location directed by the Departmental Representative at the time of construction.