

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions/Travaux
publics et Services gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

Title - Sujet StanleyBridge Breakwater Relocation	
Solicitation No. - N° de l'invitation ED001-151765/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.064507.001	Date 2015-01-20
GETS Reference No. - N° de référence de SEAG PW-\$PWC-010-3540	
File No. - N° de dossier PWC-4-37139 (010)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-01-22	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacDonald, Anne (PWC) D.	Buyer Id - Id de l'acheteur pwc010
Telephone No. - N° de téléphone (902) 626-4949 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Addendum #3
January 20, 2015

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THIS ADDENDA SHALL FORM PART OF THE CONTRACT DOCUMENTS.

Question:

1. In addenda 1, it was stated that the estimate on the SANDSTONE materials was approximately 13000 Mt +/- . I am wondering if this was meant to state the core stone of or was it actually sandstone materials on the disposal site side?

Clarification:

[REFERENCE SECTION 3/M2/M3: ELEVATION AS INDICATED ON THE LEFT HAND SIDE OF THE CROSS SECTION SHOULD BE APPROXIMATELY -3.0+/- . REFERT TO DRAWING M4 FOR BOTTOM OF HARBOUR ELEVATIONS. REVISE SANDSTONE MATERIAL QUANTITY TO 17,000 MT]

2. In cross section 5 on M3 it shows a mound of 0.15 – 0.6 dia stones on the bay side. Also in section 4 on M3 it shows the same type of mound noted as LOCAL SANDSTONE RIPRAP. Would this not be the same stone type. Is it Local sandstone to specification for sandstone or is it meant to be Core stone (imported material), or is it a different type from all of the others noted.

Clarification

[SAME TYPE OF LOCAL RIPRAP SANDSTONE MATERIAL (015 -0.6 DIA) TO BE USED AS SHOWN ON SECTIONS 4/M3 AND 5/M3]

Question:

3. I also noticed no provisions for a silt fence or boom. Is this not required?

Clarification:

[SILT BOOMS ARE REQUIRED AROUND THE LIMIT OF CONSTRUCTION]

Question:

4. Are we to do any work associated with the old breakwater and or the disposal cell? Would the toe excavation material be able to be dumped in the cell?

Clarification:

[NO WORK ON THE OLD BREAKWATER ONLY THE DISPOSAL CELL. ALL EXCAVATED MATERIAL SHALL BE DUMPED IN THE DISPOAL CELL]