



Addendum / Addenda

No./N^o
4

Project Description / Description de projet M10-Chiller Replacement		
Solicitation No./ No de sollicitation 14-22096	Project No./N ^o de projet 4045	W.O. No./N ^o d'ordre de travail A1-005221-06-01
Departmental Representative / représentant ministériel Maurice Richard		Date Jnauary 20,2015
<p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

1-.Cooling tower shall have custom extended fan cowl cut on a 45 degree angle to minimize the recirculation caused by the tall roof closeby.