



ELECTRICAL LEGEND	
SYMBOL	DESCRIPTION
	FLUORESCENT LUMINAIRE A - INDICATES TYPE (SEE SCHEDULE)
	POT LIGHT A - INDICATES TYPE (SEE SCHEDULE)
	WALL MOUNTED LUMINAIRES
	EXISTING LUMINAIRES
	EMERGENCY BATTERY PACK DUAL HEAD LIGHTING UNIT
	SINGLE-POLE LIGHT SWITCH 3 - INDICATES THREE-WAY SWITCH 4 - INDICATES FOUR-WAY SWITCH
	JUNCTION BOX
	15A/125V, 5-15R DUPLEX U-GROUND RECEPTACLE
	SPECIAL PURPOSE RECEPTACLE, MATCH EXISTING NEMA CONFIGURATION
	DIRECT CONNECTION
	TELEPHONE OUTLET
	DATA OUTLET
	ELECTRIC BASEBOARD HEATER A - INDICATES TYPE (SEE SCHEDULE)
	F.A. HORN/STROBE SIGNALING, MATCH EXISTING EQUIPMENT
	CEILING MOUNTED ALARM BEACON
	EMERGENCY PUSH BUTTON
	AUDIO SPEAKER, WALL MOUNTED
	SECURITY CAMERA
	DISCONNECT SWITCH # - INDICATES DISCONNECT SIZE
	COMBINATION MAGNETIC STARTER AND DISCONNECT SWITCH
	THREE PHASE ELECTRIC MOTOR
	SINGLE PHASE ELECTRIC MOTOR
	SURFACE MOUNTED ELECTRICAL PANELBOARD

- GENERAL NOTES:
- THE DRAWINGS ARE DIAGRAMMATIC AND INDICATES GENERAL LOCATIONS FOR ELECTRICAL EQUIPMENT. THE CONTRACTOR SHALL VERIFY ALL EQUIPMENT LOCATIONS ON SITE PRIOR TO INSTALLATION AND SHALL COORDINATE THE LOCATIONS SO AS NOT TO CAUSE INTERFERENCE WITH WORK OF OTHER TRADES. CONTRACTOR IS RESPONSIBLE TO VISIT THE JOB SITE TO VERIFY ALL EXISTING CONDITIONS WHICH COULD AFFECT THE WORK. NO EXTRA COST WILL BE ALLOWED DUE TO FAILURE TO TAKE SITE CONDITIONS INTO CONSIDERATION. BE FAMILIAR WITH ALL RELATED WORK TO AVOID CONFLICTS WITH OTHER TRADES. IF THERE IS ANY CONFLICTS REPORT TO CONSULTANT.
  - THIS CONTRACTOR SHALL COORDINATE ALL FLOOR, CEILING AND WALL PENETRATIONS WITH GENERAL CONTRACTOR AND/OR THE OWNER PRIOR TO CUTTING.
  - THIS CONTRACTOR IS RESPONSIBLE TO RELOCATE ANY ELECTRICAL THAT COULD INTERFERE WITH THIS WORK AND WORK OF OTHER TRADES. CONTRACTOR IS RESPONSIBLE TO COORDINATE CLOSELY WITH OTHER TRADES & BE FAMILIAR WITH EXISTING INSTALLATION PRIOR TO TENDER CLOSING. NO EXTRA ALLOWANCE WILL BE ALLOWED FOR RELOCATION OF ELECTRICAL SERVICES IN ORDER TO ACCOMMODATE OTHER TRADES.
  - THE REMOVAL AND INSTALLATION OF CEILING TILES SHALL BE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR.
  - ALL CUTTING, PATCHING, CORE DRILLING AND FIRE STOPPING SHALL BE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR.
  - CONTRACTOR SHALL MAINTAIN INTEGRITY OF FIRE SEPARATION AT ALL FIRE SEPARATION. COORDINATE ALL RELATED WORK WITH GENERAL CONTRACTOR.
  - ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE CODES, STANDARDS AND THEIR AMENDMENTS, IN A MANNER WITH GOOD WORKMANSHIP.
  - REVIEW MECHANICAL DRAWINGS AND COORDINATE TESTING OF NEW INSTALLATION.
  - ALL NEW MATERIAL SUPPLIED SHALL BE NEW AND CARRY CSA OR UL/C CERTIFICATION.



Public Works and Government Services Canada

Travaux Publics et Services gouvernementaux Canada

ROY CONSULTANTS  
546, av. King Ave.  
Suite 100 E2A 1T7  
T: 514-846-4445  
www.royconsultants.ca

ROY# 292-14-E1

3	RE-ISSUED FOR TENDER	NOV. 03 2014
2	ISSUED FOR TENDER	AUG. 12 2014
1	RE-ISSUED FOR 99% REVIEW	AUG. 07 2014
0	ISSUED FOR TENDER	NOV. 21 2014
B	ISSUED FOR 99% REVIEW	FEB. 28 2014
A	ISSUED FOR 66% REVIEW	FEB. 24 2014
revisions		date
project	DECOMMISSION OF THE FIRING RANGE RCMP "J" DIVISION 1445 REGENT ST. FREDERICTON YORK CO. N.B.	
drawing	desin	
ELECTRICAL LEGEND & FLOOR PLANS		
designed J. GUIGNARD	conçu	
date NOVEMBER 2014		
drawn M. ROBICHAUD	dessiné	
date NOVEMBER 2014		
approved S. GODIN	approuvé	
date NOVEMBER 2014		
Tender	Soumission	
PWSC Project Manager	Administrateur de projets TPSC	
project number	no. du projet	
R.071593.001		
drawing no.	no. du dessin	
E1		

E-DRM/GDD-E: # 495464 Version 1