

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada**  
**1713 Bedford Row**  
**Halifax, N.S./Halifax, (N.É.)**  
**B3J 1T3**  
**Bid Fax: (902) 496-5016**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.É.)  
B3J 3C9  
Nova Scot

<b>Title - Sujet</b> Motor Analyzer/Tester	
<b>Solicitation No. - N° de l'invitation</b> W355B-151486/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> W355B-15-1486	<b>Date</b> 2015-01-26
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$HAL-321-9416	
<b>File No. - N° de dossier</b> HAL-4-73170 (321)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-01-28</b>	<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Gillis, Floyd	<b>Buyer Id - Id de l'acheteur</b> hal321
<b>Telephone No. - N° de téléphone</b> (902) 496-5566 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**Amendment 002 raised to post the following questions and answers:**

**Q1:** What is the maximum rated horse power of the motors to be tested?

**Q2:** What is the highest number of poles for these motors?

**Q3:** Are they all induction motors?

**Q4:** What is the meaning of "transformer tests", Item number 3.11 of annexure A. (Page 3, Annexure A) Is it applicable for motor tastings?

**Q5:** A 4kv motor tester is not capable of performing a surge test with max. surge energy of 2.9J, whereas a higher kv tester is needed for that amount of surge energy. Therefore either a 12kv tester is needed or the "max surge energy" must be changed to a lower amount. Please clarify it.

**Q6:** Since the quantity of some of the deliverables are two and the others' are one listed in Annex A, how this can be priced as unit price in Annex B?.

**Q7:** For transformer tests (clause 3.11 in annex A), the power pack is required. In clause 2.b annex A, the power pack is stated as optional. Please clarify if providing the power pack is mandatory or optional and also please clarify the quantity of the power pack.

**A1:** 1000HP

**A2:** 8 Pole

**A3:** No, generators are to be tested as well.

**A4:** Transformer tests refer to testing of the coils, not function.

**A5:** Please ignore the 2.9j requirement. The bid should be on a 4Kv motor tester.

**A6:** There is a requirement for two (2) motor testers. Some of the accessories are only required in quantities of one (1) and others two (2). Please price accordingly.

**A7:** The power pack is optional, not mandatory. Transformer tests are as well, not mandatory, just capability exists for the unit.

**All other terms/conditions remain the same.**