

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
John Cabot Building
10 Barters Hill, P.O. Box 4600
St. John's
Newfoundland and Labrador
A1C 5T2
Bid Fax: (709) 772-4603

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
PWGSC/TPSGC-Nfld Region/Real Property
John Cabot Building
10 Barters Hill, P.O. Box 4600
St. John's
Newfoundl
A1C 5T2

| | |
|--|---|
| Title - Sujet Interior Office Fit-up -CSC - CB NL | |
| Solicitation No. - N° de l'invitation EA003-151701/A | Amendment No. - N° modif. 002 |
| Client Reference No. - N° de référence du client R.063761.003 | Date 2015-01-26 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWD-010-6261 | |
| File No. - N° de dossier PWD-4-37174 (010) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-01-28 | Time Zone Fuseau horaire Newfoundland Standard Time NST |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Chaulk, Patricia | Buyer Id - Id de l'acheteur pwd010 |
| Telephone No. - N° de téléphone (709) 772-8357 () | FAX No. - N° de FAX (709) 772-4603 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation

EA003-151701/A

Client Ref. No. - N° de réf. du client

R.063761.003

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWD-4-37174

Buyer ID - Id de l'acheteur

pwd010

CCC No./N° CCC - FMS No/ N° VME

**Interior Office Fit-up -
Correctional Services Canada (CSC) -
Corner Brook, NL**

SOLICITATION AMENDMENT NO. 002

(General Questions)

**Interior Office Fit-up -
Correctional Services Canada (CSC) -
Corner Brook, NL**

AMENDMENT # 2

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

GENERAL QUESTIONS:

Q1: How do you want us to cut the 19mm, #10 (1.8mm thick) Expanded Flattened Steel Mesh around the OWSJ, Mechanical, and Electrical?

A1: Wire mesh should be cut with a slot and secured on each side of obstruction with metal stud blocking as required. To be determined as required by site conditions.

Q2: Where there is no revised ceiling plan, would we cut for where the new partitions where ever they will fall? Or would it have to be centered for each room?

A2: Ceiling plan should be as per drawing E4

Q3: Section 087100 (Door Hardware).Refer to pages 9 & 10,Hardware Group HG3,HG4,HG6,HG7.
HG3-Lockset ,Hotel Special.

HG4,HG6,-Lockset,Electric Unlocking.

Please advise Model #/Cylindrical or Mortise Type Etc.required for these Locksets.

A3: HGs. 1,2,5,9 & 10 have heavy duty grade 1 cylindrical locks

HGs. 3 & 8 have heavy duty grade 1 mortise locks

HGs. 4, 6 & 7 have heavy duty grade 1 electric mortise locks

Q4: Given that this area of construction has a sprinkler system, does the fireproofing on the OWSJ and deck need to be maintained (i.e. repaired after construction).

A4: Fireproofing- Existing Fireproofing on the OWSJ and deck will need to be maintained. i.e. repaired after construction to match existing.

Q5: There were no ceiling heights indicated on the plans

A5: Ceiling height- As per existing site condition

Q6: The wire mesh required for P1 is indicated as being on the outside of the wall in some areas and the inside in other areas. Could this be put continuously on the inside?

A6: Wire mesh wall location. Wire mesh can be on inside of wall partition type P1

Q7: The spec notes that for all after hours work I have to carry the wages of security personnel. Please let me know what wage to carry.

A7: Security Personnel wages to carry - Contractor is responsible for the cost and coordination of any after hours work site security with Corps of Commissionaires Services.

Q8: Drawing A3 Detail 5 shows a set of burglar bars being installed in all air exchange duct openings in P1. It does not show these being inside of duct work, but all such penetrations through P1 are ducted. That said, if it is intended to go inside the duct work, then there will be a conflict with the fire dampers which are shown on the duct lines on M2.

A8: Penetrations in Duct openings- according to the Parole Office guidelines only penetrations by mechanical equipment with openings larger than 620cm² that have two dimensions greater than 150mm need to be secured with mesh or security grills. If this is in a location that is also required to have a fire damper than a combination fire damper with security grill is to be used. We will review submitted shop drawings.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.
