

LEGEND

- NEW DUCT WORK
- EXISTING DUCT WORK
- EX 200 AIR FLOW IN L/S
- EMCS CONTROLLER
- UNIT INTEGRAL CONTROLLER

MCA
CONSULTANTS
ENGINEERS - PROJECT MANAGEMENT
info@mcaconsultants.ca
www.mcaconsultants.ca
902.566.9223

NOTES

- CONTRACTOR IS CAUTIONED THAT ALL EXISTING SITE CONDITIONS ARE NOT INDICATED ON THIS DRAWING. CONTRACTOR TO REVIEW EXISTING CONDITIONS ON SITE PRIOR TO TENDER.
- THE AREAS SERVED BY THIS SYSTEM ARE CONSIDERED CRITICAL SPACES. SHUTDOWN PERIOD FOR COMMISSIONING SYSTEM IS TO BE MINIMIZED AND COORDINATED WITH ENGINEER.
- CONTRACTOR TO RE-BALANCE EXISTING SYSTEM TO VALVES INDICATED WHICH ARE CONNECTED TO NEW RTAC-4A. MEASURE & VERIFY ALL OTHER FLOWS THAT REMAIN CONNECTED TO EXISTING SYSTEM AND PROVIDE AS PART OF WRITTEN BALANCING REPORT.
- REMOVAL & REINSTATEMENT OF ALL CEILINGS, LIGHT FIXTURES, ETC. FOR EXECUTION OF THIS WORK IS THE RESPONSIBILITY OF THIS CONTRACTOR.

0	ISSUED FOR TENDER	12/22 2014
0	ISSUED FOR REVIEW	12/11 2014
revisions		date


project project

JOSEPH A. GHIZ
BUILDING
AHU#4
SYSTEM UPGRADE

drawing dessin

NEW VENTILATION
LAYOUT

designed J.D.M.	conçu
date 2014-11-14	
drawn L.J.D.J.	dessiné
date 2014-11-17	
approved	approuvé
date	
Tender	Soumission
PWOSC Project Manager	Administrateur de projets TPSOC
project number	no. du projet
R.000003.062	
drawing no.	no. du dessin
H-1	



VENTILATION - NEW LAYOUT

SCALE : 1:100
0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

VENTILATION - NEW LAYOUT CONTINUATION

SCALE : 1:100
0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

