

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet EGD High Voltage Refurbishment	
Solicitation No. - N° de l'invitation EZ108-151321/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2015-01-29
GETS Reference No. - N° de référence de SEAG PW-\$PWY-026-7427	
File No. - N° de dossier PWY-4-37267 (026)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-02-02	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Liu (PWY), Patty	Buyer Id - Id de l'acheteur pwy026
Telephone No. - N° de téléphone (604) 775-6227 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Esquimalt Graving Dock - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ108-151321/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWY-4-37267

Buyer ID - Id de l'acheteur

pw026

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande

Addendum 002 attached.

All other terms and conditions remain unchanged.

***The following changes/clarifications in the tender documents are effective immediately.
This Addendum will form part of the Contract documents.***

ANSWERS TO QUESTIONS RAISED BY CONTRACTORS

- Q1. What is the size of the gasket of the drain plug? (item 6 in Section 26 08 01, Paragraph 3.3 MINOR MODIFICATIONS AND REPAIR WORK.).
- A1. There are no accurate manufactures shop drawings available for this gasket of the drain. Site measurements must be taken before gasket is ordered and installed.
- Q2. What is the make and model number of the transformer temperature sensor? (Item 4 of the above section)
- A2. The face place of this temperature sensor states "Winding Temperature Indicator, Model RW, Teston Gauge Limited, Toronto".
- Q3. Item 5 mentions here to replace a high voltage insulator of main substation 208 volt transformer? Are you referring to the transformer with the serial number S7851.01 and manufactured by FPE? Do you have the dimension of the insulator and any associated drawings? (Please see attached).
- A3. Item 5 refers to the Main Substation 208 volt transformer with the serial number S7851.01 and manufactured by FPE. Drawing and dimensions not available but can be measured on site.
- Q4. Can we schedule to conduct the maintenance of the following areas between the scheduled shutdown periods February 28- March 1 and of March 7-8, 2015?
- HV Ship-Shore Service
 - Tonne Crane
 - North Side 30 Tonne Crane
 - South Side 30 Tonne Crane
- A4. The dates between these scheduled shut-down periods are available for maintenance on the above equipment. These dates however, are subject to changes depending on the dock operations at that time. Actual dates for maintenance during normal hours will be verified and approved in advance.
- Q5. Appendix A - Part 02 11x17' and 'Appendix B - Part 02 11x17' are the same documents. Please clarify if otherwise.
- A5. The "Relay Setting versus coordination study" in Appendix A and B are the same document.

- Q6. 'Appendix C - Part 02 11x17' drawings are ineligible. When blowing the drawings up to a workable size the line definition is lost. Please reissue Appendix C in a pdf format from a good quality source rather than a photocopy. Much appreciated.
- A6. The drawings in Appendix C will be reissued as downloadable PDF files.

END OF ADDENDUM