

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> West Coast Trail Bridges Repair	
<b>Solicitation No. - N° de l'invitation</b> EZ899-151713/A	<b>Amendment No. - N° modif.</b> 007
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2015-01-28
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-025-7409	
<b>File No. - N° de dossier</b> PWY-4-37258 (025)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-02-03</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Fung, Donna(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy025
<b>Telephone No. - N° de téléphone</b> (604) 666-9835 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada - Pacific Rim National Park - Vancouver Island, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**Les documents français seront disponibles sur demande.**

This Amendment 007 is raised to extend the solicitation closing date and to incorporate Addendum 006.

## **Extension of Time**

**West Coast Trail Bridges Repair  
Pacific Rim National Park, Vancouver Island, BC**

**Solicitation No: EZ899-151713/A**

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. on January 30, 2015 is hereby extended to  
**2:00 p.m. on February 3, 2015.**

Please see the attached Addendum 006.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

\*\*\*\*\*

**AVIS AUX SOUMISSIONNAIRES:** Veuillez utiliser l'étiquette d'adresse ci-dessous et bien l'affixer à l'extérieur de l'enveloppe ou du paquet renfermant votre offre. Dans le cas de modifications à des offres soumises par télécopieur (Fax: (604) 775-9381), servez-vous de la feuille comme page couverture. Assurez-vous de toujours inscrire lisiblement le nom de votre compagnie, l'adresse de retour, le numéro de l'offre et la date limite sur l'extérieur de votre offre.

**Marchés immobiliers  
Travaux publics et Services gouvernementaux Canada  
800, rue Burrard, bureau 219  
Vancouver (C.-B.) V6Z 0B9**

**Offre no:** EZ899-151713/A

**Date et heure limites de  
reception des soumissions:** 3 février 2015 à 1400hr

**Sujet:** Réparation des ponts du sentier de la Côte-Ouest  
Parc national Pacific Rim, île de Vancouver, C.-B.

DF

# ADDENDUM

---

Project: West Coast Trail Bridges Repair

**Addendum No.: 006**

Project No.: R.064182.001

Requisition No.: EZ899-151713/A

January 28, 2015

---

## **GENERAL**

This Addendum forms part of the Contract Documents for **Project No. R.064182.001** and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.

## **Clarification (Questions and Answers):**

1. Who is responsible for transportation of Owners Structural Engineer, Geotechnical Engineer and Departmental Representative for inspections? Are we to allow for transportation and inspection for these personnel in helicopter costs?

**Contractor will not be responsible for transportation (helicopter and other forms of transportation) cost of Structural Engineer, Geotechnical Engineer and Departmental Representative's visits, except the geotechnical engineer's/consultant's visits for the bridges 68 and 27 as per Section 011155 CI 2.2.12. (Note, other bridges will be reviewed by a geotechnical engineer retained by the Departmental Representative).**

2. Can they camp for portions of the work? Can some inspections be performed via photos? i.e Reinforcing inspections for bridges, cables on bridge 27 and final inspections. If we mobilize to Bridge 27, complete and then demob, will the engineer come to inspect prior to contractor moving to a different site?

**Ideally, inspections are to be done when all the work on the bridges is complete to minimize the reviewer's transportation (helicopter) cost. Contractor is to provide weekly electronic photo update of the work completed. It is required to establish a reliable form of communication between the consultant and the contractor's site crew.**

**Note, since there is no cell phone signal at the sites, it is advised that contractor verifies (tests) whether the satellite phone can transfer electronic photos. Structurally, there is two visits allowed for field reviews, so if planned well, it is possible that bridge 27 will be reviewed before demobilisation.**

3. GC 01 11 55 - 10.1 - Building permit, Certificates, Licenses and other permits. What jurisdiction does this fall under or is this exempt from building permit?

**This project does not require a building permit.**

## ADDENDUM

---

4. The steel angle required for this project may not be available in 350W material. Can 44W material be substituted?

**All the steel to be 350W as per specification. Any alternatives can be discussed after contract award.**

End of Addendum