

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

Title - Sujet West Coast Trail Bridges Repair	
Solicitation No. - N° de l'invitation EZ899-151713/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client	Date 2015-01-28
GETS Reference No. - N° de référence de SEAG PW-\$PWY-025-7409	
File No. - N° de dossier PWY-4-37258 (025)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-02-03	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Fung, Donna(PWY)	Buyer Id - Id de l'acheteur pwy025
Telephone No. - N° de téléphone (604) 666-9835 ( )	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada - Pacific Rim National Park - Vancouver Island, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment 007 is raised to extend the solicitation closing date and to incorporate Addendum 006.

## Extension of Time

### West Coast Trail Bridges Repair Pacific Rim National Park, Vancouver Island, BC

**Solicitation No: EZ899-151713/A**

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. on January 30, 2015 is hereby extended to  
**2:00 p.m. on February 3, 2015.**

Please see the attached Addendum 006.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

\*\*\*\*\*

**NOTE TO TENDERERS:** Use the mailing label below and affix it securely to the outside of the envelope or package containing your tender. For revisions to tenders submitted by facsimile (fax # (604) 775-9381), use this sheet as the cover sheet. Always ensure your company name, return address, tender number and closing date appear legibly on the outside of your bid submission.

**REAL PROPERTY CONTRACTING  
Public Works & Government Services Canada  
Room 219 - 800 Burrard Street  
Vancouver, B.C. V6Z 0B9**

**Requisition No.:** EZ899-151713/A

**Tender Closing Date & Time:** 3 February 2015 at 14:00

**Project Description:** West Coast Trail Bridges Repair  
Pacific Rim National Park, Vancouver Island, BC

DF

# ADDENDUM

---

Project: West Coast Trail Bridges Repair

**Addendum No.: 006**

Project No.: R.064182.001

Requisition No.: EZ899-151713/A

January 28, 2015

---

## **GENERAL**

This Addendum forms part of the Contract Documents for **Project No. R.064182.001** and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.

## **Clarification (Questions and Answers):**

1. Who is responsible for transportation of Owners Structural Engineer, Geotechnical Engineer and Departmental Representative for inspections? Are we to allow for transportation and inspection for these personnel in helicopter costs?

**Contractor will not be responsible for transportation (helicopter and other forms of transportation) cost of Structural Engineer, Geotechnical Engineer and Departmental Representative's visits, except the geotechnical engineer's/consultant's visits for the bridges 68 and 27 as per Section 011155 CI 2.2.12. (Note, other bridges will be reviewed by a geotechnical engineer retained by the Departmental Representative).**

2. Can they camp for portions of the work? Can some inspections be performed via photos? i.e Reinforcing inspections for bridges, cables on bridge 27 and final inspections. If we mobilize to Bridge 27, complete and then demob, will the engineer come to inspect prior to contractor moving to a different site?

**Ideally, inspections are to be done when all the work on the bridges is complete to minimize the reviewer's transportation (helicopter) cost. Contractor is to provide weekly electronic photo update of the work completed. It is required to establish a reliable form of communication between the consultant and the contractor's site crew.**

**Note, since there is no cell phone signal at the sites, it is advised that contractor verifies (tests) whether the satellite phone can transfer electronic photos. Structurally, there is two visits allowed for field reviews, so if planned well, it is possible that bridge 27 will be reviewed before demobilisation.**

3. GC 01 11 55 - 10.1 - Building permit, Certificates, Licenses and other permits. What jurisdiction does this fall under or is this exempt from building permit?

**This project does not require a building permit.**

## ADDENDUM

---

4. The steel angle required for this project may not be available in 350W material. Can 44W material be substituted?

**All the steel to be 350W as per specification. Any alternatives can be discussed after contract award.**

End of Addendum