

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Secondary Tank Compliance	
Solicitation No. - N° de l'invitation EW038-151870/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client PWGSC-EW038-151870	Date 2015-01-30
GETS Reference No. - N° de référence de SEAG PW-\$PWU-009-10360	
File No. - N° de dossier PWU-4-37234 (009)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-02-11	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bogus (RPC), Katherine	Buyer Id - Id de l'acheteur pwu009
Telephone No. - N° de téléphone (780) 497-3547 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Public Works and Government
Services Canada
Real Property Contracting

Project Name: Secondary Tank Compliance, Bowden Institution, Bowden, AB
Project Number: R.072042.001
Date: January 30, 2015

This addendum forms part of the tender documents and modifies them as here-in stated and are effective immediately. The following sections of the Invitation to Tender, drawings and specifications have been modified.

Pre-Tender Site Visit January 29, 2015-01-29 – Clarifications and Updated Requirements

- The existing chain link fence section removal & replacement required to for tank removal and installation is to be completed by the General Contractor. Remove any reference in the Specification & Drawings (Tender documents) to "by others", in relation to this portion of the scope.
- Change Specification Section 01 14 10 Work Hours: Monday to Sunday 6:00 a.m. (0600hrs) to 6:00p.m. (1800hrs)
- ABES. PROD.PW PWU.B009.EBSU000.PDF 000 (BA06) Schedule Requirements and clarification for construction time
- Temporary Fuel Tanks in place within 5 weeks of Notification of acceptance of the offer.
- New Tank delivered to site within 5 weeks of Notification of acceptance of the offer.
- Start Demolition of existing Tank / Tank area within 8 weeks of Notification of acceptance of the offer.

Delete:

Closing Date: February 9, 2015

Insert:

Closing Date: February 11, 2015

Question:

The addendum that was issued for this project shows new stairs and platform being installed. There is no information on the depth of the 4 piles required for the platform. Is it possible to get some more information on this?

Answer:

The piles need to be at least 2m deep and must be protected from freezing.