

DEMOLITION NOTES:

LIGHTING:

- DISCONNECT AND REMOVE ALL LIGHTING FIXTURES IN BUILDING WITH THE FOLLOWING EXCEPTIONS:
 - BOARDROOM AR-034. THESE FIXTURES ARE TO REMAIN.
 - LIGHTING IN ELECTRICAL ROOM AR-029, ELECTRICAL ROOM AR-025, MECHANICAL/SPRINKLER ROOM AR-033 AND UPPER MECHANICAL ROOM IS TO REMAIN. REPLACE EXISTING FIXTURES WITH NEW FIXTURES OF SAME TYPE.
 - GENERAL OFFICE AR-032. THESE FIXTURES ARE TO BE REMOVED AND RE-USED IN THE NEW LIGHTING DESIGN. SAFELY STORE FIXTURES ON SITE.
 - REMOVE ALL ASSOCIATED CONDUIT/WIRING BACK TO SOURCE PANEL IN MAIN ELECTRICAL ROOM.
 - REPLACEMENT OF EXTERIOR LIGHTS TO BE ADDRESSED DURING NEW CONSTRUCTION PHASE.
 - LIGHTING & CONTROLS TO REMAIN IN PLACE DURING CONSTRUCTION.
- EMERGENCY/EXIT LIGHTING:**
- DISCONNECT AND REMOVE ALL EMERGENCY/EXIT LIGHTING FIXTURES. REMOVE ALL ASSOCIATED CONDUIT/WIRING BACK TO SOURCE PANEL IN MAIN ELECTRICAL ROOM.

