




OVERALL SITE PLAN




INSTITUTION
 EDMONTON MAX INSTITUTION
 EDMONTON, ALBERTA

DESCRIPTION
**INTERCOMM SYSTEM
 BLOCK DIAGRAMS
 LIVING UNITS**


SCALE
 1:200

LAST UPDATE
 SEPT 1 2009


DRAWN BY: B. BOHACH




LCIS BLOCK DIAGRAM
 LU A/B



LCIS BLOCK DIAGRAM
 LU C/D



LCIS BLOCK DIAGRAM
 LU G/H



LCIS BLOCK DIAGRAM
 LU E/F

TO MCCP MASTER INPUTS 1,2,3&4

4 TWISTED PAIRS IN SINGLE PVC JACKET

1 TWISTED PAIR IN PVC JACKET TO EACH INTERCOM

TO MCCP MASTER INPUTS 5,6,7&8

4 TWISTED PAIRS IN SINGLE PVC JACKET

1 TWISTED PAIR IN PVC JACKET TO EACH INTERCOM

TO MCCP MASTER INPUTS 9,10,11,12

4 TWISTED PAIRS IN SINGLE PVC JACKET

1 TWISTED PAIR IN PVC JACKET TO EACH INTERCOM

TO MCCP MASTER INPUTS 9,10,11,12

4 TWISTED PAIRS IN SINGLE PVC JACKET

1 TWISTED PAIR IN PVC JACKET TO EACH INTERCOM