

**Part 1 General**

**1.1 SECTION INCLUDES**

- .1 Materials and installation for connectors and terminations.

**1.2 RELATED SECTIONS**

- .1 Section 01 11 00 - General Requirements.
- .2 Section 26 05 00 - Common Work Results for Electrical

**1.3 REFERENCES**

- .1 Canadian Standards Association (CSA International)
  - .1 CSA C22.2 No.41-07, Grounding and Bonding Equipment.

**1.4 PRODUCT DATA**

- .1 Submit product data in accordance with Section 01 00 01 - General Requirements.

**1.5 CERTIFICATES**

- .1 Obtain inspection certificate of compliance covering high voltage stress coning from inspection authority and include it with maintenance manuals.

**Part 2 Products**

**2.1 CONNECTORS AND TERMINATIONS**

- .1 Copper long barrel compression connectors as required sized for conductors.
- .2 Contact aid for aluminum cables where applicable and pre-approved by consultant.

**Part 3 Execution**

**3.1 INSTALLATION**

- .1 Install stress cones, terminations, and splices in accordance with manufacturer's instructions.
- .2 Bond and ground as required to CSA C22.2No.41.

**END OF SECTION**