

**Part 1 General**

**1.1 RELATED SECTIONS**

- .1 Section 01 11 00 - General Requirements.
- .2 Section 26 05 00 - Common Work Results for Electrical.

**1.2 REFERENCES**

- .1 Canadian Standards Association (CSA International)
  - .1 CSAC22.2No.26-1952(R2004), Construction and Test of Wireways, Auxiliary Gutters and Associated Fittings.

**1.3 PRODUCT DATA**

- .1 Submit product data in accordance with Section 01 00 01 - General Requirements.

**Part 2 Products**

**2.1 WIREWAYS**

- .1 Wireways and fittings: to CSA C22No.26.
- .2 Sheet steel with hinged cover to give uninterrupted access.
- .3 Finish: baked grey enamel.
- .4 Elbows, tees, couplings and hanger fittings manufactured as accessories to wireway supplied.

**Part 3 Execution**

**3.1 INSTALLATION**

- .1 Install wireways and auxiliary gutters.
- .2 Keep number of elbows, offsets, connections to minimum.
- .3 Install supports, elbows, tees, connectors, fittings.
- .4 Install barriers where required.
- .5 Install gutter to full length of equipment.

**END OF SECTION**