

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Resurfacement de la route et autres t	
<b>Solicitation No. - N° de l'invitation</b> EZ899-151714/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2015-02-18
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-015-7426	
<b>File No. - N° de dossier</b> PWY-4-37255 (015)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-02-25</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Chan (PWY), Scarlett	<b>Buyer Id - Id de l'acheteur</b> pwy015
<b>Telephone No. - N° de téléphone</b> (604) 775-9382 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada - Pacific Rim National Park - Tofino, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**Les documents français seront disponibles sur demande**

This solicitation amendment is raised to include the following:

- Revised Environmental Impairment Liability Insurance
- Addendum #4

Refer to the Invitation to Tender document dated 2015-01-14, delete SC02 Environmental Impairment Liability Insurance in its entirety and replace with the following:

**SC02 Environmental Impairment Liability Insurance (revised 2015-02-17)**

1. The Contractor must obtain "Contractors Pollution Liability" insurance, and maintain it in force throughout the duration of the Contract, in an amount usual for a contract of this nature, but for not less than \$1,000,000 per accident or occurrence and in the annual aggregate.
2. If the policy is written on a claims-made basis, coverage must be in place for a period of at least 12 months after the completion or termination of the Contract.
3. The "Contractors Pollution Liability" policy must include the following:
  - a. Additional Insured: Canada is added as an additional insured, but only with respect to liability arising out of the Contractor's performance of the Contract. The interest of Canada as additional insured should read as follows: Canada, represented by Public Works and Government Services Canada.
  - b. Notice of Cancellation: The Insurer will endeavour to provide the Contracting Authority thirty (30) days written notice of policy cancellation.
  - c. Separation of Insureds: The policy must apply to each Insured in the same manner and to the same extent as if a separate policy had been issued to each.
  - d. Contractual Liability: The policy must, on a blanket basis or by specific reference to the Contract, extend to assumed liabilities with respect to contractual provisions.
  - e. Incidental Transit Extension: The policy must extend to losses arising from any waste, products or materials transported, shipped, or delivered via any transportation mode to a location beyond the boundaries of a site at which the Contractor or any entity for which the Contractor is legally liable is performing or has performed the operations described in the contract.

All other terms and conditions remain unchanged.

**END**

**The following changes/clarifications in the tender documents are effective immediately.  
This addendum will form part of the contract documents.**

**Special Instructions to Bidders**

Q1. Section 31 00 99, Part 2.1.2 references the unsuitability of culvert excavation as backfill. It states that the cost of importing backfill material shall be incidental to “Unit Price Item 10 – Supply and Install Pipe Culverts”. How are we to determine how much material is required?

A1. Section 31 00 99, Part 2.1.2 shall be replaced with the following:

“It is anticipated that excavated material will be suitable for reuse. In the event that the excavated material is unsuitable for backfill and designated by the Departmental Representative as waste, the supply and placement of any additional backfill required for the completion of the project will be negotiated and paid as a change order.”

Section 33 42 13, Part 1.3.3.7 shall be replaced with the following:

“Supply, loading, hauling and placing of all culvert backfill material as shown on Drawing D-05. Leveling material shall be sand, select granular material shall be type WGB 25 mm crushed gravel, and the foundation material shall be select gravel from the excavation.”

**End of Addendum No. 4**