

**ADDENDUM 1  
TO THE  
PLANS AND SPECIFICATIONS  
FOR**

**Bowden Institution - Hot Water Systems Upgrade**

Reference No. R.023238.001

27-Feb-2015

**A. GENERAL**

There is one (1) page in this Addendum.

**B. REFER TO THE SPECIFICATIONS**

.1 SECTION 235200 - HEATING BOILERS

- .1 Item 2.3.7: Revise from *“Tubes rolled and beaded into tube sheets, accessible for cleaning and replacement.”* To *“Tube to be accessible for cleaning and replacement”*

**C. REFER TO THE DRAWINGS**

- .1 Drawing M9 – Schedules and schematics: Pump Schedule – P-1, P-2, Revise motor size from 11.19 kW to 3.75 kW
- .2 Drawing E1 – Electrical Plans
- .1 Delete Pricing General Note P1.
- .2 Motor Control Schedule:
- .1 Delete Amp Column
- .2 P-1, P-2.:
- .1 Revise motor size from 11.19 kW to 3.75.
- .2 Revise Breaker from 3P20A to 3P15A
- .3 Electrical Panel Schedule – Panel EAA: Revise Trip rating for Heating Water Distribution Pump P-1 and P-2 from 20 to 15.

**End of Addendum**