

Amendment 004

Q1) Please provide more information for HE-2. I require the GPM on the glycol as well as the steam pressure and the temperature rise

A1) Bid as per plans and specifications. Refer to section 232000 item 2.1.

Q2) Is there any base building or Control/fire alarm /security contractor?

A2) Delta Controls Inc is the contractor that manages the base building control system. The Base Building Automation System is Delta Controls. The building fire alarm system is EST3 Fireworks. FMC provides monitoring.