

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International).
 - .1 CAN/CSA C22.2 No.4-04 (R2009), Enclosed and Dead-Front Switches (Tri-National Standard With ANCE NMX-J-162-2004 and UL 98).
 - .2 CSA C22.2 No.39-13, Fuseholder Assemblies.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Separate for reuse and recycling and place in designated containers waste in accordance with Waste Management Plan.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

1.4 LEED 2009 REQUIREMENTS

- .1 LEED Documentation:
 - .1 Submit Material Safety Data Sheets (MSDS) or product data sheets, for all site applied interior paints, coatings, adhesives, sealants, sealant primers, concrete curing compounds, etc. to ensure compliance with LEED Requirements for low emitting materials as per Section 01 35 21.
-

PART 2 - PRODUCTS

2.1 DISCONNECT SWITCHES

- .1 Fusible, non-fusible, horsepower rated disconnect switch in CSA Enclosure Type 1 for indoor application and Type 4X for outdoor application, to CAN/CSA C22.2 No.4, size as indicated.
- .2 Provision for padlocking in off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Quick-make, quick-break action.
- .5 ON-OFF switch position indication on switch enclosure cover.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

2.3 WARNING SIGNS

- .1 Provide warning signs in accordance with Section 26 05 00 - Common Work Results - For Electrical.

2.4 LEED 2009 REQUIREMENTS

- .1 All site applied interior paints, coatings, adhesives, sealants, sealant primers, concrete curing compounds, etc. to comply with LEED Requirements for low emitting materials as per Section 01 35 21 - LEED 2009 Requirements.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install disconnect switches as indicated.