

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 26 29 03 - Control Devices

1.2 REFERENCES

- .1 Canadian Standards Association (CSA)
 - .1 CSA C22.2 No. 46-13, Electric Air-Heaters.

1.3 SHOP DRAWINGS

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawing sheets for unit heaters. Include:
 - .1 Product characteristics.
 - .2 Performance criteria.
 - .3 Mounting methods.
 - .4 Physical size.
 - .5 kW rating, voltage, phase.
 - .6 Cabinet material thickness.
 - .7 Limitations.
 - .8 Colour and finish.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide operation and maintenance data for unit heaters for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

PART 2 - PRODUCTS

2.1 UNIT HEATERS

- .1 Unit heater: to CSA C22.2 No. 46, horizontal discharge complete with adjustable louvers finished to match cabinet.
 - .2 Fan type unit heaters with built-in high-heat limit protection.
 - .3 Fan motor: totally enclosed, permanently lubricated ball bearing type with resilient mount. Built-in fan motor thermal overload protection.
-

- .4 Elements: mineral insulated, metal sheath with continuous helical steel fins.
- .5 Cabinet: steel, 18 gauge, fitted with brackets for wall mounting. Polyester epoxy powder coat paint finish almond colour.
- .6 Power Supply: 600 V, 60 Hz, 3ph.
- .7 Acceptable manufacturers:
 - .1 Ouellet OAS series.
 - .2 Approved Equal.

2.2 CONTROLS

- .1 Wall mounted thermostats: low voltage type, to Section 26 29 03 - Control Devices.
- .2 Built in contactor, 24 V relay with control transformer.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Mount on wall as indicated.
- .2 Install thermostat in location indicated.
- .3 Make power and control connections.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Test cut-out protection when air movement is obstructed.
- .3 Test fan delay switch to assure dissipation of heat after element shut down.
- .4 Test unit cut-off when fan motor overload protection has operated.
- .5 Ensure that heaters and controls operate correctly.