
PART 1 **GENERAL**

1.1 **RELATED REQUIREMENTS**

- .1 Section 01 33 00 – Submittal Procedures.
- .2 Section 01 74 21 – Construction/Waste Management and Disposal.
- .3 Section 04 05 00 – Common Work Results for Masonry.
- .4 Section 04 05 19 – Masonry Anchorage and Reinforcing.

1.2 **REFERENCES**

- .1 ASTM International Inc.
 - .1 ASTM D2240-05, Standard Test Method for Rubber Property - Durometer Hardness.
- .2 Canadian Standards Association (CSA International)
 - .1 CAN/CSA A371-04, Masonry Construction for Buildings.

1.3 **ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheets. Include product characteristics, performance criteria, and limitations.
- .3 Quality Assurance Submittals:
 - .1 Manufacturer's Instructions: submit in accordance with Section 04 05 00 - Common Work Results for Masonry, supplemented as follows:
 - .1 Submit installation instructions for brick vents, weeps, vents, diverters and flashings.

1.4 **FIELD MEASUREMENTS**

- .1 Make field measurements necessary to ensure proper fit of members.

1.5 **DELIVERY, STORAGE, AND HANDLING**

- .1 Deliver, store and handle masonry accessories in accordance with, Section 01 61 00 - Common Product Requirements, supplemented as follows:
 - .1 Keep fillers and adhesives dry, protected against dampness, and freezing.
-

- .2 Store packaged materials off ground and in accordance with manufacturer's written instructions.
- .2 Packaging Waste Management:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 PRODUCTS

2.1 MATERIALS

- .1 Movement joint filler: purpose-made elastomer 70 durometer hardness to ASTM D2240 of size and shape indicated.
 - .1 Material type: fibre board.
- .2 Lap adhesive: recommended by masonry flashing manufacturer.
- .3 Weep hole vents: purpose-made PVC.

2.2 MOISTURE CONTROL

- .1 Weep Hole Vents: PVC.
- .2 Cell vents: polypropylene plastic, honeycomb design.
 - .1 Size: 9.5 mm x 63.5 mm x 85.7 mm.
- .3 Colour: gray.
- .4 Mortar diverters: shaped and sized to suit cavity spaces.

2.3 FLASHINGS

- .1 Cavity wall flashing:
 - .1 SBS rubberized asphalt: 1.0 mm thick, self adhering, laminated to cross-laminated polyethylene film.

PART 3 EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.
-

3.2 INSTALLATION: MATERIALS

- .1 Install continuous movement joint fillers in movement joints at locations indicated on drawings.
- .2 Lap adhesive: apply adhesive to flashing lap joints.
- .3 Mechanical fasteners: install fasteners to suit application and in accordance with manufacturer's written installation instructions.
- .4 Brick vents: install brick vents at locations indicated on drawings.

3.3 INSTALLATION: MOISTURE CONTROL

- .1 Install weep hole vents in vertical joints immediately over flashings, in exterior wythes of cavity wall and masonry veneer wall construction, at maximum horizontal spacing of 600 mm on centre.
- .2 Mortar diverters: install purpose made diverters in cavities where indicated and as directed, size and shape to suit purpose and function.

3.4 INSTALLATION: FLASHINGS

- .1 Build in flashings in masonry in accordance with CAN/CSA A371.
 - .1 Install flashings under exterior masonry bearing on foundation walls, slabs, shelf angles, and steel angles over openings, and at base of cavity wall and where cavity is interrupted by horizontal members or supports and as shown on drawings. Install flashings under weep hole courses and as indicated.
 - .2 In cavity walls and veneered walls, carry flashings from front edge of exterior masonry, under outer wythe, then up backing not less than 150 mm, and as follows:
 - .1 For masonry backing embed or bond flashing 25 mm in joint.
 - .3 Lap joints 150 mm and seal with adhesive.
- .2 Form flashing (end dams) at lintels, sills and wall ends to prevent water from travelling horizontally past flashing ends.
- .3 Install vertical flashing where outer veneer returns at window or door jambs, to prevent contact of veneer with inner wall.

3.5 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.

- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.