

## **PART 1**      **GENERAL**

### **1.1**      **RELATED SECTIONS**

- .1      Section 01 33 00 – Submittal Procedures.
- .2      Section 01 74 21 – Construction/Demolition Waste Management and Disposal.
- .3      Section 06 10 00 – Rough Carpentry.
- .4      Section 07 31 13 – Asphalt Shingles.
- .5      Section 07 92 00 – Joint Sealants.

### **1.2**      **REFERENCES**

- .1      American Society for Testing and Materials International (ASTM)
  - .1      ASTM A792/A792M-10, Standard Specification for Steel Sheet, 55% Aluminum-Zinc Alloy-Coated by the Hot-Dip Process.
  - .2      ASTM D523-08, Standard Test Method for Specular Gloss.
- .2      Canadian Roofing Contractors Association (CRCA)
  - .1      Roofing Specifications Manual 1997.
- .3      Canadian Standards Association (CSA International)
  - .1      CSA B111-1974(R2003), Wire Nails, Spikes and Staples.
- .4      Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1      Material Safety Data Sheets (MSDS).

### **1.3**      **SUBMITTALS**

- .1      Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2      Product Data:
    - .1      Submit manufacturer's printed product literature for sheet metal flashing systems materials, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
  - .3      Samples:
    - .1      Submit duplicate 50 x 50 mm samples of each type of sheet metal material, finishes and colours.
-

## **1.4 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

## **PART 2 PRODUCTS**

### **2.1 SHEET METAL MATERIALS**

- .1 Aluminum-zinc alloy coated steel sheet: to ASTM A792/A792M, commercial quality, grade 33 with AZ150 coating, regular spangle surface, 0.61 mm base metal thickness.

### **2.2 PREFINISHED STEEL SHEET**

- .1 Prefinished steel with factory applied polyvinylidene fluoride.
  - .1 Class F1S.
  - .2 Colour selected by Departmental Representative from manufacturer's standard range.
  - .3 Specular gloss: 30 units +/- in accordance with ASTM D523.
  - .4 Coating thickness: not less than 22 micrometres.
  - .5 Resistance to accelerated weathering for chalk rating of 8, colour fade 5 units or less and erosion rate less than 20% to ASTM D822 as follows:
    - .1 Outdoor exposure period 2500 hours.
    - .2 Humidity resistance exposure period 5000 hours.

### **2.3 ACCESSORIES**

- .1 Isolation coating: alkali resistant bituminous paint.
  - .2 Plastic cement: to CAN/CGSB 37.5.
  - .3 Fasteners: of same material as sheet metal, to CSA B111, ring thread flat head roofing nails of length and thickness suitable for metal flashing application.
  - .4 Touch-up paint: as recommended by prefinished material manufacturer.
-

## **2.4 FABRICATION**

- .1 Fabricate metal flashings and other sheet metal work in accordance with applicable CRCA 'FL' series details and as indicated.
- .2 Form pieces in 2400 mm maximum lengths.
  - .1 Make allowance for expansion at joints.
- .3 Hem exposed edges on underside 12 mm.
  - .1 Mitre and seal corners with sealant.
- .4 Form sections square, true and accurate to size, free from distortion and other defects detrimental to appearance or performance.
- .5 Apply isolation coating to metal surfaces to be embedded in concrete or mortar.

## **2.5 METAL FLASHINGS**

- .1 Form flashings, copings and fascias to profiles indicated of 0.61 mm thick prefinished steel.

## **PART 3 EXECUTION**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

### **3.2 INSTALLATION**

- .1 Install sheet metal work in accordance with CRCA FL series details, FL Series and detailed.
- .2 Use concealed fastenings except where approved before installation.
- .3 Lock end joints and caulk with sealant.

### **3.3 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.
- .3 Leave work areas clean, free from grease, finger marks and stains.