

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

- .1 Section 26 28 20 - Ground Fault Circuit Interrupters - Class "A".
- .2 Section 27 05 26 - Grounding and Bonding For Communications Systems.

1.2 REFERENCES

- .1 American National Standards Institute /Institute of Electrical and Electronics Engineers (ANSI/IEEE)
 - .1 ANSI/IEEE 837-02, IEEE Standard for Qualifying Permanent Connections Used in Substation Grounding.
- .2 CSA International
 - .1 CSAZ462-12, Workplace Electrical Safety.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for grounding equipment and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for grounding equipment for incorporation into manual.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .3 Storage and Handling Requirements:
 - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
-

- .2 Store and protect grounding equipment from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.
- .4 Packaging Waste Management: remove for reuse packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.6 LEED 2009 REQUIREMENTS

- .1 LEED Documentation:
 - .1 Submit Material Safety Data Sheets (MSDS) or product data sheets, for all site applied interior paints, coatings, adhesives, sealants, sealant primers, concrete curing compounds, etc. to ensure compliance with LEED Requirements for low emitting materials as per Section 01 35 21.

PART 2 - PRODUCTS

2.1 EQUIPMENT

- .1 Clamps for grounding of conductor: size as required to electrically conductive underground water pipe.
 - .2 Copper conductor: minimum 6 m long for each concrete encased electrode, bare, stranded, MHD, size as indicated.
 - .3 Rod electrodes: copper clad steel 19 mm diameter by minimum 3 m long.
 - .4 Grounding conductors: bare stranded copper, soft annealed, size as indicated.
 - .5 Insulated grounding conductors: green, copper conductors, RW90, size as indicated. Minimum size #12 AWG.
 - .6 Ground bus: copper, size as indicated, complete with insulated supports, fastenings, connectors.
 - .7 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
 - .1 Grounding and bonding bushings.
 - .2 Protective type clamps.
 - .3 Bolted type conductor connectors.
 - .4 Thermit welded type conductor connectors.
 - .5 Bonding jumpers, straps.
 - .6 Pressure wire connectors.
 - .7 Compression connectors.
-

2.2 LEED 2009 REQUIREMENTS

- .1 All site applied interior paints, coatings, adhesives, sealants, sealant primers, concrete curing compounds, etc. to comply with LEED Requirements for low emitting materials as per Section 01 35 21 - LEED 2009 Requirements.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for grounding equipment installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Department Representative.

3.2 INSTALLATION GENERAL

- .1 Install complete permanent, continuous grounding system including, electrodes, conductors, connectors, accessories. Run insulated ground wire in each conduit.
 - .2 Install connectors in accordance with manufacturer's instructions.
 - .3 Protect exposed grounding conductors from mechanical injury.
 - .4 Make buried connections, and connections to conductive water main, electrodes, using copper welding by thermit process.
 - .5 Use mechanical connectors for grounding connections to equipment provided with lugs.
 - .6 Soldered joints not permitted.
 - .7 Install bonding wire for flexible conduit, connected at both ends to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.
 - .8 Install flexible ground straps as required.
 - .9 Install separate ground conductor to outdoor lighting standards.
-

- .10 Connect building structural steel and metal siding to ground by welding copper to steel.
- .11 Make grounding connections in radial configuration only, with connections terminating at single grounding point. Avoid loop connections.

3.3 MAINTENANCE HOLES

- .1 Install conveniently located grounding stud, electrode, size as indicated stranded copper conductor in each maintenance hole.
- .2 Install ground rod in each maintenance hole so that top projects through bottom of maintenance hole. Provide with lug to which grounding connection can be made. Confirm ground resistance meets or exceeds Canadian Electrical Code minimum requirements.

3.4 ELECTRODES

- .1 Install rod, electrodes and make grounding connections as indicated.
- .2 Bond separate, multiple electrodes together.
- .3 Use size 4/0 AWG copper conductors for connections to electrodes.
- .4 Make special provision for installing electrodes that will give acceptable resistance to ground value where rock or sand terrain prevails.

3.5 SYSTEM AND CIRCUIT GROUNDING

- .1 Install system and circuit grounding connections to neutral of secondary 120/ 208 and 347/600 V systems.

3.6 EQUIPMENT GROUNDING

- .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list. Service equipment, transformers, switchgear, duct systems, frames of motors, starters, control panels, building steel work, pumps, distribution panels, outdoor lighting.
-

3.7 GROUNDING BUS

- .1 Install copper grounding bus mounted on insulated supports on wall of electrical room and communication equipment room.
- .2 Ground items of electrical equipment in electrical room and IT equipment in communication equipment room to ground bus with individual bare stranded copper connections size 2/0AWG, unless noted otherwise.

3.8 COMMUNICATION SYSTEMS

- .1 Install grounding connections for telephone and intercommunication systems as follows:
 - .1 Make grounding system in accordance with utility company's requirements.

3.9 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.
- .4 Disconnect ground fault indicator during tests.

3.10 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.