



## Addendum 3

**Project Title:** Office Fit-up, rooms 2130 - 2140  
Building 20  
Central Experimental Farm (CEF), Ottawa (Ontario)

**Solicitation No:** 14-1392

March 9, 2015

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

---

### Q & A

**Q1. Item 2 of the Description of Work of 1/M1 “HVAC & Fire Protection Demolition Work” of drawing M1 indicates that the existing radiant heaters are to be removed and pressure washed one at the time. Can you indicate the existing type of radiant heaters (electric, hot water, etc...)?**

A1. The existing radiant heaters are steam heaters. AAFC will disconnect steam supply of each unit before removal and will re-connect after reinstallation.

**Q2. Who applies for and pays for the building permit?**

A2. Refer to GC1.8 “Laws, Permits and Taxes” of the General Conditions. We also suggest bidders to consult GI04 of the General Instructions to Bidders.

**Q3. Has the Vinyl Composition Tile (VCT) flooring been specified?**

A3. Yes, refer to Section 09 65 10 “Resilient Tile Flooring”.

**Q4. What is the existing flooring?**

A4. There is presently no flooring, exposed concrete floor.

**Q5. The specifications indicate some resilient bases but A3 drawing indicates wood bases, what is to be done?**

A5. Salvaged wood bases, supplied by AAFC, must be used for existing walls. Resilient bases are to be used for new walls only.

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**