

SimplexGrinnell

4100u Programmer

Report

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 2

Slot : No Space

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00000010

Name	Device Type	Point Type	Custom Label	PNIS code
M1-1-0	IAM	LATSUPV	MAIN PUMP RM. FIRE PUMP BYPASS VALVE #1	
M1-2-0	IAM	LATSUPV	MAIN PUMP RM. FIRE PUMP BYPASS VALVE #2	
M1-3-0	IAM	LATSUPV	MAIN PUMP RM MAIN SPRINKLER VALVE CLOSED	
M1-4-0	IAM	LATSUPV	MAIN PUMP RM MAIN SPRINKLER LOW PRESSURE	
M1-5-0	IAM	WATER	MAIN PUMP RM MAIN SPRINKLER RISER FLOW	
M1-6-0	IAM	LATSUPV	PUMP RM. JOCKEY PUMP SUCTION VALVE	
M1-7-0	IAM	LATSUPV	PUMP RM. STANDBY PUMP SUCTION VALVE	
M1-8-0	IAM	LATSUPV	PUMP RM. LEAD PUMP SUCTION VALVE	
M1-9-0	IAM	LATSUPV	PUMP RM. STANDBY PUMP TEST HEADER VALVE	
M1-10-0	IAM	LATSUPV	PUMP RM. STANDBY PUMP DISCHARGE VALVE	
M1-11-0	IAM	LATSUPV	PUMP RM. LEAD PUMP TEST HEADER VALVE	
M1-12-0	IAM	LATSUPV	PUMP RM. LEAD PUMP DISCHARGE VALVE	
M1-13-0	IAM	LATSUPV	PUMP RM. LEAD PUMP TRANSFER SWITCH	
M1-14-0	IAM	TROUBLE	PUMP RM. LEAD FIRE PUMP RUNNING	
M1-15-0	IAM	LATSUPV	PUMP RM. LEAD FIRE PUMP LOSS OF PHASE	
M1-16-0	IAM	TROUBLE	PUMP RM. LEAD FIRE PUMP TROUBLE	
M1-17-0	IAM	LATSUPV	PUMP RM. LEAD FIRE PUMP PHASE REVERSAL	
M1-18-0	IAM	LATSUPV	PUMP RM. STANDBY PUMP TRANSFER SWITCH	
M1-19-0	IAM	TROUBLE	PUMP RM. STANDBY FIRE PUMP RUNNING	
M1-20-0	IAM	LATSUPV	PUMP RM. STANDBY PUMP LOSS OF PHASE	
M1-21-0	PHOTO	SMOKE	SUB-BAS'T WEST CORRIDOR OUEST	
M1-22-0	PHOTO	SMOKE	SUB-BAS'T WEST CORRIDOR OUEST	
M1-23-0	PHOTO	SMOKE	SUB-BAS'T WEST CORRIDOR OUEST	
M1-24-0	PHOTO	SMOKE	SUB-BAS'T WEST WING/AILE OUEST	
M1-25-0	IPHOTO	SMOKE	SUB-BAS'T WEST WING/AILE OUEST	
M1-26-0	PHOTO	SMOKE	SUB-BAS'T WEST WING/AILE OUEST	
M1-27-0	CANPUL	S2STAGE	SUB-BAS'T WEST WING/AILE OUEST	
M1-28-0	IAM	WATER	SUB-BAS'T WEST ELEV PIT#2 SPRINKLER FLOW	
M1-29-0	IAM	LATSUPV	SUB-BAS'T WEST ELEV. PIT SPRINK. VALVE	
M1-30-0	IDNETISO	ISO	PROTECTING LOOP TO PUMP ROOM	
M1-31-0	IDNETISO	ISO	PROTECTING LOOP FROM PUMP ROOM	
M1-32-0	IAM	LATSUPV	PUMP RM. JOCKEY PUMP DISCHARGE VALVE	
M1-33-0	IAM	TROUBLE	PUMP RM. STANDBY FIRE PUMP TROUBLE	
M1-34-0	IAM	LATSUPV	PUMP RM. STANDBY PUMP PHASE REVERSAL	
M1-35-0	IAM	WATER	SUB-BAST TUNNELS/MECH RMS-SPRINKLER FLOW	
M1-36-0	IAM	LATSUPV	SUB-BAS'T WEST SPRINKLER VALVE CLOSED	
M1-37-0	IAM	TROUBLE	PUMP RM. BOSTER PUMP LOSS OF POWER	
M1-38-0	IAM	LATSUPV	PUMP RM. CITY MAIN INCOMING VALVE CLOSED	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 2

Slot : No Space

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00000010

Name	Device Type	Point Type	Custom Label	PNIS code
M1-40-0	PHOTO	SMOKE	BAS'T WEST WOMEN'S CHANGE-ROOM	
M1-41-0	PHOTO	SMOKE	BAS'T WEST MEN'S CHANGE-ROOM	
M1-42-0	PHOTO	SMOKE	BAS'T WEST ELEVATOR MACHINE RM.	
M1-43-0	PHOTO	SMOKE	BAS'T WEST MECHANICAL RM.	
M1-44-0	IPHOTO	SMOKE	BAS'T WEST ELCTRICAL RM.	
M1-45-0	PHOTO	SMOKE	BAS'T WEST COMMUNICATION RM.	
M1-46-0	PHOTO	SMOKE	BAS'T WEST SERVICE TUNNEL TO ANIMAL DISP	
M1-47-0	CANPUL	S2STAGE	BAS'T WEST AT STAIR "D" ESCALIER	
M1-48-0	RIAM	RELAY	BAS'T WEST DOOR STRIKE/HOLDER LOCK	
M1-49-0	CANPUL	S2STAGE	BAS'T WEST AT STAIR "C" ESCALIER	
M1-50-0	RIAM	RELAY	BAS'T WEST FAN SHUT-DOWN A.H.U. 13-01	
M1-51-0	RIAM	RELAY	BAS'T WEST FAN SHUT-DOWN A.H.U. 13-02	
M1-52-0	PHOTO	DUCT	BAS'T WEST MECH. RM. A.H.U. 13-02	
M1-53-0	PHOTO	SMOKE	SUB-BAS'T NORTH PUMP ROOM	
M1-54-0	PHOTO	SMOKE	SUB-BAS'T NORTH CORRIDOR	
M1-55-0	PHOTO	SMOKE	SUB-BAS'T NORTH CMN SPECIMEN STORAGE	
M1-56-0	PHOTO	SMOKE	SUB-BAS'T NORTH FACILITIES CHEM. STORAGE	
M1-57-0	PHOTO	SMOKE	SUB-BAS'T NORTH - EAST STORAGE ROOM	
M1-58-0	PHOTO	SMOKE	SUB-BAS'T NORTH - WEST STORAGE ROOM	
M1-59-0	IAM	LATSUPV	BAS'T WEST STANDPIPE VALVE IN STAIR "D"	
M1-60-0	IAM	LATSUPV	BAS'T WEST STANDPIPE VALVE IN STAIR "C"	
M1-61-0	IAM	WATER	BAS'T WEST SPRINKLER FLOW	
M1-62-0	IAM	LATSUPV	BAS'T WEST SPRINKLER VALVE CLOSED	
M1-63-0	PHOTO	SMOKE	TOP OF WEST ELEVATOR SHAFT #2	
M1-64-0	PHOTO	SMOKE	WEST ELEVATOR PIT #2	
M1-65-0	IDNETISO	ISO	PROTECTING TOP OF WEST ELEVATOR SHAFT	
M1-66-0	IDNETISO	ISO	PROTECTING WEST ELEVATOR PIT	
M1-67-0	RIAM	RELAY	WEST ELEVATOR #2 RECALL	
M1-68-0	RIAM	RELAY	WEST ELEVATOR #2 SHAFT FIRE	
M1-69-0	IAM	S2STAGE	BAS'T WEST - SOUTH TURRET EXIT	
M1-70-0	IAM	S2STAGE	BAS'T WEST - NORTH TURRET EXIT	
M1-71-0	PHOTO	DUCT	SUB-BAS'T NORTH-E.R.V.#1 FOR BAS'T LOBBY	
M1-72-0	RIAM	RELAY	SUB-BAS'T NORTH - E.R.V.#1 SHUTDOWN	
M1-73-0	RIAM	RELAY	SUB-BAS'T NORTH - E.R.V.#1 SMOKE EVAC	
M1-74-0	PHOTO	DUCT	SUB-BAS'T NORTH -E.R.V.#2 FOR MAIN LOBBY	
M1-75-0	RIAM	RELAY	SUB-BAS'T NORTH - E.R.V.#2 SHUTDOWN	
M1-76-0	RIAM	RELAY	SUB-BAS'T NORTH -FAN-04 FOR BAS'T ATRIUM	
M1-77-0	CANPUL	S2STAGE	BASEMENT WEST-MAIN WEST EXIT	

Card Detail

Card No: 2 Slot : No Space

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00000010

Name	Device Type	Point Type	Custom Label	PNIS code
M1-78-0	CANPUL	S2STAGE	1ST FL WEST-MAIN WEST EXIT VESTIBULE	
M1-79-0	PHOTO	SMOKE	SUB-BAS'T NORTH MEZZANINE AREA	
M1-80-0	PHOTO	SMOKE	SUB-BAS'T NORTH HANDI-CAP ELEV#4 MACH RM	
M1-81-0	RIAM	RELAY	SUB-BAS'T NORTH HANDI-CAP ELEV #4 RECALL	
M1-82-0	RIAM	RELAY	SUB-BAS'T HANDI-CAP ELEV #4 MACH RM FIRE	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 15

Slot : Block E

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00001111

Name	Device Type	Point Type	Custom Label	PNIS code
M2-18-0	CANPUL	S2STAGE	1ST FL WEST-MAIN WEST EXIT	
M2-19-0	PHOTO	SMOKE	1ST FL WEST-MAIN WEST EXIT VESTIBULE	
M2-20-0	PHOTO	SMOKE	1ST FL WEST WING STAIR "C" ESCALIER	
M2-21-0	IPHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY MEZZ.	
M2-22-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY MEZZ.	
M2-23-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY MEZZ.	
M2-24-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY MEZZ.	
M2-25-0	PHOTO	SMOKE	1ST FL WEST WING ELEC/SALLE ELECTRIQUE	
M2-26-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY MEZZ.	
M2-27-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY MEZZ.	
M2-28-0	PHOTO	SMOKE	1ST FL WEST WING COMM. RM/COMMUNICATION	
M2-29-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY FOSSILES	
M2-30-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY FOSSILES	
M2-31-0	PHOTO	SMOKE	1ST FL WEST WING MEZZANINE CONTROL RM.	
M2-32-0	PHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY FOSSILES	
M2-33-0	IPHOTO	SMOKE	1ST FL WEST WING FOSSIL GALLERY FOSSILES	
M2-34-0	IPHOTO	SMOKE	1ST FL WEST WING STAIR "D" ESCALIER	
M2-35-0	PHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-36-0	PHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-37-0	PHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-38-0	IPHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-39-0	PHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-40-0	PHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-41-0	PHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-42-0	PHOTO	SMOKE	1ST FL WEST HALL FOSSIL GALLERY FOSSILES	
M2-43-0	PHOTO	SMOKE	1ST FL WEST HALL SERVICE MEZZANINE	
M2-44-0	PHOTO	SMOKE	1ST FL WEST HALL ELECTRICAL CLOSET	
M2-45-0	PHOTO	SMOKE	1ST FL WEST WING LOWER FOSSIL GALLERY	
M2-46-0	PHOTO	SMOKE	1ST FL WEST WING LOWER FOSSIL GALLERY	
M2-47-0	PHOTO	SMOKE	1ST FL WEST WING LOWER FOSSIL STORAGE RM	
M2-48-0	PHOTO	SMOKE	1ST FL WEST WING LOWER FOSSIL GALLERY	
M2-49-0	PHOTO	SMOKE	1ST FL WEST WING LOWER FOSSIL GALLERY	
M2-50-0	COMBO	UTILITY	1ST FL WEST WING EXTINCTION THEATRE	
M2-50-1	MPHOTO	SMOKE	1ST FL WEST WING EXTINCTION THEATRE	
M2-50-2	MOHEAT	HEAT	1ST FL WEST WING EXTINCTION THEATRE	
M2-50-3	MARCOR	UCOR	1ST FL WEST WING EXTINCTION THEATRE	
M2-51-0	COMBO	UTILITY	1ST FL WEST WING EXTINCTION THEATRE	
M2-51-1	MPHOTO	SMOKE	1ST FL WEST WING EXTINCTION THEATRE	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 15

Slot : Block E

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00001111

Name	Device Type	Point Type	Custom Label	PNIS code
M2-51-2	MOHEAT	HEAT	1ST FL WEST WING EXTINCTION THEATRE	
M2-51-3	MARCOR	UCOR	1ST FL WEST WING EXTINCTION THEATRE	
M2-52-0	PHOTO	SMOKE	1ST FL WEST WING LOWER FOSSIL GALLERY	
M2-53-0	CANPUL	S2STAGE	1ST FL WEST WING AT STAIR "C" ESCALIER	
M2-54-0	CANPUL	S2STAGE	1ST FL WEST HALL EXIT TO STAIR "F"	
M2-55-0	PHOTO	SMOKE	1ST FL WEST HALL COAT ROOM	
M2-56-0	RIAM	RELAY	1ST FL WEST HALL "WON" DOOR RELEASE	
M2-57-0	CANPUL	S2STAGE	1ST FL WEST WING AT STAIR "D" ESCALIER	
M2-58-0	CANPUL	S2STAGE	1ST FL WEST HALL AT SOUTH EXIT	
M2-59-0	PHOTO	SMOKE	1ST FL WEST HALL EXIHIBITION VESTIBULE	
M2-60-0	IAM	LATSUPV	1ST FL WEST WING SPRINKLER VALVE CLOSED	
M2-62-0	IAM	WATER	1ST FL WEST WING SPRINKLER FLOW	
M2-70-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-71-0	IPHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-72-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-73-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-74-0	IPHOTO	SMOKE	2ND FL WEST WING ELEC/SALLE ELECTRIQUE	
M2-75-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-76-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-77-0	PHOTO	SMOKE	2ND FL WEST WING COMM. RM/COMMUNICATION	
M2-78-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-79-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-80-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-81-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-82-0	IPHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-83-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-84-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-85-0	IPHOTO	SMOKE	2ND FL WEST HALL ELEVATOR LOBBY	
M2-86-0	IPHOTO	SMOKE	2ND FL WEST HALL MECH SHAFT/PUIT SOUTH	
M2-87-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-88-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-89-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-90-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-91-0	PHOTO	SMOKE	2ND FL WEST HALL MECH SHAFT/PUIT NORTH	
M2-92-0	CANPUL	S2STAGE	2ND FL WEST WING AT STAIR "C" ESCALIER	
M2-93-0	CANPUL	S2STAGE	2ND FL WEST WING AT STAIR "D" ESCALIER	
M2-94-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	
M2-95-0	PHOTO	SMOKE	2ND FL WEST WING MAMMALS/MAMMIFERES	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 15

Slot : Block E

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00001111

Name	Device Type	Point Type	Custom Label	PNIS code
M2-96-0	PHOTO	SMOKE	2ND FL WEST HALL ELEC CLOSET/ELECTRIQUE	
M2-97-0	PHOTO	SMOKE	2ND FL WEST HALL SERVICE MEZZ DE SERVICE	
M2-98-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-99-0	IAM	WATER	2ND FL WEST SPRINKLER FLOW	
M2-100-0	IAM	LATSUPV	2ND FL WEST SPRINKLER VALVE CLOSED	
M2-101-0	RIAM	RELAY	2ND FLR WEST HALL "WON" DOOR RELEASE	
M2-102-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-103-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-104-0	PHOTO	SMOKE	2ND FL WEST HALL WOMENS WASH ROOM	
M2-105-0	PHOTO	SMOKE	2ND FL WEST HALL MAMMALS/MAMMIFERES	
M2-106-0	CANPUL	S2STAGE	2ND FL WEST HALL EXIT TO STAIR "F"	
M2-107-0	RIAM	RELAY	2ND FL WEST HANDICAP DOOR OPEN POWER OFF	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 17

Slot : Block F

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010001

Name	Device Type	Point Type	Custom Label	PNIS code
M3-19-0	PHOTO	SMOKE	3RD FL WEST HALL EXHIBITION VESTIBULE	
M3-20-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-21-0	IPHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-22-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-23-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-24-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-25-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-26-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-27-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-28-0	PHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-29-0	IPHOTO	SMOKE	3RD FL WEST WING TEMPORARY GALLERY/AILE	
M3-30-0	PHOTO	SMOKE	3RD FL WEST WING STAIR "D" ESCALIER	
M3-31-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-32-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-33-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-34-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-35-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-36-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-37-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-38-0	PHOTO	SMOKE	3RD FL WEST HALL TEMPORARY GALLERY	
M3-39-0	IPHOTO	SMOKE	3RD FL WEST WING ELEC/SALLE ELECTRIQUE	
M3-40-0	PHOTO	SMOKE	3RD FL WEST WING COMM. RM/COMMUNICATION	
M3-41-0	CANPUL	S2STAGE	3RD FL WEST WING AT STAIR "C" ESCALIER	
M3-42-0	CANPUL	S2STAGE	3RD FL WEST WING AT STAIR "D" ESCALIER	
M3-43-0	IPHOTO	SMOKE	3RD FL WEST WING STAIR "C" ESCALIER	
M3-44-0	PHOTO	SMOKE	3RD FL WEST HALL WOMENS WASHROOM	
M3-45-0	PHOTO	SMOKE	3RD FL WEST HALL ELEC CLOSET/ELECTRIQUE	
M3-46-0	PHOTO	SMOKE	3RD FL WEST HALL SERVICE MEZZ DE SERVICE	
M3-47-0	IAM	WATER	3RD FL WEST SPRINKLER FLOW	
M3-48-0	IAM	LATSUPV	3RD FL WEST SPRINKLER VALVE CLOSED	
M3-49-0	RIAM	RELAY	3RD FL WEST HALL "WON" DOOR RELEASE	
M3-50-0	CANPUL	S2STAGE	3RD FL WEST HALL EXIT TO STAIR "F"	
M3-51-0	RIAM	RELAY	3RD FL WEST HANDICAP DOOR POWER OFF	
M3-55-0	IPHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	
M3-56-0	PHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	
M3-57-0	PHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	
M3-58-0	PHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	
M3-59-0	PHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 17

Slot : Block F

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010001

Name	Device Type	Point Type	Custom Label	PNIS code
M3-60-0	PHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	
M3-61-0	IPHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	
M3-62-0	PHOTO	SMOKE	4TH FL WEST HALL MULTI-PURPOSE GALLERY	
M3-63-0	PHOTO	SMOKE	4TH FL WEST WING COMM. RM/COMMUNICATION	
M3-64-0	PHOTO	SMOKE	4TH FL WEST WING ELEC/SALLE ELECTRIQUE	
M3-65-0	IPHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-66-0	IPHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-67-0	PHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-68-0	PHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-69-0	PHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-70-0	PHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-71-0	PHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-72-0	IPHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-73-0	PHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-74-0	IPHOTO	SMOKE	4TH FL WEST BIRD WING/GALERIE OISEAUX	
M3-75-0	CANPUL	S2STAGE	4TH FL WEST WING AT STAIR "C" ESCALIER	
M3-76-0	CANPUL	S2STAGE	4TH FL WEST WING AT STAIR "D" ESCALIER	
M3-77-0	IAM	WATER	4TH FL WEST SPRINKLER FLOW	
M3-78-0	IAM	LATSUPV	4TH FL WEST SPRINKLER VALVE CLOSED	
M3-79-0	IPHOTO	SMOKE	4TH FL WEST HALL EXHIBITION VESTIBULE	
M3-80-0	PHOTO	SMOKE	4TH FL WEST HALL WOMENS WASHROOM	
M3-81-0	PHOTO	SMOKE	4TH FL WEST HALL ELEC CLOSET/ELECTRIQUE	
M3-82-0	PHOTO	SMOKE	4TH FL WEST HALL SERVICE MEZZ DE SERVICE	
M3-83-0	IDNETISO	ISO	PROTECTING 4TH FL LOCATED IN ELEC RM.	
M3-84-0	RIAM	RELAY	4TH FL WEST HANDICAP DOOR POWER OFF	
M3-86-0	RIAM	RELAY	4TH FL WEST HALL "WON" DOOR RELEASE	
M3-87-0	CANPUL	S2STAGE	4TH FL WEST HALL EXIT TO STAIR "F"	
M3-90-0	PHOTO	SMOKE	TOP OF SOUTH/WEST STAIR "C" ESCALIER	
M3-91-0	PHOTO	SMOKE	TOP OF NORTH/WEST STAIR "D" ESCALIER	
M3-92-0	PHOTO	SMOKE	WEST PENTHOUSE ELEVATOR LOBBY	
M3-93-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#9-01 SUPPLY	
M3-94-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#9-02 RETURN	
M3-95-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#11-02 RETURN	
M3-96-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#3-01 SUPPLY	
M3-97-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#4-01 SUPPLY	
M3-98-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#6-01 SUPPLY	
M3-99-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#5-01SUPPLY	
M3-100-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#8-02 RETURN	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 17

Slot : Block F

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010001

Name	Device Type	Point Type	Custom Label	PNIS code
M3-101-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#7-01 SUPPLY	
M3-102-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#8-01 SUPPLY	
M3-103-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#10-02 RETURN	
M3-104-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#10-01 SUPPLY	
M3-105-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#11-01 SUPPLY	
M3-106-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#1-02 RETURN	
M3-107-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#1-01 SUPPLY	
M3-108-0	PHOTO	DUCT	WEST PENTHOUSE A.H.U.#2-01 SUPPLY	
M3-109-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#9-01 SHUT-DOWN	
M3-110-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#9-02 SHUT-DOWN	
M3-111-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#11-02 SHUT-DOWN	
M3-112-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#4-01 SHUT-DOWN	
M3-113-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#3-01 SHUT-DOWN	
M3-114-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#6-01 SHUT-DOWN	
M3-115-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#5-01 SHUT-DOWN	
M3-116-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#8-02 SHUT-DOWN	
M3-117-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#10-01 SHUT-DOWN	
M3-118-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#11-01 SHUT-DOWN	
M3-119-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#10-02 SHUT-DOWN	
M3-120-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#7-01 SHUT-DOWN	
M3-121-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#8-01 SHUT-DOWN	
M3-122-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#2-01 SHUT-DOWN	
M3-123-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#1-01 SHUT-DOWN	
M3-124-0	RIAM	RELAY	WEST PENTHOUSE A.H.U.#1-02 SHUT-DOWN	
M3-125-0	IAM	WATER	WEST PENTHOUSE SPRINKLER FLOW	
M3-126-0	IAM	LATSUPV	WEST PENTHOUSE SPRINKLER VALVE CLOSED	
M3-127-0	CANPUL	S2STAGE	WEST PENTHOUSE EXIT TO STAIRWELL "F"	
M3-128-0	CANPUL	S2STAGE	WEST PENTHOUSE AT ESCAPE LADDER	
M3-129-0	IAM	WATER	WEST ROOF TURRET GLYCOL SPRINKLER FLOW	
M3-130-0	IAM	LATSUPV	WEST ROOF TURRET SPRINKLER VALVE CLOSED	
M3-131-0	RIAM	RELAY	WEST PENT. ELEV. #2 PRESSURIZATION FAN	
M3-132-0	IDNETISO	ISO	PROTECTING AND LOCATED IN TURRET "C"	
M3-133-0	IDNETISO	ISO	PROTECTING AND LOCATED IN TURRET "D"	
M3-140-0	PHOTO	SMOKE	ROOF-TOP SOUTH-WEST TURRET #3	
M3-141-0	PHOTO	SMOKE	ROOF-TOP NORTH-WEST TURRET #4	
M3-142-0	PHOTO	SMOKE	UPPER WEST PENTHOUSE - WEST END	
M3-143-0	PHOTO	SMOKE	UPPER WEST PENTHOUSE - CENTER AREA	
M3-144-0	PHOTO	SMOKE	UPPER WEST PENTHOUSE - CENTER AREA	

Job Description : VIC MUSEUM WEST 4

Wednesday, February 04, 2015 - 7:26 AM

Card Detail

Card No: 17 Slot : Block F

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010001

Name	Device Type	Point Type	Custom Label	PNIS code
M3-145-0	PHOTO	SMOKE	UPPER WEST PENTHOUSE - EAST END	
M3-146-0	CANPUL	S2STAGE	ROOF-TOP SOUTH-WEST TURRET #3	
M3-147-0	CANPUL	S2STAGE	ROOF-TOP NORTH-WEST TURRET #4	
M3-150-0	PHOTO	DUCT	SOUTH-WEST TURRET #3 A.H.U.#39 SUPPLY	
M3-151-0	PHOTO	DUCT	NORTH-WEST TURRET #4 A.H.U.#40 SUPPLY	
M3-152-0	RIAM	RELAY	NORTH-WEST TUR.#4 A.H.U.#40 -01 SHUTDOWN	
M3-153-0	RIAM	RELAY	SOUTH-WEST TUR.#3 A.H.U.#39 -01 SHUTDOWN	