

SimplexGrinnell

4100u Programmer

Report

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 2

Slot : No Space

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00000010

Name	Device Type	Point Type	Custom Label	PNIS code
M1-20-0	IPHOTO	SMOKE	SUB-BASEMENT EAST WING SOUTH	
M1-21-0	PHOTO	SMOKE	SUB-BASEMENT EAST WING CENTER	
M1-22-0	PHOTO	SMOKE	SUB-BASEMENT EAST WING NORTH	
M1-23-0	PHOTO	SMOKE	SUB-BASEMENT EAST HALL	
M1-24-0	PHOTO	SMOKE	SUB-BASEMENT EAST HALL	
M1-25-0	PHOTO	SMOKE	SUB-BASEMENT EAST HALL	
M1-26-0	PHOTO	SMOKE	SUB-BASEMENT EAST HALL	
M1-27-0	CANPUL	S2STAGE	SUB-BASEMENT EAST WING NORTH EXIT	
M1-28-0	IAM	LATSUPV	SUB-BAS'T EAST ELEV. PIT SPRINK. VALVE	
M1-29-0	IAM	WATER	SUB-BAS'T EAST ELEV. PIT#1 SPRINK. FLOW	
M1-30-0	IDNETISO	ISO	SUB-BASEMENT EAST AT SHAFT TO MACHINE RM	
M1-31-0	IAM	WATER	2ND FL BUTTERFLY STAIR&LANTERN SPRINKLER	
M1-32-0	IAM	LATSUPV	2ND FL BUTTERFLY STAIR&LANTERN VALVE	
M1-36-0	CANPUL	S2STAGE	BASEMENT EAST SOUTH/EAST TURRET EXIT	
M1-37-0	CANPUL	S2STAGE	BASEMENT EAST NORTH/EAST TURRET EXIT	
M1-38-0	CANPUL	S2STAGE	BAST NORTH/EAST WING AT STAFF WASHROOMS	
M1-39-0	PHOTO	SMOKE	BASEMENT EAST WING SECURITY DESK	
M1-41-0	PHOTO	SMOKE	BAST EAST WING FIRST AID AREA WASHROOM	
M1-42-0	IPHOTO	SMOKE	BAST EAST HALL MAIN ELECTRICAL ROOM	
M1-43-0	PHOTO	SMOKE	BAST EAST WING FIRST AID ROOM	
M1-44-0	PHOTO	SMOKE	BASEMENT EAST HALL COMMUNICATIONS RM.	
M1-45-0	PHOTO	SMOKE	BAST EAST WING MEN'S STAFF WASHROOM	
M1-46-0	IPHOTO	SMOKE	BAST EAST WING WOMEN'S STAFF WASHROOM	
M1-47-0	PHOTO	SMOKE	BSMT EAST HALL SECURITY ROOM	
M1-48-0	PHOTO	SMOKE	BAST EAST HALL BAR STORAGE RM. 088	
M1-49-0	IPHOTO	SMOKE	BAST EAST HALL MECHANICAL RM. 085	
M1-51-0	PHOTO	DUCT	BAST EAST WING COMM. ROOM E-069	
M1-52-0	RIAM	RELAY	BAST EAST HALL A.H.U.#14-01 SHUT-DOWN	
M1-53-0	PHOTO	DUCT	BAST EAST HALL MECH RM. A.H.U.#14-01	
M1-55-0	PHOTO	SMOKE	BASEMENT EAST ELEVATOR MACHINE ROOM	
M1-56-0	RIAM	RELAY	BAS'T EAST DOOR STRIKE/HOLDER LOCK	
M1-57-0	RIAM	RELAY	BAST EAST HALL A.H.U.#14-02 SHUT-DOWN	
M1-58-0	PHOTO	DUCT	BAST EAST HALL MECH RM. A.H.U.#14-02	
M1-60-0	RIAM	RELAY	ELEV#1 SHAFT FIRE	
M1-61-0	RIAM	RELAY	EAST ELEVATOR #1 RECALL	
M1-63-0	CANPUL	S2STAGE	BASEMENT EAST WING AT EAST EXIT ESCALIER	
M1-64-0	CANPUL	S2STAGE	BASEMENT EAST WING AT STAIR "A" ESCALIER	
M1-65-0	CANPUL	S2STAGE	BASEMENT EAST WING AT STAIR "B" ESCALIER	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 2 Slot : No Space

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00000010

Name	Device Type	Point Type	Custom Label	PNIS code
M1-66-0	IAM	LATSUPV	BAST EAST WING N/E STANDPIPE VALVE CLOSE	
M1-67-0	IAM	LATSUPV	BAST EAST WING S/E STANDPIPE VALVE CLOSE	
M1-68-0	IAM	LATSUPV	BAST EAST SPRINKLER VALVE CLOSED	
M1-69-0	IAM	WATER	BAST EAST & LANTERN SPRINKLER FLOW	
M1-70-0	HEAT	HEAT	BAST EAST HALL KITCHEN AT FRIDGE	
M1-71-0	HEAT	HEAT	BAST EAST HALL KITCHEN AT FREEZER	
M1-72-0	PHOTO	SMOKE	TOP OF EAST ELEVATOR SHAFT #1	
M1-73-0	PHOTO	SMOKE	EAST ELEVATOR PIT #1	
M1-75-0	IDNETISO	ISO	BAST EAST WING FOR EAST EXIT PULL	
M1-76-0	IDNETISO	ISO	BAST EAST WING FOR N/E TURRET	
M1-77-0	IAM	FIRE	BAST EAST HALL KITCHEN SUPPRESSION SYS.	
M1-78-0	IDNETISO	ISO	BAST EAST WING FOR S/E TURRET	
M1-79-0	CANPUL	S2STAGE	EAST EXIT VESTIBULE AREA	
M1-80-0	IDNETISO	ISO	BASEMENT EAST ELEV RM FOR ELEV#1 SHAFT	
M1-81-0	IDNETISO	ISO	BASEMENT EAST ELEV RM FOR ELEV#1 SHAFT	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 15

Slot : Block C

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00001111

Name	Device Type	Point Type	Custom Label	PNIS code
M2-20-0	PHOTO	SMOKE	SUB-BASEMENT APSE, STORAGE RM 001 S/E	
M2-21-0	PHOTO	SMOKE	SUB-BASEMENT APSE, PLANS/SPEC RM 005	
M2-22-0	PHOTO	SMOKE	SUB-BAS'T APSE, FACILITIES OPER. RM 009	
M2-23-0	PHOTO	SMOKE	SUB-BAS'T APSE, FACILITIES WORKSHOP 006	
M2-24-0	PHOTO	SMOKE	SUB-BASEMENT APSE, STORAGE RM 001 N/E	
M2-25-0	PHOTO	SMOKE	SUB-BASEMENT APSE, STORAGE RM 001 CENTER	
M2-26-0	PHOTO	SMOKE	SUB-BASEMENT APSE, STORAGE AREA HALL 001	
M2-27-0	PHOTO	SMOKE	SUB-BASEMENT APSE, FAC. OPER. OWS RM 010	
M2-28-0	PHOTO	SMOKE	SUB-BASEMENT APSE, WASHROOM	
M2-29-0	PHOTO	SMOKE	SUB-BASEMENT APSE, OFFICE RM 004	
M2-30-0	PHOTO	SMOKE	SUB-BASEMENT APSE, HALL AT STAIR "F"	
M2-31-0	PHOTO	SMOKE	SUB-BASEMENT APSE, ELEVATOR #3 LOBBY	
M2-32-0	IPHOTO	SMOKE	SUB-BASEMENT ATRIUM-SALON STORAGE RM 032	
M2-33-0	IPHOTO	SMOKE	SUB-BASEMENT ATRIUM, STORAGE RM D011	
M2-34-0	PHOTO	SMOKE	SUB-BASEMENT ATRIUM, CENTER CORRIDOR	
M2-41-0	PHOTO	SMOKE	SUB-BASEMENT APSE, ELEV#3 MACHINE RM 002	
M2-42-0	CANPUL	S2STAGE	SUB-BASEMENT APSE, AT STAIR "E"	
M2-43-0	CANPUL	S2STAGE	SUB-BASEMENT APSE, AT STAIR "F"	
M2-47-0	IDNETISO	ISO	SUB-BASEMENT APSE, RM 004 FOR BASEMENT	
M2-49-0	PHOTO	SMOKE	SUB-BASEMENT APSE, ELEV PIT #3	
M2-50-0	PHOTO	SMOKE	SUB-BASEMENT APSE, TOP OF ELEV SHAFT #3	
M2-52-0	IAM	LATSUPV	SUB-BASEMENT APSE, STAIR "F" FHC VALVE	
M2-53-0	IAM	WATER	SUB-BAS'T APSE, ELEV. PIT #3 SPRINK FLOW	
M2-54-0	IAM	LATSUPV	SUB-BAS'T APSE, ELEV. PIT#3 SPRINK VALVE	
M2-55-0	IDNETISO	ISO	SUB-BASEMENT APSE, FOR ELEV#3 SHAFT	
M2-56-0	IDNETISO	ISO	SUB-BASEMENT APSE, FROM ELEV#3 SHAFT	
M2-57-0	RIAM	RELAY	SUB-BASEMENT APSE, ELEV#3 RECALL	
M2-58-0	RIAM	RELAY	SUB-BASEMENT APSE, ELEV#3 SHAFT FIRE	
M2-79-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE, EAST AREA	
M2-80-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE, CENTER AREA	
M2-81-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE, WEST AREA	
M2-82-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE EAST VESTIBULE	
M2-83-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE PROJECTION RM 08	
M2-84-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE INFO KIOSK	
M2-85-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE WEST VESTIBULE	
M2-86-0	IPHOTO	SMOKE	BASEMENT APSE CORRIDOR EAST AT STAIR "E"	
M2-87-0	IPHOTO	SMOKE	BASEMENT APSE CORRIDOR WEST AT STAIR "F"	
M2-88-0	PHOTO	SMOKE	BASEMENT ATRIUM, EAST LOBBY AT STAIR "8"	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 15

Slot : Block C

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00001111

Name	Device Type	Point Type	Custom Label	PNIS code
M2-89-0	PHOTO	SMOKE	BASEMENT ATRIUM, WEST LOBBY AT STAIR "8"	
M2-90-0	PHOTO	SMOKE	BASEMENT ATRIUM-CENTER LOBBY AT STAIR 8	
M2-91-0	PHOTO	SMOKE	BASEMENT ATRIUM, MEN'S WASHROOM	
M2-92-0	PHOTO	SMOKE	BASEMENT ATRIUM, FAMILY WASHROOM	
M2-93-0	PHOTO	SMOKE	BASEMENT ATRIUM, FAMILY WASHROOM	
M2-94-0	PHOTO	SMOKE	BASEMENT ATRIUM, WOMEN'S WASHROOM	
M2-95-0	CANPUL	S2STAGE	BASEMENT APSE, AT STAIR "E"	
M2-96-0	CANPUL	S2STAGE	BASEMENT APSE, AT STAIR "F"	
M2-97-0	PHOTO	SMOKE	BASEMENT APSE, THEATRE LOBBY WEST	
M2-98-0	PHOTO	SMOKE	BASEMENT APSE, THEATRE LOBBY EAST	
M2-102-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE BEHIND SCREEN	
M2-103-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE, EAST AREA	
M2-104-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE, CENTER AREA	
M2-105-0	PHOTO	SMOKE	BASEMENT H.D. THEATRE, WEST AREA	
M2-111-0	CANPUL	S2STAGE	GRD FL APSE STAIR "6" EAST VESTIBULE	
M2-112-0	CANPUL	S2STAGE	GRD FL APSE STAIR "6" WEST VESTIBULE	
M2-114-0	RIAM	RELAY	BASEMENT APSE DOOR RELAY FOR ATRIUM	
M2-115-0	PHOTO	SMOKE	GRD. FL. DISCOVERY CENTER, NORTH AREA	
M2-116-0	PHOTO	SMOKE	GRD. FL DISCOVERY CENTER, EAST VESTIBULE	
M2-117-0	PHOTO	SMOKE	GRD. FL DISCOVERY CENTER, WEST VESTIBULE	
M2-119-0	IPHOTO	SMOKE	GRD FL APSE, EAST AT STAIR "6"	
M2-120-0	IPHOTO	SMOKE	GRD FL APSE, WEST AT STAIR "6"	
M2-121-0	PHOTO	SMOKE	GRD. FL APSE, WEST IN STAIR "F"	
M2-122-0	PHOTO	SMOKE	GRD FL ATRIUM, EAST VESTIBULE AT STAIR 8	
M2-123-0	PHOTO	SMOKE	GRD. FL ATRIUM, IN CENTER STAIR "8"	
M2-124-0	PHOTO	SMOKE	GRD FL ATRIUM, WEST VESTIBULE AT STAIR 8	
M2-125-0	PHOTO	SMOKE	STAIR "8" EXIT TO BASEMENT LOBBY	
M2-126-0	PHOTO	SMOKE	GRD FL ATRIUM, EAST CIRCULATION AREA	
M2-127-0	PHOTO	SMOKE	GRD FL ATRIUM, WEST CIRCULATION AREA	
M2-129-0	PHOTO	SMOKE	GRD FL ATRIUM, N/E CIRCULATION AREA	
M2-130-0	PHOTO	SMOKE	GRD FL ATRIUM, N/W CIRCULATION AREA	
M2-131-0	PHOTO	SMOKE	GRD. FL. MAIN ENTRANCE FOYER EAST	
M2-132-0	PHOTO	SMOKE	GRD. FL. MAIN ENTRANCE FOYER WEST	
M2-133-0	PHOTO	SMOKE	GRD. FL. MAIN ENTRANCE VESTIBULE EAST	
M2-134-0	PHOTO	SMOKE	GRD. FL. MAIN ENTRANCE VESTIBULE WEST	
M2-136-0	CANPUL	S2STAGE	GRD. FL. DISCOVERY CENTER EAST LINK EXIT	
M2-137-0	CANPUL	S2STAGE	GRD. FL. DISCOVERY CENTER WEST LINK EXIT	
M2-140-0	CANPUL	S2STAGE	GRD. FL. MAIN ENTRANCE VESTIBULE WEST	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 15

Slot : Block C

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00001111

Name	Device Type	Point Type	Custom Label	PNIS code
M2-141-0	CANPUL	S2STAGE	GRD. FL. MAIN ENTRANCE VESTIBULE CENTER	
M2-142-0	CANPUL	S2STAGE	GRD. FL. MAIN ENTRANCE VESTIBULE EAST	
M2-150-0	PHOTO	SMOKE	GRD. FL DISCOVERY CENTER SOUTH AREA	
M2-151-0	PHOTO	SMOKE	GRD. FL DISCOVERY CENTER EAST AREA	
M2-152-0	PHOTO	SMOKE	GRD. FL DISCOVERY CENTER WEST AREA	
M2-153-0	PHOTO	SMOKE	GRD. FL DISCOVERY CENTER NORTH-EAST AREA	
M2-154-0	IPHOTO	SMOKE	GRD. FL DISCOVERY CENTER NORTH-WEST AREA	
M2-160-0	PHOTO	SMOKE	2ND FL DISCOVERY MEZZANINE SOUTH AREA	
M2-161-0	PHOTO	SMOKE	2ND FL DISCOVERY MEZZANINE S/E AREA	
M2-162-0	PHOTO	SMOKE	2ND FL DISCOVERY MEZZANINE S/W AREA	
M2-163-0	PHOTO	SMOKE	2ND FL DISCOVERY MEZZANINE EAST AREA	
M2-164-0	PHOTO	SMOKE	2ND FL DISCOVERY MEZZANINE WEST AREA	
M2-165-0	PHOTO	SMOKE	2ND FL DISCOVERY MEZZANINE N/E AREA	
M2-166-0	PHOTO	SMOKE	2ND FL DISCOVERY MEZZANINE N/W AREA	
M2-167-0	IPHOTO	SMOKE	2ND FL APSE, EAST TOP OF STAIR "6"	
M2-168-0	PHOTO	SMOKE	2ND FL APSE, WEST TOP OF STAIR "6"	
M2-169-0	PHOTO	SMOKE	2ND FL ATRIUM EAST AT STAIR "8"	
M2-170-0	PHOTO	SMOKE	2ND FL ATRIUM WEST AT STAIR "8"	
M2-171-0	PHOTO	SMOKE	2ND FL ATRIUM EAST CIRCULATION AREA	
M2-172-0	PHOTO	SMOKE	2ND FL ATRIUM WEST CIRCULATION AREA	
M2-173-0	PHOTO	SMOKE	2ND FL ATRIUM N/E CIRCULATION AREA	
M2-174-0	PHOTO	SMOKE	2ND FL ATRIUM N/W CIRCULATION AREA	
M2-175-0	PHOTO	SMOKE	2ND FL LANTERN AREA AT STAIR "L" EAST	
M2-176-0	PHOTO	SMOKE	2ND FL LANTERN AREA AT STAIR "L" WEST	
M2-177-0	PHOTO	SMOKE	2ND FL LANTERN NORTH-EAST AREA	
M2-178-0	PHOTO	SMOKE	2ND FL LANTERN NORTH-WEST AREA	
M2-179-0	CANPUL	S2STAGE	2ND FL DISCOVERY MEZZ EAST AT STAIR "E"	
M2-180-0	CANPUL	S2STAGE	2ND FL DISCOVERY MEZZ WEST AT STAIR "F"	
M2-181-0	IDNETISO	ISO	3RD FL SERVICE MEZZ FOR LOOP 2 RETURN	
M2-187-0	CANPUL	S2STAGE	2ND. FL. APSE, AT STAIR "6" EAST	
M2-188-0	CANPUL	S2STAGE	2ND. FL. APSE, AT STAIR "6" WEST	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 17

Slot : Block E

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010001

Name	Device Type	Point Type	Custom Label	PNIS code
M3-18-0	PHOTO	SMOKE	GRD. FL EAST EXIT VESTIBULE	
M3-19-0	IDNETISO	ISO	GRD. FL AT SERVERY FOR DUMB-WAITER SHAFT	
M3-20-0	PHOTO	SMOKE	GRD. FL SOUTH/EAST IN STAIR "A" ESCALIER	
M3-21-0	IPHOTO	SMOKE	GRD. FL. EAST WING ASSEMBLY AREA	
M3-22-0	IPHOTO	SMOKE	GRD. FL. EAST WING SOUTH LUNCH RM AREA	
M3-23-0	PHOTO	SMOKE	GRD. FL. EAST WING ASSEMBLY AREA	
M3-24-0	PHOTO	SMOKE	GRD. FL. SOUTH/EAST WING WASHROOM	
M3-25-0	IPHOTO	SMOKE	GRD. FL. EAST WING ELECTRICAL ROOM	
M3-26-0	PHOTO	SMOKE	GRD. FL. EAST WING GROUP FOYER AREA	
M3-27-0	PHOTO	SMOKE	GRD. FL. EAST WING ADMISSION AREA	
M3-28-0	RIAM	RELAY	GRD. FL. EAST ELEV LOBBY ELEC STRIKE	
M3-29-0	PHOTO	SMOKE	GRD. FL. EAST WING ASSEMBLY AREA	
M3-30-0	PHOTO	SMOKE	GRD. FL. NORTH/EAST WING WASHROOM	
M3-31-0	PHOTO	SMOKE	GRD. FL. EAST WING COMMUNICATION ROOM	
M3-32-0	IPHOTO	SMOKE	GRD. FL. EAST WING ASSEMBLY AREA	
M3-33-0	PHOTO	SMOKE	GRD. FL NORTH/EAST IN STAIR "B" ESCALIER	
M3-34-0	IPHOTO	SMOKE	GRD. FL. EAST WING NORTH LUNCH RM AREA	
M3-35-0	PHOTO	SMOKE	GRD. FL. EAST HALL NURSING AREA	
M3-36-0	PHOTO	SMOKE	GRD. FL. EAST HALL BOUTIQUE	
M3-37-0	PHOTO	SMOKE	GRD. FL. EAST HALL BOUTIQUE	
M3-38-0	PHOTO	SMOKE	GRD. FL. EAST HALL BOUTIQUE	
M3-39-0	CANPUL	S2STAGE	GRD. FL. EAST WING AT STAIR "A" ESCALIER	
M3-40-0	CANPUL	S2STAGE	GRD. FL. EAST WING EAST MAIN EXIT	
M3-41-0	CANPUL	S2STAGE	GRD. FL. EAST WING AT STAIR "B" ESCALIER	
M3-43-0	IAM	LATSUPV	GRD. FL. EAST SPRINKLER VALVE CLOSED	
M3-44-0	IAM	WATER	GRD. FL. EAST SPRINKLER FLOW	
M3-45-0	IOHEAT	HEAT	GRD. FL. EAST HALL SERVERY AREA	
M3-46-0	OHEAT	HEAT	GRD. FL. EAST HALL TOP OF DUMB-WAITER	
M3-47-0	IPHOTO	SMOKE	GRD. FL. SOUTH/EAST WING DISPLAY MEZZ.	
M3-48-0	PHOTO	SMOKE	GRD. FL. NORTH/EAST WING DISPLAY MEZZ.	
M3-49-0	RIAM	RELAY	GRD. FL. EAST HALL "WON" DOOR RELEASE	
M3-50-0	PHOTO	SMOKE	GRD. FL. EAST HALL BOUTIQUE OFFICE MEZZ.	
M3-51-0	PHOTO	SMOKE	GRD. FL. EAST HALL AT ELEVATOR VESTIBULE	
M3-52-0	CANPUL	S2STAGE	GRD. FL. EAST HALL EXIT TO STAIRWELL "E"	
M3-53-0	CANPUL	S2STAGE	GRD. FL. EAST HALL AT SOUTH EXIT	
M3-59-0	RIAM	RELAY	2ND. FL. EAST ELEV LOBBY ELEC STRIKE	
M3-60-0	IPHOTO	SMOKE	2ND. FL. EAST WING ELECTRICAL ROOM	
M3-61-0	PHOTO	SMOKE	2ND. FL. EAST WING COMMUNICATIONS ROOM	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 17

Slot : Block E

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010001

Name	Device Type	Point Type	Custom Label	PNIS code
M3-62-0	PHOTO	SMOKE	2ND. FL. EAST HALL-NORTH MECH. SHAFT	
M3-63-0	PHOTO	SMOKE	2ND. FL. EAST HALL-SOUTH MECH. SHAFT	
M3-66-0	CANPUL	S2STAGE	2ND. FL. EAST WING AT STAIR "A" ESCALIER	
M3-67-0	CANPUL	S2STAGE	2ND. FL. EAST WING AT STAIR "B" ESCALIER	
M3-69-0	IAM	LATSUPV	2ND. FL. EAST SPRINKLER VALVE CLOSED	
M3-70-0	IAM	WATER	2ND. FL. EAST SPRINKLER FLOW	
M3-71-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-72-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-73-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-74-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-75-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-76-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-77-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-78-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-79-0	IPHOTO	SMOKE	2ND. FL. EAST WING	
M3-80-0	PHOTO	SMOKE	2ND. FL. EAST WING	
M3-81-0	PHOTO	SMOKE	2ND. FL. EAST HALL	
M3-82-0	PHOTO	SMOKE	2ND. FL. EAST HALL	
M3-83-0	PHOTO	SMOKE	2ND. FL. EAST HALL	
M3-84-0	IPHOTO	SMOKE	2ND. FL. EAST HALL	
M3-85-0	PHOTO	SMOKE	2ND. FL. EAST HALL	
M3-86-0	PHOTO	SMOKE	2ND. FL. EAST HALL	
M3-87-0	IPHOTO	SMOKE	2ND. FL. EAST HALL	
M3-88-0	PHOTO	SMOKE	2ND. FL. EAST HALL	
M3-89-0	RIAM	RELAY	2ND. FL. EAST HALL "WON" DOOR RELEASE	
M3-90-0	PHOTO	SMOKE	2ND. FL. EAST HALL FAMILY WASHROOM	
M3-91-0	PHOTO	SMOKE	2ND. FL. EAST HALL MEN'S WASHROOM	
M3-92-0	PHOTO	SMOKE	2ND. FL. EAST HALL MEZZ. ELECTRICAL ROOM	
M3-93-0	PHOTO	SMOKE	2ND. FL. EAST HALL MEZZANINE	
M3-94-0	CANPUL	S2STAGE	2ND. FL. EAST HALL EXIT TO STAIRWELL "E"	
M3-95-0	PHOTO	SMOKE	2ND. FL. EAST HALL AT ELEVATOR VESTIBULE	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 18

Slot : Block D

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010010

Name	Device Type	Point Type	Custom Label	PNIS code
M4-20-0	PHOTO	SMOKE	3RD. FL SOUTH/EAST IN STAIR "A" ESCALIER	
M4-21-0	IPHOTO	SMOKE	3RD. FL. EAST WING ELECTRICAL ROOM	
M4-22-0	PHOTO	SMOKE	3RD. FL. EAST WING COMMUNICATION ROOM	
M4-23-0	PHOTO	SMOKE	3RD. FL NORTH/EAST IN STAIR "B" ESCALIER	
M4-24-0	IDNETISO	ISO	3RD FL NORTH/EAST CEILING FOR TURRET "B"	
M4-25-0	IDNETISO	ISO	3RD FL SOUTH/EAST CEILING FOR TURRET "A"	
M4-26-0	CANPUL	S2STAGE	3RD. FL SOUTH/EAST AT STAIR "A" ESCALIER	
M4-27-0	CANPUL	S2STAGE	3RD. FL NORTH/EAST AT STAIR "B" ESCALIER	
M4-29-0	IAM	LATSUPV	3RD. FL. EAST SPRINKLER VALVE CLOSED	
M4-30-0	IAM	WATER	3RD. FL. EAST SPRINKLER FLOW	
M4-40-0	IPHOTO	SMOKE	4TH. FL. EAST WING ELECTRICAL ROOM	
M4-41-0	PHOTO	SMOKE	4TH. FL. EAST WING COMMUNICATION ROOM	
M4-44-0	CANPUL	S2STAGE	4TH. FL SOUTH/EAST AT STAIR "A" ESCALIER	
M4-45-0	CANPUL	S2STAGE	4TH. FL NORTH/EAST AT STAIR "B" ESCALIER	
M4-47-0	IAM	LATSUPV	4TH. FL. EAST SPRINKLER VALVE CLOSED	
M4-48-0	IAM	WATER	4TH. FL. EAST SPRINKLER FLOW	
M4-56-0	IAM	WATER	APSE ATTIC-LANTERN/BUTTERFLY STAIR SPRNK	
M4-57-0	IAM	LATSUPV	APSE ATTIC-LANTERN/BUTTERFLY STAIR VALVE	
M4-58-0	IAM	WATER	APSE ATTIC/APSE PENT/EAST PENT SPRINKLER	
M4-59-0	IAM	LATSUPV	APSE ATTIC/APSE PENT/EAST PENT VALVE	
M4-60-0	PHOTO	SMOKE	EAST PENTHOUSE ELEVATOR VESTIBULE	
M4-61-0	IAM	LATSUPV	EAST PENTHOUSE SPRINK VALVE #1 CLOSED	
M4-62-0	IAM	LATSUPV	EAST PENTHOUSE SPRINK VALVE #2 CLOSED	
M4-63-0	IAM	WATER	EAST ROOF TURRET GLYCOL SPRINKLER FLOW	
M4-64-0	CANPUL	S2STAGE	EAST PENTHOUSE EAST EXIT AT LADDER	
M4-65-0	RIAM	RELAY	EAST PENT. ELEV. #1 PRESSURIZATION FAN	
M4-66-0	IAM	LATSUPV	EAST PENT SPRINK GLYCOL VALVE #1 CLOSED	
M4-67-0	IAM	WATER	EAST PENTHOUSE SPRINKLER GLYCOL FLOW	
M4-68-0	IAM	LATSUPV	EAST PENT SPRINK GLYCOL VALVE #2 CLOSED	
M4-69-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U.#26-01 SUPPLY	
M4-70-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U.#25-01 SUPPLY	
M4-71-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U.#26-02 RETURN	
M4-72-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U.#17-01 SUPPLY	
M4-73-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U.#16-01 SUPPLY	
M4-74-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U.#17-02 RETURN	
M4-75-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #23-01 SUPPLY	
M4-76-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #24-01 SUPPLY	
M4-77-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #18-02 RETURN	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 18

Slot : Block D

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010010

Name	Device Type	Point Type	Custom Label	PNIS code
M4-78-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #18-01 SUPPLY	
M4-79-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #22-01 SUPPLY	
M4-80-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #21-01 SUPPLY	
M4-81-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #19-02 RETURN	
M4-82-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #20-01 SUPPLY	
M4-83-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U. #19-01 SUPPLY	
M4-84-0	PHOTO	DUCT	EAST PENTHOUSE A.H.U.#16-02 RETURN	
M4-85-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#26-01 SHUT-DOWN	
M4-86-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#25-01 SHUT-DOWN	
M4-87-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#26-02 SHUT-DOWN	
M4-88-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#17-01 SHUT-DOWN	
M4-89-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#16-01 SHUT-DOWN	
M4-90-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#17-02 SHUT-DOWN	
M4-91-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#23-01 SHUT-DOWN	
M4-92-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#24-01 SHUT-DOWN	
M4-93-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#18-01 SHUT-DOWN	
M4-94-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#18-02 SHUT-DOWN	
M4-95-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#16-02 SHUT-DOWN	
M4-96-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#22-01 SHUT-DOWN	
M4-97-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#21-01 SHUT-DOWN	
M4-98-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#19-02 SHUT-DOWN	
M4-99-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#19-01 SHUT-DOWN	
M4-100-0	RIAM	RELAY	EAST PENTHOUSE A.H.U.#20-01 SHUT-DOWN	
M4-101-0	PHOTO	SMOKE	TOP OF SOUTH/EAST TURRET STAIR "A"	
M4-102-0	PHOTO	SMOKE	TOP OF NORTH/EAST TURRET STAIR "B"	
M4-103-0	IDNETISO	ISO	EAST PENTHOUSE-EAST END	
M4-104-0	IDNETISO	ISO	EAST PENTHOUSE-WEST END	
M4-105-0	PHOTO	SMOKE	EAST PENTHOUSE-EAST END	
M4-106-0	PHOTO	SMOKE	EAST PENTHOUSE-EAST END-CENTER	
M4-107-0	PHOTO	SMOKE	EAST PENTHOUSE-WEST END-CENTER	
M4-108-0	PHOTO	SMOKE	EAST PENTHOUSE-WEST END	
M4-109-0	CANPUL	S2STAGE	EAST PENTHOUSE EXIT TO STAIR "E"	
M4-110-0	PHOTO	SMOKE	3RD. FL. EAST WING	
M4-111-0	IPHOTO	SMOKE	3RD. FL. EAST WING	
M4-112-0	PHOTO	SMOKE	3RD. FL. EAST WING	
M4-113-0	PHOTO	SMOKE	3RD. FL. EAST WING	
M4-114-0	PHOTO	SMOKE	3RD. FL. EAST WING	
M4-115-0	PHOTO	SMOKE	3RD. FL. EAST WING	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 18

Slot : Block D

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010010

Name	Device Type	Point Type	Custom Label	PNIS code
M4-116-0	PHOTO	SMOKE	3RD. FL. EAST WING	
M4-117-0	PHOTO	SMOKE	3RD. FL. EAST WING	
M4-118-0	PHOTO	SMOKE	3RD. FL. EAST WING	
M4-119-0	IPHOTO	SMOKE	3RD. FL. EAST WING	
M4-120-0	IPHOTO	SMOKE	3RD. FL. EAST HALL	
M4-121-0	PHOTO	SMOKE	3RD. FL. EAST HALL	
M4-122-0	PHOTO	SMOKE	3RD. FL. EAST HALL	
M4-123-0	PHOTO	SMOKE	3RD. FL. EAST HALL	
M4-124-0	PHOTO	SMOKE	3RD. FL. EAST HALL	
M4-125-0	PHOTO	SMOKE	3RD. FL. EAST HALL	
M4-126-0	PHOTO	SMOKE	3RD. FL. EAST HALL	
M4-127-0	IPHOTO	SMOKE	3RD. FL. EAST HALL	
M4-128-0	RIAM	RELAY	3RD. FL. EAST HALL "WON" DOOR RELEASE	
M4-129-0	PHOTO	SMOKE	3RD. FL. EAST HALL AT ELEVATOR VESTIBULE	
M4-130-0	PHOTO	SMOKE	3RD. FL. EAST HALL FAMILY WASHROOM	
M4-131-0	CANPUL	S2STAGE	3RD. FL. EAST HALL EXIT TO STAIR "E"	
M4-132-0	PHOTO	SMOKE	3RD. FL. EAST HALL MEN'S WASHROOM	
M4-133-0	PHOTO	SMOKE	3RD. FL. EAST HALL SERVICE MEZZ. ELEC. RM	
M4-134-0	PHOTO	SMOKE	3RD. FL. EAST HALL SERVICE MEZZANINE	
M4-135-0	RIAM	RELAY	3RD. FL. EAST ELEV LOBBY ELEC STRIKE	
M4-140-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-141-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-142-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-143-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-144-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-145-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-146-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-147-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-148-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-149-0	PHOTO	SMOKE	4TH. FL. EAST WING	
M4-150-0	PHOTO	SMOKE	4TH. FL. EAST HALL	
M4-151-0	PHOTO	SMOKE	4TH. FL. EAST HALL	
M4-152-0	PHOTO	SMOKE	4TH. FL. EAST HALL	
M4-153-0	PHOTO	SMOKE	4TH. FL. EAST HALL	
M4-154-0	PHOTO	SMOKE	4TH. FL. EAST HALL	
M4-155-0	PHOTO	SMOKE	4TH. FL. EAST HALL	
M4-156-0	PHOTO	SMOKE	4TH. FL. EAST HALL	
M4-157-0	IPHOTO	SMOKE	4TH. FL. EAST HALL	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 18

Slot : Block D

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010010

Name	Device Type	Point Type	Custom Label	PNIS code
M4-158-0	PHOTO	SMOKE	4TH. FL. EAST HALL AT ELEVATOR VESTIBULE	
M4-159-0	PHOTO	SMOKE	4TH. FL. EAST HALL MEN'S WASHROOM	
M4-160-0	PHOTO	SMOKE	4TH. FL. EAST HALL FAMILY WASHROOM	
M4-161-0	CANPUL	S2STAGE	4TH. FL. EAST HALL EXIT TO STAIR "E"	
M4-162-0	PHOTO	SMOKE	4TH. FL. EAST HALL SERVICE MEZZANINE	
M4-163-0	PHOTO	SMOKE	4TH. FL. EAST HALL SERVICE MEZZ. ELEC. RM	
M4-164-0	RIAM	RELAY	4TH. FL. EAST HALL "WON" DOOR RELEASE	
M4-165-0	IDNETISO	ISO	4TH. FL. EAST FOR S/E TURRET STAIR "A"	
M4-166-0	IDNETISO	ISO	4TH. FL. EAST FOR S/E TURRET STAIR "A"	
M4-167-0	IDNETISO	ISO	4TH. FL. EAST FOR N/E TURRET STAIR "B"	
M4-168-0	IDNETISO	ISO	4TH. FL. EAST FOR N/E TURRET STAIR "B"	
M4-169-0	IDNETISO	ISO	4TH. FL. EAST HALL FOR PENTHOUSE LOOP	
M4-170-0	IDNETISO	ISO	4TH. FL. EAST HALL FOR PENTHOUSE LOOP	
M4-171-0	RIAM	RELAY	SOUTH-EAST TURRET FAN #37 SHUT-DOWN	
M4-172-0	RIAM	RELAY	NORTH-EAST TURRET FAN #38 SHUT-DOWN	
M4-173-0	RIAM	RELAY	4TH. FL. EAST ELEV LOBBY ELEC STRIKE	
M4-174-0	IDNETISO	ISO	SOUTH-EAST TURRET FOR STAIRWELL SMOKE	
M4-175-0	PHOTO	SMOKE	SOUTH-EAST TURRET MECHANICAL AREA	
M4-176-0	CANPUL	S2STAGE	SOUTH-EAST TURRET MECHANICAL AREA	
M4-177-0	PHOTO	DUCT	SOUTH-EAST TURRET FAN #37	
M4-178-0	PHOTO	SMOKE	NORTH-EAST TURRET MECHANICAL AREA	
M4-179-0	CANPUL	S2STAGE	NORTH-EAST TURRET MECHANICAL AREA	
M4-180-0	PHOTO	DUCT	NORTH-EAST TURRET FAN #38	
M4-181-0	IDNETISO	ISO	NORTH-EAST TURRET FOR STAIRWELL SMOKE	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 19

Slot : Block F

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010011

Name	Device Type	Point Type	Custom Label	PNIS code
M5-1-0	IAM	LATSUPV	SUB-BASEMENT APSE, STAIR"E"SPRINK. VALVE	
M5-2-0	IAM	WATER	BASEMENT APSE, H.D. THEATRE SPRINK. FLOW	
M5-3-0	IAM	LATSUPV	BASEMENT APSE, H.D. THEATRE SPRINK VALVE	
M5-4-0	IAM	WATER	BAS'T APSE H.D. THEATRE WINDOW SPRINKLER	
M5-5-0	IAM	LATSUPV	BAS'T APSE, THEATER WINDOW SPRINK. VALVE	
M5-6-0	IAM	WATER	GRD FL DISCOVERY CENTER/APSE SPRINKLER	
M5-7-0	IAM	LATSUPV	GRD FL DISCOVERY CENTER SPRINKLER VALVE	
M5-8-0	IAM	WATER	GRD FL APSE WINDOW SPRINKLER FLOW	
M5-9-0	IAM	LATSUPV	GRD FL APSE WINDOW SPRINKLER VALVE CLOSE	
M5-10-0	IAM	WATER	GRD FL ATRIUM/FOYER SPRINKLER FLOW	
M5-11-0	IAM	LATSUPV	GRD FL ATRIUM SPRINKLER VALVE CLOSED	
M5-12-0	PHOTO	SMOKE	GRD FL APSE EAST IN STAIR "E"	
M5-13-0	IAM	WATER	2ND FL ATRIUM SPRINKLER FLOW	
M5-14-0	IAM	LATSUPV	2ND FL ATRIUM SPRINKLER VALVE CLOSED	
M5-15-0	IAM	WATER	2ND FL DISCOVERY CENTER/APSE SPRINKLER	
M5-16-0	IAM	LATSUPV	2ND FL APSE SPRINKLER VALVE CLOSED	
M5-17-0	IAM	WATER	2ND FL APSE WINDOW SPRINKLER FLOW	
M5-18-0	IAM	LATSUPV	2ND FL APSE WINDOW SPRINKLER VALVE CLOSE	
M5-19-0	IAM	FIRE	3RD FL APSE, SALON KITCHEN FIRE SYSTEM	
M5-20-0	PHOTO	SMOKE	3RD FL APSE, EAST SALON ENTRANCE	
M5-21-0	PHOTO	SMOKE	3RD FL APSE, WEST SALON ENTRANCE	
M5-22-0	PHOTO	SMOKE	3RD FL APSE, IN EAST STAIR "E"	
M5-23-0	IPHOTO	SMOKE	3RD FL APSE, EAST SALON VESTIBULE	
M5-24-0	PHOTO	SMOKE	3RD FL APSE, EAST SALON WASHROOM	
M5-25-0	PHOTO	SMOKE	3RD FL APSE, WEST SALON WASHROOM	
M5-26-0	IPHOTO	SMOKE	3RD FL APSE, WEST SALON VESTIBULE	
M5-27-0	PHOTO	SMOKE	3RD FL APSE, IN WEST STAIR "F"	
M5-28-0	PHOTO	SMOKE	3RD FL ATRIUM, S/E CIRCULATION AREA	
M5-29-0	PHOTO	SMOKE	3RD FL ATRIUM, S/W CIRCULATION AREA	
M5-30-0	PHOTO	SMOKE	3RD FL ATRIUM, EAST CIRCULATION AREA	
M5-31-0	PHOTO	SMOKE	3RD FL ATRIUM, WEST CIRCULATION AREA	
M5-32-0	PHOTO	SMOKE	3RD FL ATRIUM, N/E CIRCULATION AREA	
M5-33-0	PHOTO	SMOKE	3RD FL ATRIUM, N/W CIRCULATION AREA	
M5-34-0	IDNETISO	ISO	SUB-BAS'T STAIR "E" FOR LOOP 5	
M5-35-0	RIAM	RELAY	3RD FL SERVERY -SALON ELEC STRIKES SPARE	
M5-38-0	CANPUL	S2STAGE	3RD FL APSE, AT EAST STAIR "E"	
M5-39-0	CANPUL	S2STAGE	3RD FL APSE, AT WEST STAIR "F"	
M5-40-0	IAM	WATER	3RD FL APSE/SKYLIGHT SPRINKLER FLOW	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 19

Slot : Block F

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010011

Name	Device Type	Point Type	Custom Label	PNIS code
M5-41-0	IAM	LATSUPV	3RD FL APSE SPRINKLER VALVE CLOSED	
M5-42-0	IAM	WATER	3RD FL ATRIUM SPRINKLER FLOW	
M5-43-0	IAM	LATSUPV	3RD FL ATRIUM SPRINKLER VALVE CLOSED	
M5-53-0	HEAT	HEAT	3RD FL APSE, SERVERY AREA	
M5-60-0	PHOTO	SMOKE	3RD FL SALON, HIGH CEILING SOUTH	
M5-61-0	PHOTO	SMOKE	3RD FL SALON, HIGH CEILING SOUTH/EAST	
M5-62-0	PHOTO	SMOKE	3RD FL SALON, HIGH CEILING SOUTH/WEST	
M5-63-0	PHOTO	SMOKE	3RD FL SALON, HIGH CEILING CENTER	
M5-64-0	PHOTO	SMOKE	3RD FL SALON, HIGH CEILING NORTH/EAST	
M5-65-0	PHOTO	SMOKE	3RD FL SALON, HIGH CEILING NORTH/WEST	
M5-66-0	IPHOTO	SMOKE	4TH FL APSE, EAST BOARD-ROOM ALCOVE	
M5-67-0	PHOTO	SMOKE	4TH FL APSE, BOARD-ROOM	
M5-68-0	PHOTO	SMOKE	4TH FL APSE, WEST PROJECTION ROOM	
M5-75-0	IAM	WATER	4TH FL APSE BOARDROOM SPRINKLER FLOW	
M5-76-0	IAM	LATSUPV	4TH FL APSE SPRINKLER VALVE CLOSED	
M5-79-0	CANPUL	S2STAGE	4TH FL APSE, AT EAST STAIR "E"	
M5-80-0	CANPUL	S2STAGE	4TH FL APSE, AT EAST STAIR "F"	
M5-97-0	RIAM	RELAY	APSE ATTIC, WRE-FAN07 FAN SHUTDOWN	
M5-98-0	RIAM	RELAY	APSE ATTIC, CRE-01 FAN SHUTDOWN	
M5-100-0	PHOTO	SMOKE	APSE ATTIC, SOUTH/EAST AREA	
M5-101-0	PHOTO	SMOKE	APSE ATTIC, SOUTH/WEST AREA	
M5-102-0	PHOTO	SMOKE	APSE ATTIC, CENTER AREA	
M5-103-0	PHOTO	SMOKE	APSE ATTIC, EAST AREA	
M5-104-0	PHOTO	SMOKE	APSE ATTIC, WEST AREA	
M5-105-0	PHOTO	SMOKE	APSE ATTIC,NORTH/EAST AREA	
M5-106-0	PHOTO	SMOKE	APSE ATTIC, NORTH/WEST AREA	
M5-107-0	CANPUL	S2STAGE	APSE ATTIC, AT STAIR "E"	
M5-108-0	CANPUL	S2STAGE	APSE ATTIC, AT STAIR "F"	
M5-109-0	IPHOTO	SMOKE	APSE ATTIC, TOP OF STAIR "F"	
M5-110-0	IPHOTO	SMOKE	APSE ATTIC, TOP OF STAIR "E"	
M5-112-0	IDNETISO	ISO	PENTHOUSE APSE SOUTH STAIR FOR PENT.	
M5-113-0	IDNETISO	ISO	PENTHOUSE APSE WEST FOR PENTHOUSE	
M5-114-0	IAM	FIRE	ATRIUM BEAM DETECTORS	
M5-115-0	PHOTO	SMOKE	PENTHOUSE APSE, TOP OF SOUTH STAIR	
M5-116-0	CANPUL	S2STAGE	PENTHOUSE APSE, AT SOUTH STAIRWELL	
M5-117-0	PHOTO	SMOKE	PENTHOUSE APSE, EAST AREA	
M5-118-0	PHOTO	SMOKE	PENTHOUSE APSE, WEST AREA	
M5-119-0	PHOTO	SMOKE	PENTHOUSE APSE, STAIR LINK TO ATRIUM	

Job Description : VIC MUSEUM EAST 5

Wednesday, February 04, 2015 - 7:28 AM

Card Detail

Card No: 19

Slot : Block F

Unit : 0

(4100-3101) - IDNET 250 Points

Only activate TrueAlarm device LEDs: Disabled

Activate Signal IAM LEDs: Disabled

Addr 00010011

Name	Device Type	Point Type	Custom Label	PNIS code
M5-120-0	RPHOTO	SMOKE	4TH FLR NORTH HIGH LANTERN CEILING EAST	
M5-121-0	RPHOTO	SMOKE	4TH FLR NORTH, HIGH LANTERN CEILING WEST	
M5-122-0	RIAM	DRESET	APSE ATTIC ATRIUM BEAM SMOKE 24VDC RESET	
M5-124-0	PHOTO	SMOKE	PENTHOUSE APSE, LANTERN CATWALK SOUTH	
M5-125-0	PHOTO	SMOKE	PENTHOUSE APSE, LANTERN CATWALK NORTH	
M5-126-0	PHOTO	SMOKE	PENTHOUSE ATRIUM SKYLIGHT EAST	
M5-127-0	PHOTO	SMOKE	PENTHOUSE ATRIUM SKYLIGHT WEST	
M5-128-0	PHOTO	SMOKE	PENTHOUSE ATRIUM SKYLIGHT SOUTH	
M5-129-0	PHOTO	SMOKE	PENTHOUSE ATRIUM SKYLIGHT NORTH	
M5-130-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 12-01 SUPPLY	
M5-131-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 15-01 SUPPLY	
M5-132-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 15-02 RETURN	
M5-133-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 28-01 SUPPLY	
M5-134-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 28-02 RETURN	
M5-135-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 29-01 SUPPLY	
M5-136-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 29-02 RETURN	
M5-137-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 30-01 SUPPLY	
M5-138-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 12-02 RETURN	
M5-139-0	PHOTO	DUCT	PENTHOUSE APSE, A.H.U.# 30-02 RETURN	
M5-140-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 15-01 SHUT-DOWN	
M5-141-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 15-02 SHUT-DOWN	
M5-142-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 28-01 SHUT-DOWN	
M5-143-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 28-02 SHUT-DOWN	
M5-144-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 29-02 SHUT-DOWN	
M5-145-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 12-01 SHUT-DOWN	
M5-146-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 30-01 SHUT-DOWN	
M5-147-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 30-02 SHUT-DOWN	
M5-148-0	RIAM	RELAY	PENTHOUSE APSE, A.H.U.# 29-01 SHUT-DOWN	
M5-149-0	RIAM	RELAY	APSE ATTIC, FAN-03 FOR STAIR "E" & "F"	
M5-150-0	IDNETISO	ISO	PENTHOUSE APSE, TO LANTERN CATWALK	
M5-151-0	IDNETISO	ISO	PENTHOUSE APSE, FROM LANTERN CATWALK	
M5-152-0	RIAM	RRELAY	PENTHOUSE APSE, ALARM TO B.A.S.	
M5-153-0	IAM	LATSUPV	APSE ATTIC, 4TH FL ATRIUM GLYCOL VALVE#1	
M5-154-0	IAM	WATER	ATRIUM SKYLIGHT/LANTERN GLYCOL SPRINKLER	
M5-155-0	IAM	LATSUPV	APSE ATTIC, 4TH FL ATRIUM GLYCOL VALVE#2	
M5-156-0	RIAM	RELAY	PENTHOUSE APSE BV-FAN 01 S/D FOR SUB-BAS	