

Solicitation No. - N° de l'invitation
EW699-151273/A

Amd. No. - N° de la modif.
008

Buyer ID - Id de l'acheteur
pwz202

Client Ref. No. - N° de réf. du client
PWGSC-EW699-151273

File No. - N° du dossier
PWZ-4-37192

CCC No./N° CCC - FMS No/ N° VME

Public Works and Government Services Canada ☐	Iqaluit, Nunavut Hazardous Material Abatement, DFO Building 1074	Addendum No. 3
Project No.: R.065695.006		March 12, 2015

The following changes to the tender documents are effective immediately and will form part of the contract documents:

ITEM 1.) CLARIFICATIONS: - Questions and Answers

<u>Question No.</u>		<u>Answer No.</u>	
1.	In the Invitation to Tender, it is specified that bids cannot be transmitted by facsimile. Is the transmission by email accepted?	1.	No, electronic transmission of bids is not allowed. Due to the requirement for Bid Security an original sealed bid must be submitted, but it may be amended by fax prior to closing per SC5.
2.	I would like to know if it is an obligation to have a fence around the building concerning the decontamination and demolition.	2.	The Specification is not explicit with respect to the type of fencing or hoarding expected for this project. It is expected that a minimum standard for the Bldg 1074 program would be to include for a temporary fencing system <u>a minimum height of 1 m</u> . The contractor will need to discuss with the City of Iqaluit and conform to their requirements.
3.	Who is responsible for the air monitoring fees inside the work area?	3.	PWGSC will conduct the air monitoring. (see Item 2 below)

ITEM 2.) SPECIFICATIONS SECT 02 82 00.03 3.06 Air Monitoring (pge. 14)

Delete clause 3.06.1.1.

Amend Clause 3.06.1 to state:

From the beginning of Work until completion of cleaning operations, the Departmental Representative is to take required air samples inside and outside the work area enclosure in accordance with applicable Territorial Occupational Health and Safety Regulations and Health Canada requirements.

- end -