

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

Revision to a Request for a Standing Offer

Révision à une demande d'offre à commandes

Regional Individual Standing Offer (RISO)

Offre à commandes individuelle régionale (OCIR)

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Comments - Commentaires

All questions are to be submitted in writing to
Gisele Doucet - Email: gisele.doucet@pwgsc.gc.ca
or Fax no. (506) 636-4376.

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet NB Geotech Drilling/Sampling/Testng	
Solicitation No. - N° de l'invitation EC373-152028/A	Date 2015-03-16
Client Reference No. - N° de référence du client EC373-152028	Amendment No. - N° modif. 002
File No. - N° de dossier PWB-4-37159 (004)	CCC No./N° CCC - FMS No./N° VME
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-3577	
Date of Original Request for Standing Offer Date de la demande de l'offre à commandes originale 2015-02-18	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-03-31	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Delivery Required - Livraison exigée	
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	
Security - Sécurité This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre.	

Instructions: See Herein

Instructions: Voir aux présentes

Acknowledgement copy required Accusé de réception requis	Yes - Oui <input type="checkbox"/>	No - Non <input type="checkbox"/>
The Offeror hereby acknowledges this revision to its Offer. Le proposant constate, par la présente, cette révision à son offre.		
Signature	Date	
Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie)		
For the Minister - Pour le Ministre		

This Revision to a Request for a Standing Offer No. Two (2) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum 2.

1. QUESTIONS AND ANSWERS

Q3: In Annex "A" Basis of Payment – Item 2 a) & c) meterage estimate -Are these rates just for Drill rig, barge (If applicable), and cost per foot for drilling? Does this also include Geotechnical supervision?

A3: Yes. As indicated on page 5, section 5.1: Drilling Operations: The Consultant shall submit an hourly rate for the drill crew, supervisory field technician or equivalent and equipment, inclusive of all costs and expenses at which standby time does not exceed ten (10) hours per day, or as otherwise agreed to by PWGSC", this applies to Annex A, 2 a), 2 b), 2 c), 2 d), 2 e) and 4.0 Provisions for Standby Time.

Q4: In Annex "A" Basis of Payment – Item 2 b) Dynamic Cone Penetration Test Estimated 500 @ \$_____/Unit - Is this based on DCPT tests for 500 meters, 500 feet, 500 holes? If 500 holes to what is the depth?

A4: As indicated on Page 2, section 2.4, DCPT tests are limited by the friction created on the cone and rods at depths greater than approximately 10 metres. Therefore, DCPT tests are to be paid by the hole at depths no greater than 10 metres.

Q5: In Annex "A" 2. e) Basis of Payment – Piezometers - Is the intention for Piezometers to be PVC Standpipes, grouted in place and backfilled with silica sand or Vibrating Wire Piezometers?

A5 : Amendment: Annex "A", Section 2e: Piezometres:
50 metres @ \$_____/unit by PVC Standpipes, grouted in place
and backfilled with silica sand
50 metres @ \$_____/unit by Vibrating Wire Piezometers

2. ANNEX "A" - BASIS OF PAYMENT

REMOVE Annex "A" from your Request for a Standing Offer (RFSO) tender document and **REPLACE WITH** the attached revised copy dated 2015-03-12.
Please note revisions made to 2e).

"Revised 2015-03-16"

**ANNEX "A"
BASIS OF PAYMENT**

**GEOTECHNICAL DRILLING/SAMPLING/TESTING
VARIOUS SITES, N.B.**

1. MOBILIZATION AND DEMOBILIZATION:

Mobilization and Demobilization will include:

- .1 Organization and scheduling of work as specified in each call-up.
- .2 Fully equipped Machine Drilling-Rig and or barge, to and from the sites, including personnel, Equipment.
- .3 All necessary expenses, including ferries.
- .4 Set-up and Tear-down from all boreholes, inclusive of borehole location, surveying and field supervision personnel.
- .5 Submittal of a Health and Safety Plan.
- .6 Field supervision personnel.

Locations:

- .1 Equivalent to one mobilization and demobilization as stated above anywhere in the Province of New Brunswick where ferry access isn't required.
- .2 Equivalent to one mobilization and demobilization as stated above to any of the Province of New Brunswick's Islands: where ferry is required.

Mobilization and Demobilization:

- | | | | | | |
|----|-------------|-------|-------|----|-------|
| .1 | 40 units \$ | _____ | /each | \$ | _____ |
| .2 | 40 units \$ | _____ | /each | \$ | _____ |

2. DRILLING:

a) Over Water: (Drilling equipment sitting using floating apparatus)

Meterage: Estimate

- | | | | | | |
|-------------------------------|----|-------|----|----|-------|
| In Overburden: 2,000 meters @ | \$ | _____ | /m | \$ | _____ |
| In Bedrock: 1,000 meters @ | \$ | _____ | /m | \$ | _____ |

b) Dynamic Cone Penetration Test

Estimated 500@ \$ _____ /unit \$ _____

c) Over Ground Surface: (Drilling equipment sitting on land)

"Revised 2015-03-16"

Meterage: Estimate

In Overburden: 1,000 meters @ \$ _____/m \$ _____

In Bedrock: 500 meters @ \$ _____/m \$ _____

d) Thin Wall Sample Tube:

Estimated 200 @ \$ _____/unit \$ _____

e) Piezometres (drilling is paid under drilling, quote will materials only)

50 meters @ \$ _____/unit by PVC Standpipes, grouted in
place and backfilled with silica sand \$ _____

50 meters @ \$ _____/unit by Vibrating Wire Piezometers \$ _____

LABORATORY TESTING: ESTIMATED:

250 Moisture Content @ \$ _____/each \$ _____

250 sieve analysis @ \$ _____/each \$ _____

250 Unconfined bedrock core

Compressive Strength tests @ \$ _____/each \$ _____

3. FACTUAL REPORT

Cost per call-up: 40 unit @ \$ _____/each \$ _____

4. PROVISIONS FOR STANDBY TIME

200 hours @ \$ _____/ Hour \$ _____

5. RECOMMENDATIONS AND REVIEWS

Senior Engineer is responsible for the completion of the report and accurate soil log interpretations. An average of 4 hours per report or one hour per bore hole is expected to be charged for this responsibility. All other time for all personnel is embedded in the bid items.

Senior Engineer 160 hours @ _____/each \$ _____

Senior Technologist 160 hours @ _____/each \$ _____

TOTAL ESTIMATED COST \$ _____ (HST extra)

These items will be used for cost evaluation purposes only and do not constitute a guarantee or commitment on behalf of Canada of the quantity or amount to be used under the Standing Offer.