

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver, BC V6Z 0B9  
Bid Fax: (604) 775-7526

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada -  
Pacific Region  
219 - 800 Burrard Street  
800, rue Burrard, pièce 219  
Vancouver, BC V6Z 0B9

Title - Sujet MOBILE WET LAB TRAILER	
Solicitation No. - N° de l'invitation F1700-140641/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client F1700-140641	Date 2015-03-20
GETS Reference No. - N° de référence de SEAG PW-\$VAN-584-7467	
File No. - N° de dossier VAN-4-37333 (584)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-04-07	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Perez, Elizabeth	Buyer Id - Id de l'acheteur van584
Telephone No. - N° de téléphone (604) 775-7690 ( )	FAX No. - N° de FAX (604) 775-7526
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

F1700-140641/A

Client Ref. No. - N° de réf. du client

F1700-140641

Amd. No. - N° de la modif.

002

File No. - N° du dossier

VAN-4-37333

Buyer ID - Id de l'acheteur

van584

CCC No./N° CCC - FMS No/ N° VME

---

**AMENDMENT 002**

**TITLE: MOBILE WET LAB TRAILER**

**SEE ATTACHED.**

## **AMENDMENT 002**

This amendment is raised to present the following questions from bidders and the responses from the Project Authority.

- **Questions and Answers:**

Q4. Will the walls, floor and roof be insulated, and to what desired value?

**A4. Floors and Roof must be insulated to a minimum of R20.**

Q5. Will the entry door be better on the side of the trailer or the rear? (if side, please specify an approximate placement)?

**A5. The entry door is required at rear of the trailer, on center.**

Q6. Is there going to be propane required on the trailer?

**A6. No, heating is to be electric .**

Q7. Can you tell me what type of "tagging" the trailer will be used for? Beyond the trailer specifications listed are there any additional specifics? ?

**A7. The trailer is to be used for fish tagging and marking of salmonids for stock identification purposes (wet lab environment). No additional equipment is required and there are no additional specifications.**

Q8. There is no mention of any casework in the lab. Is this intended to be an open interior without any benchtop space, cabinets, etc? If not, we need some direction as to what is required?

**A8. Correct, the trailer is to open with no furnishings. Once delivered to site the trailer will be retrofitted by DFO with existing equipment.**

Q9. There is also no mention of any analytical equipment. We just want to confirm this is the case?

**A9. No analytical equipment is required.**

Q10. In the spec there is no mention of insulation in walls, ceiling or floor, can you please confirm this?

**A10. The walls, ceiling and floor are to be insulated to a minimum rating of R20.**

Q11. The floor drains are installed in the floor with no plumbing below?

**A11. All floor drains are to be plumbed together so that potential water from each floor drain is discharged through the same pipe.**

Q12. Does the A/C unit have to be ducted?

**A12. No, the A/C unit does not need to be ducted.**

Solicitation No. - N° de l'invitation  
F1700-140641/A  
Client Ref. No. - N° de réf. du client  
F1700-140641

Amd. No. - N° de la modif.  
002  
File No. - N° du dossier  
VAN-4-37333

Buyer ID - Id de l'acheteur  
van584  
CCC No./N° CCC - FMS No./N° VME

---

Q13. There is no mention of trailer brakes and DOT lighting, it was mentioned that it did not have to be road legal but I am not sure what that all means?

**A13. Trailer brakes and DOT lighting are not required. Once delivered the trailer will only be moved in and out of storage on private property.**

Q14. In Sec 2.3 - Can the wiring be concealed in the framing rather than surface mounted in conduit?

**A14. Yes, the wiring can be concealed in the framing rather than surface mounted in conduit.**

Q15. Sec 2.3 – Can the plugs, switches, and lights be flush mount rather than surface. Please note: this would provide a much cleaner, safer finish to the interior?

**A15. Yes, plugs, switches and lights can be flush mounted rather than surface mounted.**

**Please Note: No additional equipment or furnishing are included as part of this requirement. Fisheries and Oceans Canada will retrofit the trailer with existing equipment once the trailer has been supplied.**

- **ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**