

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Réception des soumissions - TPSGC / Bid Receiving
- PWGSC
1550, Avenue d'Estimauville
1550, D'Estimauville Avenue
Québec
Québec
G1J 0C7

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
TPSGC/PWGSC
601-1550, Avenue d'Estimauville
Québec
Québec
G1J 0C7

Title - Sujet Marine Generator Sets	
Solicitation No. - N° de l'invitation F3089-14G094/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F3089-14G094	Date 2015-03-31
GETS Reference No. - N° de référence de SEAG PW-\$QCN-006-16387	
File No. - N° de dossier QCN-4-37338 (006)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-05-11	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lamarre, Jacynthe	Buyer Id - Id de l'acheteur qcn006
Telephone No. - N° de téléphone (418) 649-2776 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

F3089-14G094/A

Amd. No. - N° de la modif.

001

Buyer ID - Id de l'acheteur

qcn006

Client Ref. No. - N° de réf. du client

F3089-14G094

File No. - N° du dossier

QCN-4-37338

CCC No./N° CCC - FMS No/ N° VME

The purpose of this amendment is to insert the terms and conditions and the annexes A and B of the Request for Proposal which were missing.

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

TABLE OF CONTENTS

PART 1 - GENERAL INFORMATION

- 1.1 Requirement
- 1.2 Debriefings

PART 2 - BIDDER INSTRUCTIONS

- 2.1 Standard Instructions, Clauses and Conditions
- 2.2 Submission of Bids
- 2.3 Enquiries - Bid Solicitation
- 2.4 Applicable Laws

PART 3 - BID PREPARATION INSTRUCTIONS

- 3.1 Bid Preparation Instructions

PART 4 - EVALUATION PROCEDURES AND BASIS OF SELECTION

- 4.1 Evaluation Procedures
- 4.2 Basis of Selection

PART 5 - CERTIFICATIONS

- 5.1 Certifications Precedent to Contract Award

PART 6 - RESULTING CONTRACT CLAUSES

- 6.1 Security Requirement
- 6.2 Requirement
- 6.3 Standard Clauses and Conditions
- 6.4 Term of Contract
- 6.5 Authorities
- 6.6 Payment
- 6.7 Invoicing Instructions
- 6.8 Certifications
- 6.9 Applicable Laws
- 6.10 Priority of Documents
- 6.11 Defence Contract
- 6.12 SACC Manual Clauses

List of Annexes:

Annex A - Requirements
Annex B - Pricing

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

PART 1 - GENERAL INFORMATION

1.1 Requirement

The requirement is detailed under Annex A - Requirement.

1.2 Debriefings

Bidders may request a debriefing on the results of the bid solicitation process. Bidders should make the request to the Contracting Authority within 15 working days of receipt of the results of the bid solicitation process. The debriefing may be in writing, by telephone or in person.

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

PART 2 - BIDDER INSTRUCTIONS

2.1 Standard Instructions, Clauses and Conditions

All instructions, clauses and conditions identified in the bid solicitation by number, date and title are set out in the [Standard Acquisition Clauses and Conditions Manual](https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual) (<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual>) issued by Public Works and Government Services Canada.

Bidders who submit a bid agree to be bound by the instructions, clauses and conditions of the bid solicitation and accept the clauses and conditions of the resulting contract.

The [2003](#) (2014-09-25), Standard Instructions - Goods or Services - Competitive Requirements, are incorporated by reference into and form part of the bid solicitation.

2.2 Submission of Bids

Bids must be submitted only to Public Works and Government Services Canada (PWGSC) Bid Receiving Unit by the date, time and place indicated on page 1 of the bid solicitation.

2.3 Enquiries - Bid Solicitation

All enquiries must be submitted in writing to the Contracting Authority no later than five (5) calendar days before the bid closing date. Enquiries received after that time may not be answered.

Bidders should reference as accurately as possible the numbered item of the bid solicitation to which the enquiry relates. Care should be taken by bidders to explain each question in sufficient detail in order to enable Canada to provide an accurate answer. Technical enquiries that are of a proprietary nature must be clearly marked "proprietary" at each relevant item. Items identified as "proprietary" will be treated as such except where Canada determines that the enquiry is not of a proprietary nature. Canada may edit the question(s) or may request that the Bidder do so, so that the proprietary nature of the question(s) is eliminated, and the enquiry can be answered to all bidders. Enquiries not submitted in a form that can be distributed to all bidders may not be answered by Canada.

2.4 Applicable Laws

Any resulting contract must be interpreted and governed, and the relations between the parties determined, by the laws in force in Quebec.

Bidders may, at their discretion, substitute the applicable laws of a Canadian province or territory of their choice without affecting the validity of their bid, by deleting the name of the Canadian province or territory specified and inserting the name of the Canadian province or territory of their choice. If no change is made, it acknowledges that the applicable laws specified are acceptable to the bidders.

PART 3 - BID PREPARATION INSTRUCTIONS

3.1 Bid Preparation Instructions

Canada requests that bidders provide their bid in separately bound sections as follows:

Section I: Technical Bid (1 hard copy)
Section II: Financial Bid (1 hard copy)
Section III: Certifications (1 hard copy)

Prices must appear in the financial bid only. No prices must be indicated in any other section of the bid.

Canada requests that bidders follow the format instructions described below in the preparation of their bid:

- (a) use 8.5 x 11 inch (216 mm x 279 mm) paper;
- (b) use a numbering system that corresponds to the bid solicitation.

In April 2006, Canada issued a policy directing federal departments and agencies to take the necessary steps to incorporate environmental considerations into the procurement process Policy on Green Procurement (<http://www.tpsgc-pwgsc.gc.ca/ecologisation-greening/achats-procurement/politique-policy-eng.html>). To assist Canada in reaching its objectives, bidders should:

- 1) use 8.5 x 11 inch (216 mm x 279 mm) paper containing fibre certified as originating from a sustainably-managed forest and containing minimum 30% recycled content; and
- 2) use an environmentally-preferable format including black and white printing instead of colour printing, printing double sided/duplex, using staples or clips instead of cerlox, duotangs or binders.

Section I: Technical Bid

In their technical bid, bidders should explain and demonstrate how they propose to meet the requirements and how they will carry out the Work.

Technical documents describing the proposed product at Annex B should accompany the bid.

Bidders should include with their bids the “Table of Technical Compliance” of Part 4, item 4.1.1.

Section II: Financial Bid

Bidders must submit their financial bid in accordance with the Basis of Payment. The total amount of Applicable Taxes must be shown separately.

3.1.1 Exchange Rate Fluctuation

SACC Manual clause C3011T (2013-11-06), Exchange Rate Fluctuation

Section III: Certifications

Bidders must submit the certifications required under Part 5.

PART 4 - EVALUATION PROCEDURES AND BASIS OF SELECTION**4.1 Evaluation Procedures**

- (a) Bids will be assessed in accordance with the entire requirement of the bid solicitation including technical and financial evaluation criteria.
- (b) An evaluation team composed of representatives of Canada will evaluate the bids.

4.1.1 Technical Evaluation**4.1.1.1 Mandatory technical requirements precedent to contract award**

	Description	Remplie et joint
1	Attestation « approved marine » for the offered product, as per item 3.1 of annex A.	
2	Environmental compliance certificate for the offered product, as per item 3.3 of annex A.	
3	Certification ISO 9001 or equivalent for the offered product, as per item 3.11 of annex A.	
4	Attestation of manufacturer authorized reseller to make sale and maintenance of offered product, as per items 4.1 and 4.2 of annex A.	

4.1.1.2 Table of technical compliance

Note: The Bidder should indicate, for each following criteria, whether the proposed system complies or not by checking the relevant box. The Bidder should clearly demonstrate how the proposed system complies to each criteria. Where it is necessary to refer to other documentation that is included in the proposal, Bidders should include the precise location of the reference material including the title of the document, and the page and paragraph numbers. *It is the bidder's responsibility to provide enough details to permit a complete evaluation.*

TABLE OF TECHNICAL COMPLIANCE				
Purchase of four (4) Marine Generator Sets				
		Compliant		Description / References
		Yes	No	
1. Electrical Properties				
a.	Minimum Prime Power: 5 kW			
b.	Cycle : 60 Hz.			
c.	Phase : 1 phase			
d.	Minimum Voltage : 120 Volts			
e.	Current : 40 à 50 A.			
f.	Maximum rotation speed : 3 000 RPM			

TABLE OF TECHNICAL COMPLIANCE				
Purchase of four (4) Marine Generator Sets				
		Compliant		Description / References
		Yes	No	
2. Dimensions				
a.	Maximum length : 665 mm			
b.	Maximum width : 515 mm			
c.	Maximum height : 525 mm			
d.	Maximum dry weight : 170 kg			
3. The Generator sets must :				
3.1	be approved marine grade by a Classification Society with which Transport Canada has an official agreement (for example, Lloyds Register Marine);			
3.2	have the following connections: Fuel intake, fuel outlet, sea water, battery power and gas exhaust on the right side of the housing to allow installation in the vessel's confined space (680 mm x 530 mm x 540 mm);			
3.3	have an environmental compliance certificate from the Environmental Protection Agency (EPA) meeting minimum Tier 4 standards;			
3.4	have a start switch with ignition pre-heater.			
3.5	have a 4-stroke diesel motor running on No. 2 diesel oil with a minimum of 2 cylinders with a starter and 12 V. alternator/charger;			
3.6	have a maximum full load noise output of 71 dB(A) measured at 1 meter;			
3.7	have a front inspection panel providing access to: the sea water pump, oil filler, fuel/oil filter and oil level, oil drain, coolant drain, fire extinguisher fitting and fuel filter;			
3.8	<div>a) have an electronic regulator to maintain isochronous frequency control and perfectly regulate voltage to meet the power requirements of digital equipment and computers;</div> <div>b) have a maximum frequency variation of +/- 0.5% and voltage variation of +/- 1.5%;</div>			
3.9	a) have a independent remote monitoring and automatic stop system with a minimum 25 foot cable to read the diagnostics for the following: battery voltage, high freshwater temperature,			

TABLE OF TECHNICAL COMPLIANCE Purchase of four (4) Marine Generator Sets				
		Compliant		Description / References
		Yes	No	
	high exhaust temperature, low oil pressure, overspeed, high voltage, starter motor stop, sea water flow stop. b) a running indicator light; c) a digital remote control with AC power voltage and frequency display; d) a motor start/stop button; e) an hour meter.			
3.10	have a diesel fuel primer pump with a lifting capacity of at least 1.22 m.			
3.11	be designed and built in a ISO 9001 certified or equivalent standard facility.			
4. The supplier must :				
4.1	be a manufacturer authorized reseller;			
4.2	have manufacturer trained and approved technician(s);			
4.3	be able to provide spare parts within a maximum of 72 hours;			
4.4	be able to provide manufacturer approved technical support, maintenance and mechanical/electrical repair services, on site and in shop, in French.			

4.1.2 Financial Evaluation

SACC Manual Clause [A0220T](#) (2014-06-26), Evaluation of Price

4.2 Basis of Selection

SACC Manual Clause A0069T (2007-05-25), Basis of Selection

PART 5 – CERTIFICATIONS

Bidders must provide the required certifications and associated information to be awarded a contract.

The certifications provided by bidders to Canada are subject to verification by Canada at all times. Canada will declare a bid non-responsive, or will declare a contractor in default in carrying out any of its obligations under the Contract, if any certification made by the Bidder is found to be untrue whether made knowingly or unknowingly, during the bid evaluation period or during the contract period.

The Contracting Authority will have the right to ask for additional information to verify the Bidder's certifications. Failure to comply and to cooperate with any request or requirement imposed by the Contracting Authority may render the bid non-responsive or constitute a default under the Contract.

5.1 Certifications Precedent to Contract Award

The certifications listed below should be completed and submitted with the bid, but may be submitted afterwards. If any of these required certifications is not completed and submitted as requested, the Contracting Authority will inform the Bidder of a time frame within which to provide the information. Failure to comply with the request of the Contracting Authority and to provide the certifications within the time frame provided will render the bid non-responsive.

5.1.1 Integrity Provisions - Associated Information

By submitting a bid, the Bidder certifies that the Bidder and its Affiliates are in compliance with the provisions as stated in Section 01 Integrity Provisions - Bid of Standard Instructions [2003](#). The associated information required within the Integrity Provisions will assist Canada in confirming that the certifications are true.

5.1.2 Federal Contractors Program for Employment Equity - Bid Certification

By submitting a bid, the Bidder certifies that the Bidder, and any of the Bidder's members if the Bidder is a Joint Venture, is not named on the Federal Contractors Program (FCP) for employment equity "[FCP Limited Eligibility to Bid](#)" list (http://www.labour.gc.ca/eng/standards_equity/eq/emp/fcp/list/inelig.shtml) available from [Employment and Social Development Canada \(ESDC\) - Labour's](#) website.

Canada will have the right to declare a bid non-responsive if the Bidder, or any member of the Bidder if the Bidder is a Joint Venture, appears on the "[FCP Limited Eligibility to Bid](#)" list at the time of contract award.

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

PART 6 - RESULTING CONTRACT CLAUSES

The following clauses and conditions apply to and form part of any contract resulting from the bid solicitation.

6.1 Security Requirement

There is no security requirement applicable to this Contract.

6.2 Requirement

The Contractor must provide four (4) Marine Generator Sets, in accordance with the Requirement at Annex " A ".

6.3 Standard Clauses and Conditions

All clauses and conditions identified in the Contract by number, date and title are set out in the *Standard Acquisition Clauses and Conditions Manual* (<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual>) issued by Public Works and Government Services Canada.

6.3.1 General Conditions

2010A (2014-11-27), General Conditions - Goods (Medium Complexity), apply to and form part of the Contract.

The paragraph 09 « Warranty » of 2010A, General Conditions – Goods (Medium Complexity), is amended as follows:

Delete: 12 months

Insert: 24 months

6.4 Term of Contract

The period of the contract is from date of contract to the acceptance of the goods by Canada

6.4.1 Delivery Date *(will be fill out at contract award)*

All the deliverables must be received on or before _____.

6.5 Authorities

6.5.1 Contracting Authority

The Contracting Authority for the Contract is:

Name: Jacynthe Lamarre
Title: Supply Specialist
Public Works and Government Services Canada
Acquisitions Branch

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

Telephone: 418-649--2776
Facsimile: 418-648-2209
E-mail address: jacynthe.lamarre@tpsgc-pwgsc.gc.ca

The Contracting Authority is responsible for the management of the Contract and any changes to the Contract must be authorized in writing by the Contracting Authority. The Contractor must not perform work in excess of or outside the scope of the Contract based on verbal or written requests or instructions from anybody other than the Contracting Authority.

6.5.2 Project Authority

The Project Authority for the Contract is: (to be filled and contract award)

Name: _____
Title: _____
Organization: _____
Address: _____

Telephone : _____
Facsimile: _____
E-mail address: _____

The Project Authority is the representative of the department or agency for whom the Work is being carried out under the Contract and is responsible for all matters concerning the technical content of the Work under the Contract. Technical matters may be discussed with the Project Authority, however the Project Authority has no authority to authorize changes to the scope of the Work. Changes to the scope of the Work can only be made through a contract amendment issued by the Contracting Authority.

6.5.3 Contractor's Representative

The Contractor's representative will be:

Name: _____
Title: _____

Telephone : _____

Facsimile: _____

E-mail address: _____

6.6 Payment

6.6.1 Basis of payment – Firm Price

In consideration of the Contractor satisfactorily completing all of its obligations under the Contract, the Contractor will be paid a firm price as specified in *Annex B*, for a cost of \$ _____. Customs duties are *included* and Applicable Taxes are extra.

Canada will not pay the Contractor for any design changes, modifications or interpretations of the Work, unless they have been approved, in writing, by the Contracting Authority before their incorporation into the Work.

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

6.6.2 Limitation of Price

SACC Manual clause C6000C (2011-05-16), Limitation of Price

6.6.3 Single Payment

SACC Manual clause H1000C (2008-05-12), Single Payment

6.6.3 Shipping Instructions - Delivery at Destination

Goods must be consigned to the destination specified in the Contract and delivered:

Delivered Duty Paid (DDP), Fisheries and Oceans Canada – Canadian Coast Guard, 850, route de la Mer, Mont-Joli, Que., Canada, G5H 3Z4, Incoterms 2000 for shipments from a commercial contractor.

6.7 Invoicing Instructions

Invoice to be made to the name of:

DFOinvoicing-MPOfacturation@dfo-mpo.gc.ca

Write the name of the contact person;
Michelle Turcotte – Tel. 418 648-5930

An electronic copy must be transmitted to the Contracting Authority.

6.8 Certifications

6.8.1 Compliance

Compliance with the certifications and related documentation provided by the Contractor in its bid is a condition of the Contract and subject to verification by Canada during the term of the Contract. If the Contractor does not comply with any certification, provide the related documentation or if it is determined that any certification made by the Contractor in its bid is untrue, whether made knowingly or unknowingly, Canada has the right, pursuant to the default provision of the Contract, to terminate the Contract for default.

6.9 Applicable Laws

The Contract must be interpreted and governed, and the relations between the parties determined, by the laws in force in the province of Quebec.

6.10 Priority of Documents

If there is a discrepancy between the wording of any documents that appear on the list, the wording of the document that first appears on the list has priority over the wording of any document that subsequently appears on the list.

- (a) Articles of Agreement;

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

-
- (b) General conditions 2010A (2014-11-27), General Conditions - Goods (medium complexity);
 - (c) Annex A, Requirements;
 - (d) Annex B, Pricing
 - (e) Contractor's bid dated _____.

6.11 Defence Contract

SACC Manual clause A9006C (2012-07-16) Defence Contract

6.12 SACC Manual Clauses

SACC Manual clauses G1005C (2008-05-12) Insurance

ANNEX A – Requirements

Provide and deliver to the Department of Fisheries and Oceans Canada / Canadian Coast Guard, four (4) Marine Generator Sets to replace the one in four (4) Canadian Hydrographic Service vessels: GARROT, MERLU, GUILLEMOT et KRILL The generator sets will be installed in a confined space measuring 680 mm x 530 mm x 540 mm.

The Generator Sets must be in accordance with the following minimum specifications:

1. Electrical characteristics

- a. Minimum prime power: 5 kW
- b. Cycle: 60 Hz.
- c. Phase: 1 phase.
- d. Minimum voltage: 120 V.
- e. Current: 40 to 50 A.
- f. Maximum rotation speed: 3000 rpm

2. Dimensions:

- a. Maximum length: 665 mm.
- b. Maximum width: 515 mm.
- c. Maximum height. : 525 mm.
- d. Maximum dry weight: 170 kg

3. The service generators must:

1. Be approved marine grade by a Classification Society with which Transport Canada has an official agreement (for example, Lloyds Register Marine).
2. Have the following connections: Fuel intake, fuel outlet, sea water, battery power and gas exhaust on the right side of the housing to allow installation in the vessel's confined space (680 mm x 530 mm x 540 mm).
3. Have an environmental compliance certificate from the Environmental Protection Agency (EPA) meeting minimum Tier 4 standards.
4. Have a start switch with ignition pre-heater.
5. Have a 4-stroke diesel motor running on No. 2 diesel oil with a minimum of 2 cylinders with a starter and 12 V alternator/charger.
6. Have a maximum full load noise output of 71 dB(A) measured at 1 meter.
7. Have a front inspection panel providing access to: the sea water pump, oil filler, fuel/oil filter and oil level, oil drain, coolant drain, fire extinguisher fitting and fuel filter.
8. Have an electronic regulator to maintain isochronous frequency control and perfectly regulate voltage to meet the power requirements of digital equipment and computers. Have a maximum frequency variation of +/- 0.5% and voltage variation of +/- 1.5%.
9. Have a independent remote monitoring and automatic stop system with a minimum 25 foot cable to read the diagnostics for the following: battery voltage, high freshwater temperature, high exhaust temperature, low oil pressure, overspeed, high voltage, starter motor stop, sea water flow stop. Running indicator light. A digital remote control with AC power voltage and frequency display. A motor start/stop button. An hour meter.

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

-
10. Have a diesel fuel primer pump with a lifting capacity of at least 1.22 m.
 11. Be designed and built in a ISO 9001 certified or equivalent standard facility.

4. The supplier must:

1. be a manufacturer authorized reseller;
2. have manufacturer trained and approved technician(s);
3. be able to provide spare parts within a maximum of 72 hours;
4. be able to provide manufacturer approved technical support, maintenance and mechanical/electrical repair services, on site and in shop, in French.

Solicitation No. - N° de l'invitation
F3089-14G094/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
qcn006

Client Ref. No. - N° de réf. du client
F3089-14G094

File No. - N° du dossier
QCN-4-37338

CCC No./N° CCC - FMS No./N° VME

ANNEX B - Pricing

Item	Description	Quantity	Firm Unit Price	Calculated Price
1	Marine Generator Sets, as described at annex A.	4	\$	\$
TOTAL :				\$

*Customs duties are included and all applicable taxes are extra, if applicable.

Specify the brand name: _____

Specify the product number: _____

Best delivery date:

While delivery of the four (4) Generator Sets is requested by or before:

- June 11, 2015 for a quantity of two (2), the best delivery that could be offered is _____,
quantity offered: _____
and
- July 11, 2015 for two (2) more, the best delivery that could be offered is _____,
quantity offered: _____