

PART 1 - GENERAL

1.1 PRODUCT DATA

- .1 Submit product data in accordance with Section 01 33 00 - Submittals.

PART 2 - PRODUCTS

2.1 DISCONNECT SWITCHES

- .1 Fusible disconnect switch in CSA Enclosure Type 1, size as indicated.
- .2 Provision for padlocking in on-off switch position by three (3) locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuses: size as indicated, to Section 26 28 14 - Fuses- Low Voltage.
- .5 Fuseholders: re-locatable and suitable without adaptors, for type and size of fuse indicated.
- .6 Quick-make, quick-break action.
- .7 ON-OFF switch position indications on switch enclosure cover.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 01 - Electrical General Requirements.
- .2 Indicate name of load controlling on size 4 nameplate.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install disconnect switches complete with fuses.