



**L.P. GANDER &  
ASSOCIATES LTD.**

CONSULTING ENGINEERS ELECTRICAL


106-3855 HENNING DRIVE BURNABY  
B.C. V5C 6N3 email: lpg@oxion.net  
TEL: 604 298 0939 FAX: 604 298 9823



Feb 23, 2015.




DETAIL 'X' - BUILDING U  
NTS




BUILDING 'U' CONTROL POST ANNUNCIATOR  
NTS


| ITEM | DESCRIPTION   | COMMENTS  |
|------|---|---|
| a    | EXISTING ANGLED SURFACE BOX FOR GUI ANNUNCIATOR                                   | RE-USE BOX FOR LCD ANNUNCIATOR  |
| b    | FLUSH MOUNT ANNUNCIATOR IN ANGLED FACE OF OLD GUI ANNUNCIATOR BOX                 | INSTALL BACK BOX ON ANNUNCIATOR. INSTALL UNISTRUT SUPPORTS OR OTHER SUPPORT TO FIX NEW LCD ANNUNCIATOR AND BACK BOX FLUSH MTD INTO ANGLED SURFACE BOX   |
| c    | PROVIDE 16 GAUGE BLACK FINISHED SHEETMETAL CLOSURE TO FRONT OF ANGLED SURFACE BOX | USE BLACK GLOSS FINISH. ARRANGE AND PAY FOR PAINTING TO BE DONE PROFESSIONALLY. FOR EXAMPLE AN AUTO BODY SHOP. UNPROFESSIONAL PAINT-JOBS WILL BE REJECTED BY THE D.R. AND REPLACED AT NO COST TO THE CONTRACT |




DETAIL 'X' - BUILDING F  
NTS



PENTHOUSE - BUILDING U  
SCALE: 1:100



PART PLAN LEVEL 2 - BUILDING U  
SCALE: 1:100 (LEVEL 1 SIMILAR)



KEY PLAN - SHADING INDICATES BUILDINGS  
NTS IN WHICH WORK IS TO BE PERFORMED

| Revision | Description       | Date     |
|----------|-------------------|----------|
| 1        | Issued For Tender | 02/23/15 |

Correctional Service Canada  
Abbotsford BC  
Pacific Institution

Project title/Titre du projet

Fire Alarm System  
Computer Replacement

Consultant/Signature Only

Designed by/Concepté par  
L.P. GANDER

Drawn by/Dessiné par  
LMG

Jan 2015

Project Manager/Administrateur de Projet TFSOC

Tony Tang

Regional Manager, Architectural and Engineering Services  
Gestionnaire régional, Services d'architecture et de génie, TFSOC

Drawing title/Titre du dessin

Details 2

| Project No./No. du projet | Sheet/Feuille | Revision no./no. de révision |
|---------------------------|---------------|------------------------------|
| R.072304.001              | E4            |                              |