



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Highway #16 Guardrail Replacement Jasper National Park		
Solicitation No. - No. de l'invitation 5P420-15-5026/A		Date: April 14, 2014
GETS Reference No. - No de reference de SEAG PW-15-00677590		Amendment No. - N° de la modif. 003
Solicitation Closes:		
at - á 02:00 PM	on - le April 15, 2015	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Pahl		
Telephone No. - No de téléphone (403) 292-4572		Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 3

This amendment is issued to answer questions from a potential bidder.

- Q15.** In Amendment #2, Question 8 you state that you will accept the Standard AT post length of 1829mm long. Are you saying you will accept the standard wood post noted on TEB 3.01?
http://www.transportation.alberta.ca/Content/docType233/Production/teb3.01_R13.pdf this link should take you to TEB 3.01. OR, do the posts still have to be steel as your project spec indicates but are allowed to be the shorter 1829mm length?
- A15.** Posts shall be steel as noted in Section 32 17 23 Clause 2.3.2 and shall be either 1970mm or 1829mm long.
- Q16.** In Amendment #2, Question 13 – If there are 12 installation lengths, I assume that there is 1 Fleat 350 for each end thus no other type of termination is required (ie Winged or Flared End Terminal). Can you confirm?
- A16.** All newly installed guardrail ends shall be treated with an Impact Absorbing Guardrail End Terminal as noted in Section 32 17 23.

All other terms and conditions remain unchanged.