



Parks Canada Agency  
111 Water Street East  
Cornwall, ON  
K6H 6S3

**QUESTIONS AND ANSWERS. NO. 1**

Comments - Commentaries

Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency  
111 Water Street East  
Cornwall, ON  
K6H 6S3

Title-Sujet <b>Replacement of Fuel Storage Tanks and Pumps – Cheticamp NS</b>		Date <b>Apr 16, 2015</b>
Solicitation No. - No. de l'invitation <b>10142042</b>	Amendment No. – No modif.	
GETS Reference No. – No de reference de SEAG N/A		
Solicitation Closes L'invitation prend fin – at – à <b>2 :00 p.m.</b> on – le <b>April 24, 2015</b>	Time Zone Fuseau horaire - <b>Eastern Standard Time (EST)</b>	
F.O.B. - F.A.B.		
Address Inquiries to: - Adresser toute demande de renseignements à : <b>Céline Morin (celine.morin@pc.gc.ca)</b>		
Telephone No. - No de téléphone <b>613-938-5940</b>	Fax No. – No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:  <b>Cheticamp Compound Cape Breton Highlands National Park 16649 Cabot Trail Cheticamp NS B0E 1H0</b>		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur  <b>Telephone No. - N° de téléphone : Facsimile No. - N° de télécopieur :</b>		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur  _____		
<b>Name/Nom</b>		<b>Title/Titre</b>
_____ <b>Signature</b>		_____ <b>Date</b>

## **QUESTIONS & ANSWERS #1**

**THE FOLLOWING QUESTIONS HAVE BEEN ASKED BY POTENTIAL BIDDERS.  
THE ANSWERS ARE PROVIDED BELOW FOR YOUR INFORMATION.**

Q1) Are the tanks to be 4500 litre or 4800 litre?

**A1) The 2 existing fuel storage tanks are 4800 litres in size however Parks Canada will accept tanks that are 4500 litres in size if 4800 litre tanks are not available or the alternate size will result in a substantial cost savings. Please indicate alternate size on the Basis of Payment and provide an explanation of the advantages on a separate sheet.**

Q2) The pump controller (PC1) in the past I sold to Parks Canada sites ( Fort Louisburg, Cape Breton, N.S) & (Kejimkujik Park, N.S) Computrol C6000 with mag stripe readers, is it the intention to be consistent and stay with the same reader, or should I be looking at other pump controllers.

**A2) The Computrol C6000 pump controller which is in use at other Parks Canada locations has both mag stripe and optional proximity card reader capabilities required in this application therefore the C6000 controller or an equivalent alternative is acceptable.**

Q3) If I am looking at another pump controller, do they have to have a mag stripe reader or can we use a proximity reader?

**A3) The pump controller must have both mag stripe and optional proximity card reader capabilities as specified.**