



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS A:  
Bid Receiving/Réception des  
sousmissions**

**RCMP / GRC  
Procurement & Contracting services  
c/o Commissionaires, F Division  
6101 Dewdney Avenue  
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:  
(306) 780-5232**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les memes.

**Comments - Commentaries**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Facsimile No. - No de télécopieur:**

**Telephone No. - no de téléphone:**

Title-Sujet Loading Dock and Site Paving Renovation, Depot, Regina, SK	
Solicitation No. - No. de l'invitation M5000-5-4871/A	Date 21 April 2015
Amendment No. - No modif. 03	
Client Reference No. - No. De Référence du Client N/A	
GETS REFERENCE No. - No. de Référence de SEAG PW-15-00678607	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 16 April 2015	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Bonny Manz, Senior Contracting Officer	
Telephone No. - No de téléphone (306) 780-3352	Fax No. - N° de FAX: (306) 780-5232
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police 5600 - 11th Avenue Regina, SK S4P 3J7	
This document does contain a PERSONNEL SECURITY Clearance requirements	
Delivery Required - Livraison exigée: See Herein Voir aux présentes	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	
(Please sign and return cover page with bid proposal./ Signez s'il vous plaît et la page de couverture de retour avec la proposition d'offre.)	



The purpose of this amendment is to add Addenda, attached separately; to answer questions, and to replace the "BID AND ACCEPTANCE FORM", as follows:

**QUESTIONS AND ANSWERS:**

**Q2.** Is the existing concrete pad to be removed?

**A2.** Yes

**Q3.** What type of controls are to be used, Honeywell or Andover?

**A3.** Honeywell.

**Q4.** The sewer leaving the sub basement actually has a 45 degree elbow imbedded in the wall, the drawings show it leaving the building straight, with the 45 approximately 3' out.

**A4.** *The drawings are based on the survey plan. Refer to attached mechanical addendum for clarification.*

**Q5.** What is the scale on the drawings/C2.0 drawing?

**A5.** *Original plot was 1:150 but skew during printing is possible. Contractor should verify scale using dimensions labeled on C2.0.*

**Q6.** Are paving areas to be light duty asphalt?

**A6.** Yes.

**Q7.** Are any curbs to be installed?

**A7.** No.

**Q8.** Is there a known or estimated thickness of the existing slab to be removed where the old transformers were located?

**A8.** No.

**Q9.** Access to the site is over top of a tunnel of which is questionable in terms of its structural integrity. Is there any concern with the construction traffic materials, etc. traveling over this area?

**A9.** *An alternate route has been determined and a drawing with that information is attached separately.*

**Q10.** For the scissors lift, do you really need 15,000 lbs. capacity? If not 8,000 lbs capacity is possible with a double scissor.

**A10.** *The crane has a 5 ton (11,200 lbs) capacity, so the lift will need to support anything the crane lifts. If there is a lift that will support 12,000 lbs, that would work.*

**Q11.** Does the scissors lift need 83" of vertical travel?

**A11.** *Yes, as it must reach from the lowered height to the height of the truck bed. See dimensions in drawings. The truck bed is 4' from the grade, and from the grade to the lowered height of the lift is 2'11", which is a total of 83".*

**Q13.** If piles are encountered under the slab to be removed, can they be left, or addressed as a change after the fact?

**A13.** *They are to be removed. See the request for separate pricing on the pile removal on the replacement "BID AND ACCEPTANCE FORM", as the exact number of piles is unconfirmed.*

**DELETE:** BID AND ACCEPTANCE FORM (BA) in its entirety

**INSERT:** The BID AND ACCEPTANCE FORM (BA) on Pages 3 and 4 of this amendment.



**BID AND ACCEPTANCE FORM (BA)**

**BA01 IDENTIFICATION**

Work in this contract comprises, but is not limited to, the following for the Royal Canadian Mounted Police (RCMP): Re-surfacing of the loading dock area including the installation of a platform lift and slab heating. The project includes some electrical, mechanical, structural, and site work, as described in the specifications and drawing and any amendments thereto.

**BA02 BUSINESS NAME AND ADDRESS OF BIDDER**

Name: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

Telephone: \_\_\_\_\_

Fax: \_\_\_\_\_

GST #: \_\_\_\_\_

E-mail: \_\_\_\_\_

**BA03 THE OFFER**

**A) Base Bid:**

The Bidder offers to Her Majesty the Queen in right of Canada to perform and complete the Work for the above named project, in accordance with the Bid Documents, for the Bid Amount of

\$ \_\_\_\_\_ excluding GST/HST.  
 (amount in numbers)

**B) Pile removal, to be priced separately (estimated at 6).\***

\$ \_\_\_\_\_/ea x 6 = \$ \_\_\_\_\_ excluding GST/HST  
 (amount in numbers)

**TOTAL (A + B):** \$ \_\_\_\_\_ excluding GST/HST

The tenders will be evaluated based on the lowest total bid.

**\*A Change Order will be done, if necessary, to increase or decrease the contract value, once the RCMP Project Manager has been advised on the actual number of piles.**



---

Government  
of Canada

Gouvernement  
du Canada

Solicitation No./No de l'invitation: M5000-5-4871/A  
Amendment No./No de Modification: 03

---

**BA04 BID VALIDITY PERIOD**

The bid shall not be withdrawn for a period of 60 days following the date of solicitation closing.

**BA05 ACCEPTANCE AND CONTRACT**

Upon acceptance of the Contractor's offer by Canada, a binding Contract shall be formed between Canada and the Contractor. The documents forming the Contract shall be the contract documents identified in Contract Documents (CD).

**BA06 CONSTRUCTION TIME**

The Contractor shall perform and complete the Work within 20 weeks of award.

**BA07 BID SECURITY**

The Bidder is enclosing bid security with its bid in accordance with GI08 - Bid Security Requirements of R2710T - General Instructions - Construction Services – Bid Security Requirements.

**BA08 SIGNATURE**

\_\_\_\_\_  
Name and title of person authorized to sign on behalf of Bidder (Type or print)

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date