



NOTE:
SKETCH NOTES REFLECT ADDENDUM REVISIONS. ALL OTHER NOTES
FROM C05 APPLY TO NEW SERVICING DESIGN THAT IS UNCHANGED.

STRUCTURE TABLE		
STRUCTURE NAME:	PIPES IN:	PIPES OUT
NCB1	1050 mm RIM = 1.77 SUMP = -1.27 INV OUT = 0.175	NCB1, 300 mm PVC INV OUT = 0.18
NCB2	1050 mm RIM = 2.34 SUMP = 0.46 INV OUT = 0.907	NCB2, 300 mm PVC INV OUT = 0.91
NCB3	1050 mm RIM = 1.66 SUMP = -0.79 INV OUT = -0.339	NCB3, 375 mm CONC INV OUT = -0.34
NCB4	1050 mm RIM = 1.72 SUMP = 0.24 INV OUT = 0.688	NCB4, 300 mm PVC INV OUT = 0.69
NCBMH1	1050 mm RIM = 2.35 SUMP = -1.55 INV IN = -0.246 INV IN = 0.837 INV OUT = -0.346	NCBMH1, 375 mm CONC INV OUT = -0.35

STRUCTURE TABLE		
STRUCTURE NAME:	PIPES IN:	PIPES OUT
NSTMH1	1200 mm RIM = 1.77 SUMP = -0.54 INV IN = -0.440 INV IN = -0.440 INV OUT = -0.538	NSTMH1, 525 mm CONC INV OUT = -0.54
NSTMH2 (TREATMENT)	1200 mm RIM = 1.97 SUMP = -2.38 INV IN = -0.778 INV OUT = -0.878	NSTMH2 (TREATMENT), 533 mm HDPE INV OUT = -0.88 (610 O.D.)
NSTMH3	1200 mm RIM = 1.96 SUMP = -0.76 INV IN = -0.614 INV IN = 0.393 INV OUT = -0.764	NSTMH3, 525 mm CONC INV OUT = -0.76



REFERENCE DWG C05

Public Works and
Government Services
Canada

Troux Publics et
Services gouvernementaux
Canada

LOCATION PLAN: NTS

revisions

project

date

ST. JOHN'S COAST GUARD
SITE REDEVELOPMENT
SOUTHSIDE BASE
ST. JOHN'S
NEWFOUNDLAND

drawing

dessin

SERVICING
REVISIONS

designed AB

compté

drawn AB

dessiné

approved NL

approuvé

date

15-04-22

Tender

15-04-22

PWSC Project Manager

Administrateur de projets TPSCC

project number

R.053663.006

drawing no.

CSK-09

no. du dessin

E-DRM/GDD-E: 512652-0001-D-C-SKT-0005-01-C02-02