



Parks Canada Agency
111 Water Street East
Cornwall, ON
K6H 6S3

QUESTIONS AND ANSWERS. NO. 3

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
111 Water Street East
Cornwall, ON
K6H 6S3

Title-Sujet Replacement of Fuel Storage Tanks and Pumps – Cheticamp NS		Date Apr 27, 2015
Solicitation No. - No. de l'invitation 10142042	Amendment No. – No modif.	
GETS Reference No. – No de reference de SEAG N/A		
Solicitation Closes L'invitation prend fin – at – à 2 :00 p.m. on – le April 30, 2015	Time Zone Fuseau horaire - Eastern Standard Time (EST)	
F.O.B. - F.A.B.		
Address Inquiries to: - Adresser toute demande de renseignements à : Céline Morin (celine.morin@pc.gc.ca)		
Telephone No. - No de téléphone 613-938-5940	Fax No. – No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Cheticamp Compound Cape Breton Highlands National Park 16649 Cabot Trail Cheticamp NS B0E 1H0		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur Telephone No. - N° de téléphone : Facsimile No. - N° de télécopieur :		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur _____		
Name/Nom		Title/Titre
_____ Signature		_____ Date

QUESTIONS & ANSWERS #3

**THE FOLLOWING QUESTIONS HAVE BEEN ASKED BY POTENTIAL BIDDERS.
THE ANSWERS ARE PROVIDED BELOW FOR YOUR INFORMATION.**

Q 1 Please explain what the note below refers to.

The note below, found in the top right hand corner of M1, refers to the supply and installation of two posts and base plates secured to the concrete pad in order to store and contain a future spill kit drum (Spill kit would contain a typical 205 L drum with fuel containment boom, absorbent pads, etc.). We do not carry the spill kit itself but an area dedicated to strap the drum down and keep it in place.

“Two (2) 50mm X 50mm X 1500mm steel posts with 150mm X 150mm base plate secured to containment platform. Provide straps for securement of containment boom weatherproof storage drums. Provide corrosion resistant paint and primer to match fuel storage tank requirements.”