



Parks Canada Agency  
111 Water Street East  
Cornwall, ON  
K6H 6S3

**QUESTIONS AND ANSWERS. NO. 4**

Comments - Commentaries

Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency  
111 Water Street East  
Cornwall, ON  
K6H 6S3

Title-Sujet <b>Replacement of Fuel Storage Tanks and Pumps – Cheticamp NS</b>		Date Apr 28, 2015
Solicitation No. - No. de l'invitation <b>10142042</b>	Amendment No. – No modif.	
GETS Reference No. – No de reference de SEAG N/A		
Solicitation Closes L'invitation prend fin – at – à 2 :00 p.m. on – le April 30, 2015	Time Zone Fuseau horaire - Eastern Standard Time (EST)	
F.O.B. - F.A.B.		
Address Inquiries to: - Adresser toute demande de renseignements à : <b>Céline Morin (celine.morin@pc.gc.ca)</b>		
Telephone No. - No de téléphone <b>613-938-5940</b>	Fax No. – No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:  <b>Cheticamp Compound Cape Breton Highlands National Park 16649 Cabot Trail Cheticamp NS B0E 1H0</b>		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur          <b>Telephone No. - N° de téléphone : Facsimile No. - N° de télécopieur :</b>		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Name/Nom		Title/Titre
Signature		Date

## **QUESTIONS & ANSWERS #4**

**THE FOLLOWING QUESTIONS HAVE BEEN ASKED BY POTENTIAL BIDDERS.  
THE ANSWERS ARE PROVIDED BELOW FOR YOUR INFORMATION.**

Q 1. Addendum #1 General Item #2. It is implied that you want the C6000 with mag strips and optional proximity card capability. In Item #3 the controller must have mag strip or proximity card capability. Which do you want?

A1. The Computrol C-6000 is configurable with either magnetic stripe or proximity card reader but not both. The intent is to include magnetic stripe keycards and include 100 cards as per the Pump Control Unit Schedule on Drawing M2.

Q 2. Addendum #1 Specification Item #1, this statement clarifies that the contractor is responsible for the first fill of the tanks. The question of concern is who is expected to bare the cost of the product?

A2 The Contractor is responsible for the first fill of the tanks with Parks Canada being responsible for the cost of the fuel at the time of the fill up.