

PART 1 - GENERAL

- |   |  |
|---|--|
| <u>1.1 General</u>                      | .1 This Section covers items common to Sections of Division 26. This section supplements requirements of Division 1.   |
| <u>1.2 Codes and Standards</u>          | .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.<br><br>.2 Do overhead and underground systems in accordance with CSA C22.3 No.1 except where specified otherwise.   |
| <u>1.3 Care, Operation and Start-up</u> | .1 Instruct Departmental Representative and operating personnel in the operation, care and maintenance of systems, system equipment and components.<br><br>.2 Operating instructions to include following:<br>.1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.<br>.2 Starts up, proper adjustment, operating, lubrication, and shutdown procedures.<br>.3 Safety precautions.<br>.4 Procedures to be followed in event of equipment failure.<br>.5 Other items of instruction as recommended by manufacturer of each system or item of equipment.<br><br>.3 Arrange and pay for services of manufacturer's factory service engineer to supervise start-up of installation, check, adjust, balance and |

calibrate components and instruct operating personnel.

- .4 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with all aspects of its care and operation.

1.4 Design Requirements

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard. Equipment to operate in extreme operating conditions established in above standard without damage to equipment.

1.5 Submittals

- .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Newfoundland and Labrador, Canada.
- .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure coordinated installation.
- .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
- .4 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
- .5 Quality Control: in accordance with Section 01 45 00 - Quality Control.

.1 Provide CSA certified equipment and material. Where CSA certified equipment and material is not available, submit such equipment and material to authority having jurisdiction for approval before delivery to site.

.2 Submit test results of installed electrical systems and instrumentation.

.3 Submit, upon completion of Work, load balance report as described in 1.18 - LOAD BALANCE.

.4 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.

.6 Manufacturer's Field Reports: submit to Departmental Representative within 7 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in 1.20 FIELD QUALITY CONTROL

1.6 Permits, Fees  
and Inspection

.1 Submit to Electrical Inspection Department and Supply Authority necessary number of drawings and specifications for examination and approval prior to commencement of work.

.2 Pay associated fees.

.3 Departmental Representative will provide drawings and specifications required by Electrical Inspection Department and Supply Authority at no cost.

.4 Notify Departmental Representative of changes required by Electrical Inspection Department prior to making changes.

.5 Furnish Certificates of Acceptance from Electrical Inspection Department or authorities having jurisdiction on completion of work to Departmental Representative.

1.7 Materials and  
Equipment

- .1 Provide materials and equipment in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Equipment and material to be CSA certified. Where there is no alternative to supplying equipment which is not CSA certified, obtain special approval from Electrical Inspection Department.
- .3 Factory assemble control panels and component assemblies.

1.8 Electric  
Motors, Equipment  
and Controls

- .1 Supplier and installer responsibility is indicated in Motor, Control and Equipment Schedule on electrical drawings and related mechanical responsibility is indicated on Mechanical Equipment Schedule on mechanical drawings, where applicable.
- .2 Control wiring and conduit is specified in Division 26

1.9 Finishes

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
  - .1 Paint outdoor electrical equipment "equipment green" finish to EEMAC Y1-1.
  - .2 Paint indoor switchgear and distribution enclosures light grey to EEMAC 2Y-1.
- .2 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment

or installation, to match original paint.

- .3 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

1.10 Equipment  
Identification

- .1 Identify electrical equipment with nameplates and labels as follows:
  - .2 Nameplates:
    - .1 Lamicoid 3 mm thick plastic engraving sheet, black white face, black white core, mechanically attached with self tapping screws.

NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

- .3 Labels:
  - .1 Embossed plastic labels with 6 mm high letters unless specified otherwise.
- .4 Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.
- .5 Allow for average of twenty-five (25) letters per nameplate and label.

- .6 Identification to be English .
- .7 Nameplates for terminal cabinets and junction boxes to indicate system name and voltage characteristics.
- .8 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .9 Terminal cabinets and pull boxes: indicate system name and voltage.
- .10 Transformers: indicate capacity, primary and secondary voltages and transformer number.

1.11 Wiring  
Identification

- .1 Identify wiring with permanent indelible identifying markings, either numbered or coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.
- .2 Maintain phase sequence and colour coding throughout.
- .3 Colour code: to CSA C22.1, Canadian Electrical Code.
- .4 Use colour coded wires in communication cables, matched throughout system.

1.12 Conduit and  
Cable  
Identification

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide

auxiliary colour.

Conduit System	Prime	Auxiliary
up to 250 V	Yellow	
up to 600 V	Yellow	Green
up to 5 kV	Yellow	Blue
up to 15 kV	Yellow	Red
Telephone	Green	
Other	Green	Blue
Communication Systems		
Fire Alarm	Red	
Emergency	Red	Blue
Voice		
Other	Red	Yellow
Security Systems		

1.13 Wiring  
Terminations

- .1 Lugs, terminals, screws used for termination of wiring to be suitable for either copper or aluminum conductors.

1.14 Manufacturers  
and CSA Labels

- .1 Visible and legible, after equipment is installed.

1.15 Warning Signs

- .1 As specified and to meet requirements of Electrical Inspection Department and Departmental Representative.
- .2 Porcelain enamel decal signs, minimum size 175 x 250 mm.

1.16 Location of  
Outlets

- .1 Locate outlets in accordance with Section 26 27 26 - Wiring Devices.
- .2 Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
- .3 Change location of outlets at no extra cost or credit, providing distance does not exceed 3000 mm, and information is given before installation.
- .4 Locate light switches on latch side of doors. Locate disconnect devices in mechanical and elevator machine rooms on latch side of door.

1.17 Mounting  
Heights

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
- .3 Install electrical equipment at following heights unless indicated otherwise.
  - .1 Local switches: 1200 mm.
  - .2 Wall receptacles:
    - .1 General: 300 mm.
    - .2 Above top of continuous baseboard heater: 200 mm.
    - .3 In mechanical rooms: 1400 mm.
  - .3 Panelboards: as required by Code or as indicated.
  - .4 Telephone and interphone outlets: 300 mm.
  - .5 Wall mounted telephone and interphone outlets: 1400 mm.
  - .6 Exit lights: 2400mm.
  - .7 Emergency lighting heads: 2400 mm.



- |  |   |
|--|---|
| <u>1.18 Load Balance</u>                   | <ul style="list-style-type: none"><li>.1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance. Adjust branch circuit connections as required to obtain best balance of current between phases and record changes.</li><li>.2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.</li><li>.3 Submit, at completion of work, report listing phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load. State hour and date on which each load was measured, and voltage at time of test.</li></ul> |
| <br>                                       |   |
| <u>1.19 Conduit and Cable Installation</u> | <ul style="list-style-type: none"><li>.1 Install conduit and sleeves prior to pouring of concrete. Sleeves through concrete: schedule 40 steel pipe, sized for free passage of conduit, and protruding 50 mm.</li><li>.2 If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.</li><li>.3 Install cables, conduits and fittings to be embedded or plastered over, neatly and close to building structure so furring can be kept to minimum.</li></ul>  |
| <br>                                       |   |
| <u>1.20 Field Quality Control</u>          | <ul style="list-style-type: none"><li>.1 All electrical work to be carried out by qualified, licensed electricians or apprentices as per the conditions of the Provincial Act respecting manpower vocational training and qualification. Employees registered in a provincial apprentices program</li></ul>   |

shall be permitted, under the direct supervision of a qualified licensed electrician, to perform specific tasks - the activities permitted shall be determined based on the level of training attained and the demonstration of ability to perform specific duties.

- .2 The work of this division to be carried out by a contractor who holds a valid Code 1 Electrical Contractor License as issued by the Province.
- .3 Conduct and pay for following tests:
  - .1 Power generation and distribution system including phasing, voltage, grounding and load balancing.
  - .2 Circuits originating from branch distribution panels.
  - .3 Lighting and its control.
  - .4 Motors, heaters and associated control equipment including sequenced operations of systems where applicable.
  - .5 Systems: fire alarm system, communications.
- .4 Furnish manufacturer's certificate or letter confirming that entire installation as it pertains to each system has been installed to manufacturer's instructions.
- .5 Insulation resistance testing.
  - .1 Megger and record circuits, feeders and equipment up to 350 V with a 500 V instrument.
  - .2 Megger and record 350-600 V circuits, feeders and equipment with a 1000 V instrument.
  - .3 Check resistance to ground before energizing.
- .6 Carry out tests in presence of Departmental Representative
- .7 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.

- .8 Submit test results for Departmental Representative's review

- |   |   |
|---|---|
| <u>1.21 Co-ordination of Protective Devices</u> | .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings. |
|---|---|

PART 2 - PRODUCTS

- |                     |              |
|---------------------|--------------|
| <u>2.1 Not Used</u> | .1 Not Used. |
|---------------------|--------------|

PART 3 - EXECUTION

- |                     |              |
|---------------------|--------------|
| <u>3.1 Not Used</u> | .1 Not Used. |
|---------------------|--------------|